Energy performance certificate (EPC)

Carlshead Business Centre Paddock House Lane Sicklinghall WETHERBY LS22 4BJ Energy rating

Valid until: 25 June 2034

Certificate number:

5855-8567-0113-0003-2985

Property type Offices and Workshop Businesses


Total floor area 696 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

9 A

If typical of the existing stock

37 B

Breakdown of this property's energy performance

Main heating fuel	Biomass
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	13.85
Primary energy use (kWh/m2 per year)	158

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report</u> (/energy-certificate/9192-2215-3577-5594-0921).

Who to contact about this certificate

Contacting the assessor

Date of assessment

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Stephen Goj
Telephone	07711287225
Email	s.goj@nrgfocus.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/024303
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment Employer	NRG Focus Ltd
Employer address	Unit 31 Century Business Park Manvers Way Rotherham S63 5DA
Assessor's declaration	The assessor is not related to the owner of the property.

6 June 2024

26 June 2024