# **Energy performance certificate (EPC)**

160 High Street HERNE BAY CT6 5AJ Energy rating

Valid until: 20 June 2034

Certificate number: **7425-2031-5702-6354-6223** 

Property type

Restaurants and Cafes/Drinking Establishments/Takeaways

Total floor area


170 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

### How this property compares to others

Properties similar to this one could have ratings:

If newly built	21 A
If typical of the existing stock	86 D

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity	
Building environment	Heating and Natural Ventilation	
Assessment level	3	
Building emission rate (kgCO2/m2 per year)	74.85	
Primary energy use (kWh/m2 per year)	636	

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/6690-3937-4915-8780-3251).

### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Yvonne Forbes
Telephone	01843 298635
Email	yvonne.forbes@btinternet.com

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Elmhurst Energy Systems Ltd
EES/008610
01455 883 250
enquiries@elmhurstenergy.co.uk
Majestic Energy Assessments
38 Friends Avenue, Margate, Kent, CT9 3XQ
The assessor is not related to the owner of the property.
21 June 2024
21 June 2024