
Energy performance certificate (EPC)				
Unit 1 30 Progress Road LEIGH-ON-SEA SS9 5PR	Energy rating	Valid until:	14 February 2029	
		Certificate number:	0020-2989-0381-0680-2094	
Property type	В	1 Offices and Works	shop businesses	
Total floor area	416 square metres			

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

23 A

68 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	39.26
Primary energy use (kWh/m2 per year)	232

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/9209-4082-0818-0200-6905)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Malcolm Clarke	
Telephone	07764 859569	
Email	sales@assuredepc.co.uk	

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd	
Assessor's ID	EES/007811	
Telephone	01455 883 250	
Email	enquiries@elmhurstenergy.co.uk	

About this assessment

Employer	Sterling Energy Surveys	
Employer address	7 Graham Avenue, Broxbourne. EN10 7DN	
Assessor's declaration	The assessor is not related to the owner of the property.	
Date of assessment	6 February 2019	
Date of certificate	15 February 2019	