

# Energy performance certificate (EPC)

160 Old Street LONDON EC1V 9BW	Energy rating <b>A</b>	Valid until: <b>29 April 2028</b>  Certificate number: <b>0040-4943-0358-3890-8090</b>
--------------------------------------	---------------------------	--

Property type

B1 Offices and Workshop businesses

Total floor area


20077 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## Energy efficiency rating for this property

This property's current energy rating is A.



Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

32 | B

If typical of the existing stock

84 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

## Breakdown of this property’s energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	5
Building emission rate (kgCO2/m2 per year)	9.45
Primary energy use (kWh/m2 per year)	65

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9439-4094-0485-0800-8301\)](#).

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	Geoff Hardwick
Telephone	01527870243
Email	<a href="mailto:geoff@ecoteric.co.uk">geoff@ecoteric.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/019182
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### Assessment details

Employer	Ecoteric Ltd
Employer address	Office 10 Greenbox, Westonhall Road, Stoke road, Bromsgrove, B60 4AL
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	8 April 2018
Date of certificate	30 April 2018

---