Energy performance certificate (EPC)

8 The Sterling Centre Eastern Road Bracknell RG12 2PW Energy rating

Valid until: 4 January 2033

Certificate number: 2152-3641-0729-9600-4191

Property type

General Industrial and Special Industrial Groups

Total floor area


2,058 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	25 A
If typical of the existing stock	102 E

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity	
Building environment	Heating and Natural Ventilation	
Assessment level	3	
Building emission rate (kgCO2/m2 per year)	19.56	
Primary energy use (kWh/m2 per year)	172	

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report (/energy-certificate/6410-0642-5792-2491-1902</u>).

Who to contact about this certificate

Contacting the assessor
If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created

Assessor's name	Shayn Bennett
Telephone	01225753755
Email	info@greenrockenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID206866
Telephone	01225 667 570
Email	info@guidos.co.uk

About this assessment

Employer	GreenRock Energy
Employer address	11 Dunkirk Business Park, Southwick, Trowbridge, Wiltshire,
	BA14 9NL
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	14 September 2022
Date of certificate	5 January 2023