

Unit 2268b Dunbeath Road Elgin Industrial Estate SWINDON SN2 8EA Energy rating

Valid until: 2 February 2030

Certificate number: 0190-0630-6602-7729-0002

Property type B8 Storage or Distribution


Total floor area 805 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

26 B

If typical of the existing stock

77 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Mixed-mode with Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	65.95
Primary energy use (kWh/m2 per year)	390

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/0027-2696-0740-1600-9003).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Colin C MacGregor
Telephone	0203 325 7148
Email	info@braithwaiteenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID205861
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	Braithwaite Energy
Employer address	Kemp House, 152 City Road, London, EC1V 2NX
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	29 January 2020
Date of certificate	3 February 2020