

Energy performance certificate (EPC)

UNIT 14
BILLET ROAD
WALTHAM PARK WAY
LONDON
E17 5DU

Energy rating

B

Valid until:

29 July 2031

Certificate
number:

**0940-5252-1452-9232-
3680**

Property type

B8 Storage or Distribution

Total floor area

1,064 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

25 A

If typical of the existing stock

74 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	27.51
Primary energy use (kWh/m2 per year)	163

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/3001-1094-0363-5558-5990\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Nat Hines
Telephone	02476233144
Email	nat.hines@wensleylawz.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO034753
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	Wensley & Lawz Ltd
Employer address	116 Walsgrave Road Coventry CV2 4ED
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	19 April 2021
Date of certificate	30 July 2021
