
Energy performance certificate (EPC)			
Unit 2 Westpoint Trading Estate Alliance Road ACTON W3 0RA	Energy rating	Valid until:	22 September 2031
		Certificate number:	5120-9287-0131-1001-0923
Property type	B2 to B7 General Industrial and Special Industrial Groups		
Total floor area	486 square metres		

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock



Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	50.37
Primary energy use (kWh/m2 per year)	295

27 B

79 D

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/0985-0201-1409-7112-2104).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Shayn Bennett	
Telephone	01225753755	
Email	info@greenrockenergy.co.uk	

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID206866
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

GreenRock Energy
11 Dunkirk Business Park, Southwick, Trowbridge,
Wiltshire, BA14 9NL
The assessor is not related to the owner of the property.
19 August 2021
23 September 2021