

Energy performance certificate (EPC)

Unit 2
Boundary Road
Buckingham Road Industrial Estate
BRACKLEY
NN13 7ES

Energy rating

D

Valid until:

29 January 2028

Certificate number:

9806-3049-0780-0400-0671

Property type	B1 Offices and Workshop businesses
Total floor area	246 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is D.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

The figure shows a horizontal bar chart representing the energy rating scale. The scale consists of eight colored bars, each representing a rating from A+ to G. The bars are arranged in descending order of rating. A yellow arrow points to the 'D' rating bar, which is labeled with the score '99 D'. A horizontal line labeled 'Net zero CO2' is positioned above the 'A+' rating bar.

Rating	Score Range
A+	Under 0
A	0-25
B	26-50
C	51-75
D	76-100
E	101-125
F	126-150
G	Over 150

<https://find-energy-certificate.service.gov.uk/energy-certificate/9806-3049-0780-0400-0671?print=true>

1/3

How this property compares to others

Properties similar to this one could have ratings:

If newly built	26 B
If typical of the existing stock	75 C

Breakdown of this property’s energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	48.79
Primary energy use (kWh/m2 per year)	289

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0080-0448-0709-6479-6002\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Stephen Cocks
Telephone	01295 268516
Email	synergy_steve@btinternet.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/009696
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Synergy
Employer address	Danvers Cottage Broughton Banbury OX15 5DY
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	30 January 2018
Date of certificate	30 January 2018