# **Energy performance certificate (EPC)**

COTY Wallisdown Road BOURNEMOUTH BH11 8PL Energy rating

Valid until: 8 September 2031

Certificate number:

3438-8039-8807-8336-3534

Property type

B8 Storage or Distribution

Total floor area


25,461 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

If newly built

21 A

If typical of the existing stock

63 C

## Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Mechanical Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	48.92
Primary energy use (kWh/m2 per year)	288

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/1751-6233-2413-5569-6218).

#### Who to contact about this certificate

### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Tom Pope
Telephone	0148 988 3231
Email	tom@energyreport.co.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA123342
Telephone	020 8772 3649
Email	epc@cibsecertification.org

#### About this assessment

Date of certificate	9 September 2021
Date of assessment	16 August 2020
Assessor's declaration	The assessor is not related to the owner of the property.
Employer address	25 Barnes Wallis Road FAREHAM PO15 5TT
Employer	ENERGY REPORT LIMITED