

Energy performance certificate (EPC)

327-329 Harrow Road
London
W9 3RB

Energy rating

C

Valid until: 20 April 2033

Certificate number: 6593-4380-2561-6420-1434

Property type Offices and Workshop Businesses


Total floor area 614 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

15 A

If typical of the existing stock

62 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	13.25
Primary energy use (kWh/m ² per year)	130

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/7506-7658-9259-7187-4159\)](/energy-certificate/7506-7658-9259-7187-4159).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Robert Diamond
Telephone	01206 442 538
Email	robert.diamond@ingletonwood.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA011217
Telephone	020 8772 3649
Email	epc@cibsecertification.org

About this assessment

Employer	Ingleton Wood
Employer address	875-876 The Crescent, Colchester Business Park, Colchester, CO4 9YQ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	18 April 2023
Date of certificate	21 April 2023