

Energy performance certificate (EPC)

Jackson House Meadowcroft Business Park WHITESTAKE PR4 4BA	Energy rating C	Valid until: 18 February 2033
		Certificate number: 3657-2280-5765-6543-1378


Property type	Offices and Workshop Businesses
Total floor area	163 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	17 A
If typical of the existing stock	70 C

Breakdown of this property's energy performance

Main heating fuel	LPG
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	29.44
Primary energy use (kWh/m ² per year)	188

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/1897-2126-2270-5027-6989\)](/energy-certificate/1897-2126-2270-5027-6989).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	John Maddock
Telephone	01772696745
Email	john@e-missionltd.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO001673
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	E-mission GB Ltd
Employer address	22 The Ferns Walton Park Preston PR5 5QT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	31 January 2023
Date of certificate	19 February 2023
