Energy performance certificate (EPC)

Third Floor North and Northern Tower Fitted Rigging House, Anchor Wharf, Main Gate Road, Historic Dockyard, Chatham ME4 4TZ Energy rating

Valid until: 21 August 2032

Certificate number:

8612-8914-7151-4631-6475


Property type	Offices and Workshop Businesses
Total floor area	1,212 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

52 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	29.8
Primary energy use (kWh/m2 per year)	214

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> report (/energy-certificate/7820-5176-9093-8509-0947).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Martyn Bloomfield
Telephone	01795479579
Email	surveyorsandvaluers@ymail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Sterling Accreditation Ltd
Assessor's ID	STER500171
Telephone	0161 727 4303
Email	info@sterlingaccreditation.com

About this assessment

Employer	Surveyors & Valuers Limited
Employer address	Top Floor Sears Business Centre, 3-9 Station Street, Sittingbourne, Kent, ME10 3DU
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	2 March 2022
Date of certificate	22 August 2022