

# Energy performance certificate (EPC) recommendation report

Third Floor North and Northern  
Tower  
Fitted Rigging House,  
Anchor Wharf, Main Gate Road,  
Historic Dockyard,  
Chatham  
ME4 4TZ

Report number  
**7820-5176-9093-8509-0947**

Valid until  
**21 August 2032**

---

## Energy rating and EPC

This property's energy rating is D.

For more information on the property's energy performance, see the EPC for this property.

---

## Recommendations

### Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Add optimum start/stop to the heating system.	Medium
The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.	Low

### Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Some windows have high U-values - consider installing secondary glazing.	Medium
Add weather compensation controls to heating system.	Medium
Some loft spaces are poorly insulated - install/improve insulation.	Medium
Add local time control to heating system.	Medium
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	Medium

---

## Property and report details

Report issued on	22 August 2022
Total useful floor area	1,212 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	Property Tectonics Ltd, Lifespan SBEM, v6.1.c.0, SBEM, v6.1.c.0

---

## Assessor's details

Assessor's name	Martyn Bloomfield
Telephone	01795479579
Email	<a href="mailto:surveyorsandvaluers@ymail.com">surveyorsandvaluers@ymail.com</a>
Employer's name	Surveyors & Valuers Limited
Employer's address	Top Floor Sears Business Centre, 3-9 Station Street, Sittingbourne, Kent, ME10 3DU
Assessor ID	STER500171
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Sterling Accreditation Ltd

---