

Energy performance certificate (EPC)

7, Lower Cockcroft
BLACKBURN
BB2 1JD

Energy rating

C

Valid until:

2 December 2028

Certificate number:

9186-3009-0788-0890-1621

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


143 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

22 A

If typical of the existing stock

64 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	108.01
Primary energy use (kWh/m ² per year)	633

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0110-0848-8789-6029-6092\)](/energy-certificate/0110-0848-8789-6029-6092).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jonathan Whittaker
Telephone	07841352393
Email	jonathanwhittaker@outlook.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK
Assessor's ID	ECMK302223
Telephone	0333 123 1418
Email	info@ecmk.co.uk

About this assessment

Employer	Schema Delta Ltd
Employer address	<insert Employer/Trading Address>
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	29 November 2018
Date of certificate	3 December 2018
