

Energy performance certificate (EPC)

Dane Works Crown Quay Lane SITTINGBOURNE ME10 3HU	Energy rating D	Valid until: 19 June 2034
		Certificate number: 2916-3384-8849-0753-0048


Property type	General Industrial and Special Industrial Groups
Total floor area	280 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	12 A
If typical of the existing stock	47 B

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	31.16
Primary energy use (kWh/m ² per year)	238

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/4254-8457-4273-5588-0072\)](/energy-certificate/4254-8457-4273-5588-0072).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Malcolm Clarke
Telephone	01622200628
Email	sales@assuredepc.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/007811
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	sales@assuredepc.co.uk
Employer address	16 Millers Wharf, Maidstone, Kent. ME15 6YW
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	14 June 2024
Date of certificate	20 June 2024