Energy performance certificate (EPC)

Unit G3 Base Business Space Chamberlain Road KINGSTON UPON HULL HU8 8HL Energy rating

Valid until: 8 November 2033

Certificate number:

9294-6584-2901-9798-3428

Property type

Offices and Workshop Businesses

Total floor area


311 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

8 A

If typical of the existing stock

33 B

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	8.64
Primary energy use (kWh/m2 per year)	92

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation report}}{\text{(/energy-certificate/4790-9807-6284-9459-5588)}}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Nicholas Procter 01759 301114
Telephone	01759301114
Email	njp@procters.net

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Sterling Accreditation Ltd
Assessor's ID	STER500127
Telephone	0161 727 4303
Email	info@sterlingaccreditation.com

About this assessment

Procters Property Ltd
Prospect House, 4a George Street, Pocklington, York, YO42 2DF
The assessor is not related to the owner of the property.
25 October 2023
9 November 2023