Energy performance certificate (EPC)

Unit 28 Bergen Way HULL HU7 0YQ Energy rating

Valid until: 21 June 2028

Certificate number: 9571-3005-0288-0000-4321

Property type B8 Storage or Distribution


Total floor area 1,173 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

26 B

If typical of the existing stock

76 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	79.31
Primary energy use (kWh/m2 per year)	460

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation report}}{(\text{/energy-certificate/0450-0048-7289-1025-3002})}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Alexander Smith
Telephone	07799700977
Email	alex.smith@wensleylawz.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Sterling Accreditation Ltd
Assessor's ID	STER001401
Telephone	0161 727 4303
Email	info@sterlingaccreditation.com

About this assessment

National Westminster Building 116-118 Walsgrave Road
Coventry CV2 4ED
The assessor is not related to the owner of the property.
24 May 2018
22 June 2018