Energy performance certificate (EPC)

Unit 2 High Street Scotter GAINSBOROUGH DN21 3RX Energy rating

Valid until: 27 April 2032

Certificate number:

5872-6057-1523-6194-9218

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


62 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

28 B

If typical of the existing stock

83 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	61.68
Primary energy use (kWh/m2 per year)	365

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> report (/energy-certificate/1406-7562-0983-5741-7778).

Who to contact about this certificate

Contacting the assessor

Date of assessment

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mr Kristen Jones
Telephone	01522 524282
Email	lincenergysurveys@btinternet.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008857
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment	
Employer	Lincoln Energy Surveys
Employer address	62 St Augustine Road, Lincoln, LN2 4FH
Assessor's declaration	The assessor is not related to the owner of the

property.

19 April 2022 28 April 2022