

Energy performance certificate (EPC)

Unit 4, Newchase House
Annesley Street
Grimsby
DN32 1XB

Energy rating

B

Valid until:

14 January 2035

Certificate number:

7460-6770-0960-3364-1213

Property type

Offices and Workshop Businesses

Total floor area


73 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

24 A

If typical of the existing stock

94 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO ₂ /m ² per year)	3.23
Primary energy use (kWh/m ² per year)	34

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0708-0390-2424-1775-9297\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Neil Ingham
Telephone	020 7148 6290
Email	neil@thepes.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA158593
Telephone	020 8772 3649
Email	epc@cibsecertification.org

About this assessment

Employer	
Employer address	
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	13 January 2025
Date of certificate	15 January 2025