
Energy performance certificate (EPC)				
31 Abbey Road TORQUAY TQ2 5NQ	Energy rating	Valid until:	14 March 2030	
		Certificate number:	2382-3097-0806-0200-7995	
Property type	D2 General Assembly and Leisure plus Night Clubs and Theatres			
Total floor area	104 square metres			

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



24 A


70 C

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock



Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	51.16
Primary energy use (kWh/m2 per year)	303

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/0730-0240-8862-2997-9006)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

Andrew Coleman

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme Assessor's ID Telephone Email Stroma Certification Ltd STRO001688 0330 124 9660 certification@stroma.com

About this assessment

Employer Employer address Assessor's declaration

Date of assessment Date of certificate Deatorbay 15 Grosvenor Close The assessor is not related to the owner of the property. 13 March 2020 15 March 2020