Energy performance certificate (EPC)

26 High Street ROYAL TUNBRIDGE WELLS TN1 1UX

Property type

Energy rating

Valid until: 8 June 2032

Certificate number:

0068-0200-0302-6861-8214

Total floor area

A1/A2 Retail and Financial/Professional services


113 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

28 B

If typical of the existing stock

81 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	81.43
Primary energy use (kWh/m2 per year)	482

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/2061-4866-0020-2801-8005).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	S. Cappuccini
Telephone	01892 300 450
Email	enquiries@jcmlconsultancy.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID300156	
Telephone	01225 667 570	
Email	info@quidos.co.uk	

Employer GreenFish (JCML) Employer address G5 Basepoint Business Centre, Pine Grove, Crowborough TN6 1DH Assessor's declaration The assessor is not related to the owner of the property. Date of assessment 8 June 2022 Date of certificate 9 June 2022