

Energy performance certificate (EPC)

Newhaven Ferry Terminal Building
Railway Approach
NEWHAVEN
BN9 0DF

Energy rating

B

Valid until:

14 March 2034

Certificate number:

0367-0288-4406-5182-9654

Property type

General Assembly and Leisure, Night Clubs, and Theatres

Total floor area


1,855 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

17 A

If typical of the existing stock

67 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO ₂ /m ² per year)	34.49
Primary energy use (kWh/m ² per year)	376

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/3704-5456-5402-3743-4924\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Stephen Peacock
Telephone	02086969520
Email	stephen@bespokeplans.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008714
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Bespokeplans Limited
Employer address	24 Walmsley House, London, SW16 1RH
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	26 January 2024
Date of certificate	15 March 2024