Unit 18 Greenway Workshops Bedwas House Industrial Estate Bedwas CF83 8HW Energy rating Valid until: 3 April 2032 Certificate number: 7600-3389-1267-2874-7486

Property type

B2 to B7 General Industrial and Special Industrial Groups

Total floor area


100 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

1 of 3 09/05/2025, 11:51

How this property compares to others

Properties similar to this one could have ratings:

If newly built	19 A
If typical of the existing stock	62 C

Breakdown of this property's energy performance

Main heating fuel	Other
Building environment	Unconditioned
Assessment level	3
Building emission rate (kgCO2/m2 per year)	44.13
Primary energy use (kWh/m2 per year)	261

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/6467-9081-0086-6783-2587).

2 of 3 09/05/2025, 11:51

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name Maurice Carter

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd	
Assessor's ID	STRO002235	
Telephone	0330 124 9660	
Email	certification@stroma.com	

About this assessment

Employer	EPC 4 South Wales
Employer address	23 Slade Close, Sully, Vale of Glamorgan, Penarth, Wales
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	1 April 2022
Date of certificate	4 April 2022

3 of 3