

Display energy certificate (DEC)



HM Government

West Sussex County Council
Training Centre, Brougham Road
WORTHING
BN11 2NU

Operational rating

F

Certificate number: 9220-9912-0161-3460-3094

Valid until: 30 August 2029

Total useful floor area: 925 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D		
101-125	E		100
126-150	F	138 F	
150+	G		

Previous operational ratings

Date	Operational rating
August 2019	138 F

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
August 2019	13	53	0

Assessment details

Assessor's name	Alastair Humphries-Cuff
Employer/Trading name	ESOS Energy
Employer/Trading address	2nd Floor Tower House, Fairfax Street, Bristol, BS1 3BN
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	21 February 2020
Nominated date	31 August 2019

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	25	297
Typical energy use (kWh/m ² /year)	40	153
Energy from renewables	0%	0%