Energy performance certificate (EPC)

Tiffin Box 115 Chiswick High Road LONDON W4 2ED Energy rating

26 September 2029

Certificate number: 9166-3021-0115-0400-7625

Property type

A3/A4/A5 Restaurant and Cafes/Drinking Establishments and Hot Food takeaways

Total floor area

101 square metres

Valid until:

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is C.

Under 0 A+

Net zero CO2

0-25 A

26-50 B

51-75 C

76-100 D

101-125 E

126-150 F

Over 150 G

Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

30 B

If typical of the existing stock

88 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	139.31
Primary energy use (kWh/m2 per year)	816

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation}}{\text{report}}$ ($\frac{\text{recommendation}}{\text{recommendation}}$).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name laiq shaikh
Telephone 07960300832

Email <u>zeehips@gmail.com</u>

Accreditation scheme contact details

Accreditation scheme Stroma Certification Ltd

Assessor ID STRO002700 Telephone 0330 124 9660

Email certification@stroma.com

Assessment details

Employer Zeehips limited. Email zeehips@gmail.com

Employer address 408 ,legacy centre hanworth trading estate ,feltham

,tw13 6dh Mobile07960300832

Assessor's declaration The assessor is not related to the owner of the

property.

Date of assessment 23 September 2019
Date of certificate 27 September 2019