

Property type Offices and Workshop Businesses


Total floor area 364 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

If newly built	13 A
If typical of the existing stock	51 C

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	13.52
Primary energy use (kWh/m2 per year)	148

# **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/3756-0693-4695-1891-8410).

### Who to contact about this certificate

### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jason March
Telephone	01603 555705
Email	jm@epcnorfolk.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/022863
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment	
Employer	EPC Norfolk Ltd
Employer address	Norwich, Norfolk

About this assessment	
Employer	EPC Norfolk Ltd
Employer address	Norwich, Norfolk
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	28 July 2025
Date of certificate	5 August 2025
	<u> </u>