Energy performance certificate (EPC)

47c East Street BLANDFORD FORUM DT11 7DX Energy rating

Valid until: 27 January 2035

Certificate number:

2140-3509-7050-4108-9421

Property type

Retail/Financial and Professional Services

Total floor area


72 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

2 A

If typical of the existing stock

8 A

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity	
Building environment	Heating and Natural Ventilation	
Assessment level	3	
Building emission rate (kgCO2/m2 per year)	15.22	
Primary energy use (kWh/m2 per year)	163	

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/5918-7145-4002-0029-4402).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Steve Williams
Telephone	07850329751
Email	steve@williamsenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID211119	
Telephone	01225 667 570	
Email	info@quidos.co.uk	

About this assessment

Employer	Williams Energy
Employer address	30 Wentworth Close Bournemouth Dorset BH5 2DZ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	21 January 2025
Date of certificate	28 January 2025