

Property type Restaurants and Cafes/Drinking Establishments/Takeaways


Total floor area 187 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	32 B
If typical of the existing stock	127 F

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO2/m2 per year)	79.19
Primary energy use (kWh/m2 per year)	550

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/2925-3862-8476-1969-5632).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	William White
Telephone	03333 445 504
Email	william@whiteenergyservices.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/015575
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Future Building Ltd
Employer address	Use Space Paddock Street Manchester M12 6PN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	1 August 2024
Date of certificate	9 August 2024
	-