# **Energy Performance Certificate**



## Address of dwelling and other details

7 NORTHGATE PEEBLES EH45 8RX Dwelling type:

Name of approved organisation:

Membership number: Date of certificate:

Reference number: Type of assessment:

Total floor area:

Main type of heating and fuel:

Ground-floor maisonette Elmhurst Energy Systems Ltd

EES/008226 24 October 2011


9160-2554-5000-9229-8265 RdSAP, existing dwelling

117 m<sup>2</sup>


Boiler and radiators, mains gas

# This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2009 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO<sub>2</sub>) emissions. CO<sub>2</sub> is a greenhouse gas that contributes to climate change.



The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.



The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating the less impact it has on the environment.

Approximate current energy use per square metre of floor area: 352 kWh/m²per year Approximate current CO₂emissions: 68 kg/m²per year

#### Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above. Higher cost measures could also be considered and these are recommended in the attached energy report.

- 1 Low energy lighting for all fixed outlets
- 2 Upgrade heating controls

A full energy report is appended to this certificate



Remember to look for the Energy Saving Trust Recommended logo when buying energy-efficient products. It's a quick and easy way to identify the most energy-efficient products on the market.

Information from this EPC may be given to the Energy Saving Trust to provide advice to householders on financial help available to improve home energy efficiency.

# **Energy Report**



The Energy Performance Certificate and Energy Report for this dwelling were produced following an energy assessment undertaken by a member of Elmhurst Energy Systems Ltd. This is an organisation which has been approved by the Scottish Ministers. The certificate has been produced under the Building (Scotland) Amendment Regulations 2006 and a copy of the certificate and this energy report have been lodged on a national register.

Assessor's name: Mr. Christopher J Highton
Company name/trading name: Allied Surveyors Scotland Plc

Address: The Engine House Ettrick Riverside Dunsdale Road Selkirk TD7 5EB

Phone number: 01750 724170 Fax number: 01750 724171

E-mail address: chris.highton@alliedsurveyorsscotland.com

Related party disclosure: No related party

## Estimated energy use, carbon dioxide (CO<sub>2</sub>) emissions and fuel costs of this home

	Current	Potential
Energy use	352 kWh/m²per year	325 kWh/m²per year
Carbon dioxide emissions	7.9 tonnes per year	7.3 tonnes per year
Lighting	£92 per year	£60 per year
Heating	£1277 per year	£1205 per year
Hot water	£141 per year	£132 per year

The figures in the table above have been provided to enable prospective buyers and tenants to compare the fuel costs and carbon emissions of one home with another. To enable this comparison the figures have been calculated using standardised running conditions (heating periods, room temperatures, etc.) that are the same for all homes, consequently they are unlikely to match an occupier's actual fuel bills and carbon emissions in practice. The figures do not include the impacts of the fuels used for cooking or running appliances, such as TV, fridge etc.; nor do they reflect the costs associated with service, maintenance or safety inspections. Always check the certificate date because fuel prices can change over time and energy saving recommendations will evolve.

#### About the building's performance ratings

The ratings on the certificate provide a measure of the buildings overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used.

Not all buildings are used in the same way, so energy ratings use standard occupancy assumptions which may be different from the specific way you use your home.

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings in the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

#### About the impact of buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple everyday measures that will save money, improve comfort and reduce the impact on the environment. Some examples are given at the end of this report.

## Summary of this home's energy performance related features

The table below gives an assessment of the key individual elements that have an impact on this home's energy and environmental performance. Each element is assessed by the national calculation methodology; 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the physical condition of any element. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology based on age and type of construction

		Current performance		
Element	Description	Energy Efficiency	/ Environmental	
Walls	Granite or whin, as built, no insulation (assumed)	* & & & &	* ជ ជ ជ ជ	
Roof	Pitched, 150 mm loft insulation Roof room(s), no insulation (assumed)	**** ****	**** ***	
Floor	Solid, no insulation (assumed)	doubloat	na politico de Glades de la companya del companya del companya de la companya de	
Windows	Mostly double glazing	****	****	
Main heating	Boiler and radiators, mains gas	****	****	
Main heating controls	Programmer, TRVs and bypass	****	****	
Secondary heating	None	governe de un	pour eral jeu	
Hot water	From main system	****	****	
Lighting	Low energy lighting in 48% of fixed outlets	****	****	
Current energy eff	iciency rating	E 44		
Current environmental impact (CO <sub>2</sub> ) rating			E 39	

### Low and zero carbon energy sources

These are sources of energy (producing or providing electricity or hot water) which emit little or no carbon dioxide into the atmosphere. There are none applicable to this home.

# Recommended measures to improve this homes energy performance

The measures below are cost effective. The performance ratings after improvement listed below are cumulative, that is they assume the improvements have been installed in the order that they appear in the table. However you should check the conditions in any covenants, warranties or sale contracts, and whether any legal permissions are required such as a building warrant, planning consent or listed building restrictions. The indicative costs are representative for most properties but may not apply in a particular case.

		Tuningle agaings	Ratings after improvement	
Lower cost measures	Indicative Cost	Typical savings per year	Energy Efficiency	Environmental Impact
1 Low energy lighting for all fixed outlets	£28	£26	E 45	E 40
2 Upgrade heating controls	£350 - £450	£87	E 48	E 43
Sub-Total		£113	enym G	wohado
Higher cost measures				
Replace boiler with new condensing boiler	£1,500 - £3,500	£122	E 53	E 47
Total	To live secol	£235		(miletje)
Potential energy efficiency rating			E 53	
Potential environmental impact (CC	O <sub>2</sub> ) rating			E 47

# Further measures to achieve even higher standards

None

# Summary of this home's energy performance related features

The table below gives an assessment of the key individual elements that have an impact on this home's energy and environmental performance. Each element is assessed by the national calculation methodology; 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the physical condition of any element. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology based on age and type of construction

Element	Description	Current performance		
Element	Description	Energy Efficiency	Environmental	
Walls	Granite or whin, as built, no insulation (assumed)	* * * * * *	★ ជ ជ ជ ជ	
Roof	Pitched, 150 mm loft insulation Roof room(s), no insulation (assumed)	* * * * * \( \phi \) * \( \phi \) \( \phi \) \( \phi \)		
Floor	Solid, no insulation (assumed)		_	
Windows	Mostly double glazing	****	****	
Main heating	Boiler and radiators, mains gas	****	****	
Main heating controls	Programmer, TRVs and bypass	****	****	
Secondary heating	None	_		
Hot water	From main system	****	****	
Lighting	Low energy lighting in 48% of fixed outlets	****	****	
Current energy eff	iciency rating	E 44		
Current environme	rrent environmental impact (CO <sub>2</sub> ) rating		E 39	

## Low and zero carbon energy sources

These are sources of energy (producing or providing electricity or hot water) which emit little or no carbon dioxide into the atmosphere. There are none applicable to this home.

Function of the Community of the Communi

modination. The later restaurant to the contract of the second of the se