Energy performance certificate (EPC)				
311 Littleton Road SALFORD M7 3TA	Energy rating	Valid until:	26 March 2028	
WIT STA		Certificate number:	0290-2272-2530-2200-6803	
Property type		A1/A2 Retail a services	and Financial/Professional	
Total floor area		103 square m	etres	

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



25 A

75 C

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock



Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	79.88
Primary energy use (kWh/m2 per year)	465

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/0270-6922-0428-2250-2004).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	William White
-----------------	---------------

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID206130
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	EPC Online	
Employer address	Provident House, Burrell Row, Beckenham, Kent, BR3 1AT	
Assessor's declaration	The assessor is a relative of the professional dealing with the property transaction.	
Date of assessment	22 March 2018	
Date of certificate	27 March 2018	