



Home Report

shepherd.co.uk



SHEPHERD

CHARTERED SURVEYORS

All Angles Covered

Residential | Commercial | Property & Construction

Home Report

Property: **Clydesdale Bank House
High Street
Aberlour
Moray
AB38 9QB**

Prepared for: **Joanna Murdoch**

Prepared by: **Olga MacGregor MRICS**

Report reference: **1717931-1-2**

Date of Report: **09/10/2024**



Energy Performance Certificate



Energy Performance Certificate (EPC)

Dwellings

Scotland

BANK HOUSE, 89 HIGH STREET, ABERLOUR, AB38 9QB

Dwelling type: Top-floor maisonette
Date of assessment: 09 October 2024
Date of certificate: 11 October 2024
Total floor area: 271 m²
Primary Energy Indicator: 346 kWh/m²/year

Reference number: 3190-8612-0322-0208-1043
Type of assessment: RdSAP, existing dwelling
Approved Organisation: Elmhurst
Main heating and fuel: Boiler and radiators, mains gas


You can use this document to:

- Compare current ratings of properties to see which are more energy efficient and environmentally friendly
- Find out how to save energy and money and also reduce CO₂ emissions by improving your home

Estimated energy costs for your home for 3 years*	£14,427	See your recommendations report for more information
Over 3 years you could save*	£4,524	

* based upon the cost of energy for heating, hot water, lighting and ventilation, calculated using standard assumptions

Very energy efficient - lower running costs



Current	Potential
55	69


Energy Efficiency Rating

This graph shows the current efficiency of your home, taking into account both energy efficiency and fuel costs. The higher this rating, the lower your fuel bills are likely to be.

Your current rating is **band D (55)**. The average rating for EPCs in Scotland is **band D (61)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Very environmentally friendly - lower CO₂ emissions



Current	Potential
44	60

Environmental Impact (CO₂) Rating

This graph shows the effect of your home on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating, the less impact it has on the environment.

Your current rating is **band E (44)**. The average rating for EPCs in Scotland is **band D (59)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years
1 Room-in-roof insulation	£1,500 - £2,700	£2331.00
2 Internal or external wall insulation	£4,000 - £14,000	£1716.00
3 Heating controls (room thermostat)	£350 - £450	£480.00

A full list of recommended improvement measures for your home, together with more information on potential cost and savings and advice to help you carry out improvements can be found in your recommendations report.

To find out more about the recommended measures and other actions you could take today to stop wasting energy and money, visit [greenerscotland.org](https://www.greenerscotland.org) or contact Home Energy Scotland on 0808 808 2282.

THIS PAGE IS THE ENERGY PERFORMANCE CERTIFICATE WHICH MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED CERTIFICATE

Summary of the energy performance related features of this home

This table sets out the results of the survey which lists the current energy-related features of this home. Each element is assessed by the national calculation methodology; 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the condition of an element and how well it is working. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology, based on age and type of construction.

Element	Description	Energy Efficiency	Environmental
Walls	Sandstone or limestone, as built, no insulation (assumed)	★★☆☆☆	★★☆☆☆
Roof	Pitched, no insulation (assumed) Roof room(s), ceiling insulated	★☆☆☆☆ ★★☆☆☆	★☆☆☆☆ ★★☆☆☆
Floor	(other premises below) Suspended, no insulation (assumed)	— —	— —
Windows	Mostly multiple glazing	★★★☆☆	★★★☆☆
Main heating	Boiler and radiators, mains gas	★★★★☆	★★★★☆
Main heating controls	Programmer, TRVs and bypass	★★★☆☆	★★★☆☆
Secondary heating	Room heaters, mains gas	—	—
Hot water	From main system	★★★★☆	★★★★☆
Lighting	Low energy lighting in all fixed outlets	★★★★★	★★★★★

The energy efficiency rating of your home

Your Energy Efficiency Rating is calculated using the standard UK methodology, RdSAP. This calculates energy used for heating, hot water, lighting and ventilation and then applies fuel costs to that energy use to give an overall rating for your home. The rating is given on a scale of 1 to 100. Other than the cost of fuel for electrical appliances and for cooking, a building with a rating of 100 would cost almost nothing to run.

As we all use our homes in different ways, the energy rating is calculated using standard occupancy assumptions which may be different from the way you use it. The rating also uses national weather information to allow comparison between buildings in different parts of Scotland. However, to make information more relevant to your home, local weather data is used to calculate your energy use, CO₂ emissions, running costs and the savings possible from making improvements.

The impact of your home on the environment

One of the biggest contributors to global warming is carbon dioxide. The energy we use for heating, lighting and power in our homes produces over a quarter of the UK's carbon dioxide emissions. Different fuels produce different amounts of carbon dioxide for every kilowatt hour (kWh) of energy used. The Environmental Impact Rating of your home is calculated by applying these 'carbon factors' for the fuels you use to your overall energy use.

The calculated emissions for your home are 61 kg CO₂/m²/yr.

The average Scottish household produces about 6 tonnes of carbon dioxide every year. Based on this assessment, heating and lighting this home currently produces approximately 17 tonnes of carbon dioxide every year. Adopting recommendations in this report can reduce emissions and protect the environment. If you were to install all of these recommendations this could reduce emissions by 6 tonnes per year. You could reduce emissions even more by switching to renewable energy sources.


Estimated energy costs for this home

	Current energy costs	Potential energy costs	Potential future savings
Heating	£13,128 over 3 years	£8,640 over 3 years	
Hot water	£645 over 3 years	£609 over 3 years	
Lighting	£654 over 3 years	£654 over 3 years	
Totals	£14,427	£9,903	

These figures show how much the average household would spend in this property for heating, lighting and hot water. This excludes energy use for running appliances such as TVs, computers and cookers, and the benefits of any electricity generated by this home (for example, from photovoltaic panels). The potential savings in energy costs show the effect of undertaking all of the recommended measures listed below.

Recommendations for improvement

The measures below will improve the energy and environmental performance of this dwelling. The performance ratings after improvements listed below are cumulative; that is, they assume the improvements have been installed in the order that they appear in the table. Further information about the recommended measures and other simple actions to take today to save money is available from the Home Energy Scotland hotline which can be contacted on 0808 808 2282. Before carrying out work, make sure that the appropriate permissions are obtained, where necessary. This may include permission from a landlord (if you are a tenant) or the need to get a Building Warrant for certain types of work.

Recommended measures	Indicative cost	Typical saving per year	Rating after improvement	
			Energy	Environment
1 Room-in-roof insulation	£1,500 - £2,700	£777		
2 Internal or external wall insulation	£4,000 - £14,000	£572		
3 Upgrade heating controls	£350 - £450	£160		

Choosing the right improvement package

For free and impartial advice on choosing suitable measures for your property, contact the Home Energy Scotland hotline on 0808 808 2282 or go to www.greenerscotland.org.

energy
saving
trust

About the recommended measures to improve your home's performance rating

This section offers additional information and advice on the recommended improvement measures for your home

1 Room-in-roof insulation

Insulating roof rooms will significantly reduce heat loss; this will improve levels of comfort, reduce energy use and lower fuel bills. If it has a flat ceiling insulation can usually be added above the ceiling, and sloping ceilings and walls of roof rooms can be insulated using an internal lining board. Roof voids must have adequate ventilation to prevent dampness; seek advice about this if unsure. Further information about roof room insulation and details of local contractors can be obtained from the National Insulation Association (www.nationalinsulationassociation.org.uk). Building regulations generally apply to this work so it is best to check this with your local authority building standards department.

2 Internal or external wall insulation

Internal or external wall insulation involves adding a layer of insulation to either the inside or the outside surface of the external walls, which reduces heat loss and lowers fuel bills. As it is more expensive than cavity wall insulation it is only recommended for walls without a cavity, or where for technical reasons a cavity cannot be filled. Internal insulation, known as dry-lining, is where a layer of insulation is fixed to the inside surface of external walls; this type of insulation is best applied when rooms require redecorating. External solid wall insulation is the application of an insulant and a weather-protective finish to the outside of the wall. This may improve the look of the home, particularly where existing brickwork or rendering is poor, and will provide long-lasting weather protection. Further information can be obtained from the National Insulation Association (www.nationalinsulationassociation.org.uk). It should be noted that a building warrant is required for the installation of external wall insulation. Planning permission may also be required and that building regulations apply to external insulation so it is best to check with your local authority on both issues.

3 Heating controls (room thermostat)

The heating system should have a room thermostat to enable the boiler to switch off when no heat is required. A competent heating engineer should be asked to do this work. Insist that the thermostat switches off the boiler as well as the pump and that the thermostatic radiator valve is removed from any radiator in the same room as the thermostat. Building regulations generally apply to this work and a building warrant may be required, so it is best to check with your local authority building standards department and seek advice from a qualified heating engineer.

Low and zero carbon energy sources

Low and zero carbon (LZC) energy sources are sources of energy that release either very little or no carbon dioxide into the atmosphere when they are used. Installing these sources may help reduce energy bills as well as cutting carbon.

LZC energy sources present: There are none provided for this home

Your home's heat demand

In this section, you can see how much energy you might need to heat your home and provide hot water. These are estimates showing how an average household uses energy. These estimates may not reflect your actual energy use, which could be higher or lower. You might spend more money on heating and hot water if your house is less energy efficient. The table below shows the potential benefit of having your loft and walls insulated. Visit <https://energysavingtrust.org.uk/energy-at-home> for more information.

Heat demand	Existing dwelling	Impact of loft insulation	Impact of cavity wall insulation	Impact of solid wall insulation
Space heating (kWh per year)	58,180	(8,999)	N/A	(7,775)
Water heating (kWh per year)	2,944			

Addendum

This dwelling has stone walls and so requires further investigation to establish whether these walls are of cavity construction and to determine which type of wall insulation is best suited.

About this document

This Recommendations Report and the accompanying Energy Performance Certificate are valid for a maximum of ten years. These documents cease to be valid where superseded by a more recent assessment of the same building carried out by a member of an Approved Organisation.

The Energy Performance Certificate and this Recommendations Report for this building were produced following an energy assessment undertaken by an assessor accredited by Elmhurst (www.elmhurstenergy.co.uk), an Approved Organisation Appointed by Scottish Ministers. The certificate has been produced under the Energy Performance of Buildings (Scotland) Regulations 2008 from data lodged to the Scottish EPC register. You can verify the validity of this document by visiting www.scottishepcregister.org.uk and entering the report reference number (RRN) printed at the top of this page.

Assessor's name:	Miss Olga MacGregor
Assessor membership number:	EES/014056
Company name/trading name:	J & E Shepherd
Address:	13 Albert Square Dundee DD1 1XA
Phone number:	01382 200454
Email address:	dundee@shepherd.co.uk
Related party disclosure:	No related party

If you have any concerns regarding the content of this report or the service provided by your assessor you should in the first instance raise these matters with your assessor and with the Approved Organisation to which they belong. All Approved Organisations are required to publish their complaints and disciplinary procedures and details can be found online at the web address given above.

Use of this energy performance information

Once lodged by your EPC assessor, this Energy Performance Certificate and Recommendations Report are available to view online at www.scottishepcregister.org.uk, with the facility to search for any single record by entering the property address. This gives everyone access to any current, valid EPC except where a property has a Green Deal Plan, in which case the report reference number (RRN) must first be provided. The energy performance data in these documents, together with other building information gathered during the assessment is held on the Scottish EPC Register and is available to authorised recipients, including organisations delivering energy efficiency and carbon reduction initiatives on behalf of the Scottish and UK governments. A range of data from all assessments undertaken in Scotland is also published periodically by the Scottish Government. Further information on these matters and on Energy Performance Certificates in general, can be found at www.gov.scot/epc.

Advice and support to improve this property

There is support available, which could help you carry out some of the improvements recommended for this property on page 3 and stop wasting energy and money. For more information, visit [greenerscotland.org](https://www.greenerscotland.org) or contact Home Energy Scotland on 0808 808 2282.

Home Energy Scotland's independent and expert advisors can offer free and impartial advice on all aspects of energy efficiency, renewable energy and more.

HOMEENERGYSCOTLAND.ORG
0808 808 2282
FUNDED BY THE SCOTTISH GOVERNMENT





Scottish Single Survey



Schedule 1

Survey Report

Clydesdale Bank House

High Street

Aberlour

Moray

AB38 9QB

Customer

Joanna Murdoch

Date of Inspection

09/10/2024

Prepared by

Olga MacGregor MRICS

1. INFORMATION AND SCOPE OF INSPECTION

This section tells you about the type, accommodation, neighbourhood, age and construction of the property. It also tells you about the extent of the inspection and highlights anything that the surveyor could not inspect.

All references to visual inspection refer to an inspection from within the property without moving any obstructions and externally from ground level within the site and adjoining public areas. Any references to left or right in a description of the exterior of the property refer to the view of someone standing facing that part of the property from the outside.

The inspection is carried out without causing damage to the building or its contents and without endangering the occupiers or the surveyor. Heavy furniture, stored items and insulation are not moved. Unless identified in the report the surveyor will assume that no harmful or hazardous materials or techniques have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

Services such as TV/cable connection, internet connection, swimming pools and other leisure facilities etc. will not be inspected or reported on.

Description	The subjects comprise a ground, first and attic floor maisonette located over The Gatherin' Cafe.
Accommodation	The accommodation may be summarised as follows: Ground Floor: Entrance Vestibule, Hallway and Rear Vestibule, First Floor: Landing, Lounge, Dining Room, Bedroom, Kitchen, Utility Room and Bathroom. Attic Floor: Landing, Two Bedrooms, Shower Room, Study with Boiler Room and Storage Area off.
Gross internal floor area (m^2)	Amounts to 271 square metres, or thereby.
Neighbourhood and location	The subjects are located within an area of mixed residential and commercial properties within Aberlour where surrounding properties are of a similar design, vintage and character. Adequate local shopping, educational and transport facilities are available.
Age	Erected circa 1900.
Weather	The weather was wet at the time of inspection.
Chimney stacks	There are four pointed stone stacks with cement/metal flashings.
Roofing including roof space	Roof spaces were visually inspected and were entered where there was safe and reasonable access from a 3 metre ladder within the property. The roof is of a pitched, ridged and hipped design comprising timber trusses clad with slates over timber sarking boards and incorporating dormer projections to the front and sides of the property. Access to the roof void area was undertaken from a ceiling

	hatch within an attic floor bedroom and from a door off the study.
Rainwater fittings	Gutters and downpipes are predominantly of cast iron manufacture with uPVC sections noted to the front elevation.
Main walls	Foundations and concealed parts were not exposed or inspected. The main outer walls are of pointed solid stone construction (wall width 690mm approximately).
Windows, external doors and joinery	Internal and external doors were opened and closed where keys were available. Random windows were opened and closed where possible. Doors and windows were not forced open. Windows are predominantly of a double glazed, sealed unit, uPVC manufacture with a secondary glazed cast iron skylight to the landing cast iron skylight within the study and timber casement, single glazed with secondary internal glazing at the stairwell. Soffits are a mix of timber and uPVC manufacture.
External decorations	Visually inspected. External décor is of a paintwork finish.
Conservatories/Porches	Not applicable.
Communal areas	Not applicable.
Garages and permanent outbuildings	Visually inspected. There is a detached single car garage of rendered blockwork construction built off the stone boundary wall, contained beneath a corrugated cement sheet roof covering.
Outside areas and boundaries	Visually inspected. There are garden grounds are laid to paving with grass and a gravel path with trees, shrubs and flowerbeds. Boundaries are defined with a mix of retaining blockwork and retaining stone walls and timber fencing.
Ceilings	Visually inspected from floor level. Ceiling linings are of a lath and plaster and timber design.

Internal walls	Visually inspected from floor level. Using a moisture meter, walls were randomly tested for dampness where considered appropriate. Internal wall linings are predominantly of lath and plaster design with timber linings noted within the store room.
Floors including sub floors	Surfaces of exposed floors were visually inspected. No carpets or floor coverings were lifted. Flooring is of a suspended timber construction throughout.
Internal joinery and kitchen fittings	Built-in cupboards were looked into but no stored items were moved. Kitchen units were visually inspected excluding appliances. Internal joinery is of a softwood pattern consisting of moulded timber skirtings and door surrounds with timber panel and glazed panel internal pass doors. There is a fitted kitchen with both floor and wall mounted units. The stairs and handrail are of timber manufacture.
Chimney breasts and fireplaces	Visually inspected. No testing of the flues or fittings was carried out. There is a living flame gas fire within the lounge with blocked and vented fireplaces within the first floor and an attic floor bedroom with a blocked, unvented fireplace noted within the dining room.
Internal decorations	Visually inspected. Internal décor is of wallpaper and/or paintwork finishes throughout.
Cellars	Not applicable.
Electricity	Accessible parts of the wiring were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances. Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the surveyor will state that in the report and will not turn them on. Mains electricity is connected. The consumer unit and electric meter are located within a low level cupboard within the attic floor study.

Gas	Accessible parts of the system were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances. Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the surveyor will state that in the report and will not turn them on. Mains gas is connected. The gas meter is located externally within a service box to the rear elevation.
Water, plumbing and bathroom fittings	Visual inspection of the accessible pipework, water tanks, cylinders and fittings without removing any insulation. No tests whatsoever were carried out to the system or appliances. Water is from the public rising main. The plumbing installation, where seen, consists with copper distribution pipes, together with uPVC waste pipes. Sanitary fittings are white and consist of a shower room at attic floor with shower unit (electric shower), WC and wash hand basin and a bathroom at first floor level with bath, shower unit (mixer shower), WC and wash hand basin.
Heating and hot water	Accessible parts of the system were visually inspected apart from communal systems, which were not inspected. No tests whatsoever were carried out to the system or appliances. Heating is provided by way of a gas fired wet central heating system supplying radiators throughout. Domestic hot water is provided the central heating system and supplemented from the hot water tank which is located within the store room cupboard.
Drainage	Drainage covers etc were not lifted. Neither drains nor drainage systems were tested. Drainage is understood to be to the main public sewer.
Fire, smoke and burglar alarms	Visually inspected. No tests whatsoever were carried out to the system or appliances. Smoke alarms have been installed within the property. These were not tested. We are advised that fire detection equipment within the

property fully complies with Scottish Government standards effective from February 2022 and this should be confirmed by the purchaser.

All Scottish homes require a smoke alarm to be installed in the room most frequently used for living purposes and in every circulation space on each floor. A heat alarm also needs to be installed in each kitchen. The alarms need to be ceiling mounted and interlinked. Where there is a carbon-fuelled appliance such as a boiler, open fire or wood burner, a carbon monoxide detector is also required. We have not assessed or tested any existing equipment and it is the purchasers responsibility to confirm that the property will comply with these standards following a change of ownership.

Any additional limits to inspection

Only the subject flat and internal communal areas giving access to the flat were inspected.

If the roof space or under-building/basement is communal, reasonable and safe access is not always possible. If no inspection was possible, this will be stated. If no inspection was possible, the surveyor will assume that there are no defects that will have a material effect on the valuation.

The building containing the flat, including any external communal areas, was visually inspected only to the extent that the surveyor is able to give an opinion on the general condition and standard of maintenance.

An inspection for Japanese Knotweed was not carried out. This is a plant which is subject to control regulation, is considered to be invasive and one which can render a property unsuitable for some mortgage lenders. It is therefore assumed that there is no Japanese Knotweed within the boundaries of the property or its neighbouring property. Identification of Japanese Knotweed is best undertaken by a specialist contractor.

The property was fully furnished and had fitted floor coverings, therefore no detailed inspection was possible of the floors and accordingly, no comment can be made on their condition. Internal cupboards were generally filled with storage items. No access was available beneath sanitary or kitchen fittings.

Windows and external doors were not all fully opened or tested.

Limited access was available to any sub-floor areas.

Roof spaces are only entered where deemed safe and reasonable to do so. In keeping with health and safety legislation, roof voids are entered and inspected where secured flooring is provided, consequently a 'head and shoulders' inspection from the access hatch was undertaken in this instance. Our inspection was further restricted due to insulation materials laid between the ceiling joists.


We were not able to fully inspect all areas of boundary walls and fences due to garden vegetation and restricted access.

Some areas of the external building fabric including some roof pitches and chimneys were not fully or closely inspectable from the surrounding ground level.

No inspection of areas below sanitaryware was possible.

The cold water rising main was not fully inspectable.

▷ Sectional diagram showing elements of a typical house:



Reference may be made in this report to some or all of the above component parts of the property. This diagram may assist you in locating and understanding these terms.

2. CONDITION

This section identifies problems and tells you about the urgency of any repairs by using one of the following three categories.

Category 3	Category 2	Category 1
Urgent Repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.	Repairs or replacement requiring future attention, but estimates are still advised.	No immediate action or repair is needed.

Structural movement



Repair category:	1
Notes	Evidence of settlement/movement has affected the building reflected by off level flooring. On the basis of a single inspection this appears longstanding with no evidence of recent movement apparent.

Dampness, rot and infestation



Repair category:	3
Notes	Traces of wood bore infestation were noted to timbers within the property. In the absence of valid guarantees for previous timber specialist treatment works, a reputable timber specialist should carry out a full and thorough inspection of all timbers within the property and provide estimates for any recommended remedial works. Above average damp meter readings were obtained to wall linings adjacent to the first floor bathroom window. The source of water ingress should be confirmed and fully repaired to prevent additional damp and rot related defects. We understand that the Vendors will carry out remedial repairs before point of sale. This should be confirmed.

Chimney stacks



Repair category:	2
Notes	Weathered and open pointing with vegetation growth were noted at chimney stacks. Future repairs will be required. Our inspection of chimneys was limited but they are of an age and style where a degree of regular ongoing maintenance should be anticipated.

Roofing including roof space



Repair category:	2
Notes	Broken slates were visible. Roof coverings are of an age and style where a degree of regular ongoing maintenance should be anticipated. Roofing contractors recommend that roof coverings are inspected regularly in order to ensure they remain watertight.

Rainwater fittings



Repair category:	3
Notes	Rainwater goods are of an older style and have suffered corrosion.

	Maintenance is required and gutters/downpipes checked during heavy rainfall.
	Fern growth noted to downpipe to the front elevation. Repairs are required.

Main walls



Repair category:	2
Notes	Weathered pointing noted to external walls. Repairs to traditional stone chimneys can be expensive, particularly to ornate finishes.

Windows, external doors and joinery



Repair category:	2
Notes	Windows are of an age and style where a degree of ongoing maintenance should be anticipated to sealed units and opening mechanisms. The window unit within the kitchen was noted to have a cracked pane. Future repairs will be required.

External decorations



Repair category:	1
Notes	Paint finished and decorated external surfaces will require re-decoration on a regular basis.

Conservatories/porches



Repair category:	-
Notes	Not applicable.

Communal areas



Repair category:	-
Notes	Not applicable.

Garages and permanent outbuildings



Repair category:	1
Notes	Normal maintenance will be required to the garage. The garage may contain materials with an asbestos content including the corrugated cement sheet roof covering. These have not been tested and we have not carried out an asbestos survey on the property however these materials should be handled by a competent contractor only. Asbestos waste can be costly to dispose of.

Outside areas and boundaries



Repair category:	2
Notes	Evidence of settlement/movement was observed in the form of cracking to the retaining blockwork wall. It is not possible to say that further movement will not occur. All further movement would seem unlikely. Further advice may seem prudent.

Ceilings



Repair category:	1
Notes	Some cracked/uneven ceiling plaster was noted and some repairs may be required at the time of re-decoration or disturbance.

Internal walls



Repair category:	1
Notes	Cracked/bossed wall plaster was noted and repairs may be required at the time of disturbance or re-decoration.

Floors including sub-floors



Repair category:	1
Notes	Due to fitted carpets and floor coverings no detailed inspection of floors was possible and accordingly no comment can be made on their condition.

Internal joinery and kitchen fittings



Repair category:	1
Notes	Within the limitations of our inspection no significant defects were noted. Low level internal glazing should be checked for safety glass.

Chimney breasts and fireplaces



Repair category:	1
Notes	All flue linings should be checked, repaired if necessary and swept prior to fires being re-used. A number of the fireplaces have been removed/covered over. It is assumed that the chimneys are adequately vented with the chimneys capped. Ventilators should be fitted to prevent the build-up of dampness within the chimney flue. It is assumed that the gas fire has been installed in accordance with the manufacturer's recommendations for fluing and ventilation and that this has been regularly checked and tested. All test documentation should be obtained and authenticated at the point of sale. In the absence of any such documentation, the appliance should be tested by a registered engineer prior to use.

Internal decorations



Repair category:	1
Notes	The property is in reasonable decorative order.

Cellars



Repair category:	2
Notes	At the time of inspection water was noted to be trickling into the cellar. The Vendor advises that significant works have been undertaken to the cellar area, carried out by the Local Authority during flood alleviation works undertaken within the area. We understand that the Vendor is to contact the Local Authority regarding the recent water ingress.

Electricity



Repair category:	2
Notes	The Institution of Engineering Technology recommends that inspections and testings are undertaken at least every 5 years and on a change of occupancy. It should be appreciated that only the most recently constructed or re-wired properties will have installations which fully comply with IET regulations.

Gas



Repair category:	1
Notes	In the interests of safety and in light of recent regulations it would be prudent to have all gas appliances checked by a Gas Safe registered contractor.

Water, plumbing and bathroom fittings



Repair category:	2
Notes	A cracked wash hand basin was noted within the attic shower room. Future repairs will be required. No tests have been undertaken of the system, however within the limitations of our inspection, no significant defects were noted. No inspection has been possible to enclosed timbers beneath wet appliances and no comment has been made on the condition of unseen areas. Watertight seals will require to be regularly checked and replaced, to prevent water damage to adjoining areas.

Heating and hot water



Repair category:	1
Notes	It is assumed that the central heating system has been properly installed, updated and maintained to meet with all current regulations and standards with particular regard to fluing and ventilation requirements. Service records should be obtained and checked. In the absence of service documentation further advice should be obtained from a qualified heating engineer to ascertain the condition, efficiency, and life expectancy of the system.

Drainage



Repair category:	1
Notes	All foul and surface water drainage is assumed to be to the main public sewer. The system was not tested.

Summary:

Set out below is a summary of the condition of the property which is provided for reference only. You should refer to the previous comments for detailed information.

Category 3	Structural Movement	1
Urgent Repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.	Dampness, rot and infestation	3
	Chimney stacks	2
	Roofing including roof space	2
	Rainwater fittings	3
Category 2	Main walls	2
Repairs or replacement requiring future attention, but estimates are still advised.	Windows, external doors and joinery	2
	External decorations	1
	Conservatories/porches	-
	Communal areas	-
Category 1	Garages and permanent outbuildings	1
No immediate action or repair is needed.	Outside areas and boundaries	2
	Ceilings	1
	Internal walls	1
	Floors including sub floors	1
	Internal joinery and kitchen fittings	1
	Chimney breasts and fireplaces	1
	Internal decorations	1
	Cellars	2
	Electricity	2
	Gas	1
	Water, plumbing and bathroom fittings	2
	Heating and hot water	1
	Drainage	1

Remember:

The cost of repairs may influence the amount someone is prepared to pay for the property. We recommend that relevant estimates and reports are obtained in your own name.

Warning:

If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions where the effect can be considerable.

3. ACCESSIBILITY INFORMATION

Guidance notes on Accessibility Information:

Three steps or fewer to a main entrance door of the property:

In flatted developments the 'main entrance' would be the flat's own entrance door, not the external door to the communal stair. The 'three steps or fewer' are counted from external ground level to the flat's entrance door. Where a lift is present, the count is based on the number of steps climbed when using the lift.

Unrestricted parking within 25 metres:

For this purpose, 'unrestricted parking' includes parking available by means of a parking permit. Restricted parking includes; parking that is subject to parking restrictions, as indicated by the presence of solid yellow, red or white lines at the edge of the road or by a parking control sign, parking meters or other coin operated machines.

1	Which floor(s) is the living accommodation on?	Ground, First & Attic
2	Are there three steps or fewer to a main entrance door of the property?	Yes
3	Is there a lift to the main entrance door of the property?	No
4	Are all door openings greater than 750mm?	Yes
5	Is there a toilet on the same level as the living room and kitchen?	Yes
6	Is there a toilet on the same level as a bedroom?	Yes
7	Are all rooms on the same level with no-internal steps or stairs?	No
8	Is there unrestricted parking within 25 metres of an entrance door to the building?	Yes

4. VALUATION AND CONVEYANCER ISSUES

This section highlights information that should be checked with a solicitor or licensed conveyancer. It also gives an opinion of market value and an estimated re-instatement cost for insurance purposes

Matters for a solicitor or licensed conveyancer:

The assumed tenure is Absolute Ownership (formerly Feudal).

The full extent of the garden grounds and position of the boundaries should be ascertained by reference to the Title Deeds.

It is assumed that there are no statutory, town planning, road proposals or environmental matters which are likely to have an adverse effect on the property.

The road and footpath adjoining the site are made up and are assumed to be adopted by the Local Authority.

The property may be located in an area subject to higher than normal level of noise on occasion due to the proximity of the Aberlour Hotel.

We understand that the maintenance costs of the common parts of the building will be shared on an equitable basis with the adjoining proprietors, although this should be confirmed.

Some materials within the property may have an asbestos content including the corrugated cement sheet roof covering and the ground lagging noted to pipework in areas. We have not tested these materials and are not acting as Licensed Asbestos Inspectors. These materials should be left undisturbed until advice is obtained from a Licensed Specialist.

We are aware that significant flood prevention works have been carried out locally with a view to alleviating any future risk of flooding. We have assumed that insurance can be obtained on normal terms.

Estimated re-instatement cost for insurance purposes:	For Reinstatement Cost Assessment purposes, it is recommended that the subjects be insured for a sum of not less than £1,455,000 (ONE MILLION FOUR HUNDRED AND FIFTY FIVE THOUSAND POUNDS STERLING).. This figure is the estimate of the cost of rebuilding the premises and bears no direct relationship to current market value.
Valuation and market comments:	Having considered matters, taking account of our general observations on site, we are of the opinion that the Market Value of the subjects in their present condition and with the benefit of vacant possession may be fairly stated in the sum of £310,000 (THREE HUNDRED AND TEN THOUSAND POUNDS STERLING).

Signed:	Electronically by Olga MacGregor MRICS
Report author:	Olga MacGregor MRICS
Company name	Shepherd Chartered Surveyors (Elgin)
Address:	Park House Business Centre, South Street, Elgin, Moray, IV30 1JB
Date of report:	11/10/2024

Mortgage Valuation Report

Clydesdale Bank House

High Street

Aberlour

Moray

AB38 9QB

Seller's Name:

Joanna Murdoch

Date of Inspection:

09/10/2024

Prepared by:

Olga MacGregor MRICS

1. Property Details

Property type:	Purpose built maisonette
Floor(s) on which located (<i>Flat or maisonettes only</i>):	Ground, first & attic
Number of floors in block (<i>Flat or maisonettes only</i>):	3
Number of units in block (<i>Flat or maisonettes only</i>):	2
Is there a lift provided? (<i>Flat or maisonettes only</i>):	No
Property style:	Low rise block
Does the surveyor believe that the property was built for the public sector, e.g. local authority, military, police?	No
Approximate year of construction:	1900

2. Tenure

Tenure:	Absolute Ownership
Ground rent:	
Unexpired years:	

3. Accommodation

Number of living rooms:	1
Number of bedrooms:	4
Number of kitchens:	1
Number of Bathrooms	2
Number of water closets:	2
Other Rooms:	2 - Utility Room and Study
Internal gross floor area (excluding garages and outbuildings):	m ²
External gross floor area (excluding garages and outbuildings):	m ²
Does the property have a residential element greater than 40%?	Yes

4. Garage / Parking / Outbuildings

Parking type:	Single garage
Available on site?	Yes
Permanent Outbuildings:	Not applicable.

5. Construction

Main wall type:	Stone
Other (please specify):	
Roof type:	Slate
Other (please specify):	

6. Special Risks

Has the property suffered structural movement?	Yes
Is this recent or progressive?	No
Is there evidence, history, or reason to anticipate subsidence, heave, landslide or flood in the	No

immediate vicinity?

If yes, please specify any of the above:

7. Service Connections

Based on visual inspection only. If any services appear to be non-mains, please comment on the type and location of the supply in the 'brief description of central heating' section below

Drainage:	Mains
Electricity:	Mains
Central Heating:	Yes
Water:	Mains
Gas:	Mains
Brief description of central heating:	Gas fired wet central heating system supplying radiators throughout.

8. Site

Apparent legal issues to be verified by the conveyancer

Legal Issue	Verification	Description
Rights of way:	Yes	We understand that the Cafe has a right of access across the rear garden for emergency purposes only. This should be confirmed.
Shared drives / access:		
Garage or other amenities on separate site:		
Shared service connections:		
Ill-defined boundaries:		
Agricultural land included with property:		
Other:		

9. Location

Location type:	Mixed residential/commercial
Other (if not specified):	

10. Planning Issues

Has the property been extended / converted / altered?	No
Details (if extended, converted, or altered):	

11. Roads

Roads that relate to the property:	Adopted
------------------------------------	---------

12. General Remarks

General remarks on the property:	The subjects are located within Aberlour where surrounding
----------------------------------	--

	properties are of a mixed residential and commercial nature. Adequate local shopping, educational and transport facilities are available. In addition to the listed accommodation there is a utility room and a study. The assumed tenure is Absolute Ownership (formerly Feudal). The full extent of the garden grounds and position of the boundaries should be ascertained by reference to the Title Deeds. It is assumed that there are no statutory, town planning, road proposals or environmental matters which are likely to have an adverse effect on the property. The road and footpath adjoining the site are made up and are assumed to be adopted by the Local Authority. The property may be located to higher than normal level of noise on occasion due to the proximity of the Aberlour Hotel. We understand that the maintenance costs of the common parts of the building will be shared on an equitable basis with the adjoining proprietors, although this should be confirmed. Some materials within the property may have an asbestos content including the corrugated cement sheet roof covering and the ground lagging noted to pipework in areas. We have not tested these materials and are not acting as Licensed Asbestos Inspectors. These materials should be left undisturbed until advice is obtained from a Licensed Specialist. We are aware that significant flood prevention works have been carried out locally with a view to alleviating any future risk of flooding. We have assumed that insurance can be obtained on normal terms.
--	---

13. Essential Repairs

Information relating to essential repairs for the property:

Estimated cost of essential repairs:

Retention recommendation?

Amount:

14. Comment on Mortgageability

Information relating to mortgageability of the property:

The property forms suitable security for mortgage purposes subject to the specific lending criteria of any mortgage provider.

15. Valuations

Market value in present condition:	£310,000.00
Market value on completion of essential repairs:	
Insurance reinstatement value (to include the cost of total rebuilding, site clearance, professional fees, ancillary charges plus VAT)	£1,455,000.00
Is re-inspection necessary?	No

Signed:	Electronically by Olga MacGregor MRICS
Report author:	Olga MacGregor MRICS
Company name:	Shepherd Chartered Surveyors (Elgin)
Address:	Park House Business Centre, South Street, Elgin, Moray, IV30 1JB
Date of report:	11/10/2024



Property Questionnaire



Property Questionnaire

Clydesdale Bank House

High Street

Aberlour

Moray

AB38 9QB

Property Address:

Clydesdale Bank House
High Street
Aberlour
Moray
AB38 9QB

Seller(s):

Joanna Murdoch

Completion date of Property Questionnaire:

09/10/2024

Note for sellers

- Please complete this form carefully. It is important that your answers are correct.
- The information in your answers will help ensure that the sale of your house goes smoothly. Please answer each question with as much detailed information as you can.
- If anything changes after you fill in this questionnaire but before the date of entry for the sale of your house, tell your solicitor or estate agent immediately.

Information to be given to prospective buyer(s)

1. Length of ownership

How long have you owned the property?	22 years and 1 month
---------------------------------------	----------------------

2. Council Tax

Which Council Tax band is your property in?	D
---	---

3. Parking

What are the arrangements for parking at your property?	Garage, Driveway, On street
---	-----------------------------

4. Conservation Area

Is your property in a designated Conservation Area (i.e. an area of special architectural or historic interest, the character or appearance of which it is desirable to preserve or enhance)?	No
---	----

5. Listed Buildings

Is your property a Listed Building, or contained within one (i.e. a building recognised and approved as being of special architectural or historical interest)?	No
---	----

6. Alterations/additions/extensions

a.	Yes
-----------	-----

(i). During your time in the property, have you carried out any structural alterations, additions or extensions (for example, provision of an extra bath/shower room, toilet, or bedroom)?	
--	--

<i>If you have answered yes, please describe the changes which you have made:</i>	2nd bathroom installed on top floor of the house
---	--

(ii). Did you obtain planning permission, building warrant, completion certificate and other consents for this work?	Yes
--	-----

<i>If you have answered yes, the relevant documents will be needed by the purchaser and you should give them to your solicitor as soon as possible for checking.</i> <i>If you do not have the documents yourself, please note below who has these documents and your solicitor or estate agent will arrange to obtain them.</i>	Not required as internal work on non listed building with no structural amends
b. Have you had replacement windows, doors, patio doors or double glazing installed in your property? If you have answered yes, please answer the three questions below:	No
(i). Were the replacements the same shape and type as the ones you replaced?	
(ii). Did this work involve any changes to the window or door openings?	
(iii). Please describe the changes made to the windows, doors, or patio doors (with approximate dates when the work was completed?) Please give any guarantees which you received for this work to your solicitor or estate agent.	
7. Central Heating	
a. Is there a central heating system in your property? Note: A partial central heating system is one which does not heat all the main rooms of the property – the main living room, the bedroom(s), the hall and the bathroom). <i>If you answered yes/partial:</i> What kind of central heating is there? (Examples: gas-fired, solid fuel, electric storage heating, gas, warm air). <i>If you answered yes, please answer the following three questions:</i>	Yes
(i). When was your central heating system or partial central heating system installed?	Gas
(ii). Do you have a maintenance contract for the central heating system? <i>If you have answered yes, please give details of the company with which you have a maintenance agreement:</i>	Unknown, prior to purchase. Boiler updated within last 5 years.
(iii). When was your maintenance agreement last renewed? (Please provide the month and year).	No

8. Energy Performance Certificate

Does your property have an Energy Performance Certificate which is less than 10 years old?

No

Note: The surveyor will provide this within their inspection.

9. Issues that may have affected your property

a.

Has there been any storm, flood, fire or other structural damage to your property while you have owned it?

No

If you have answered yes, is the damage the subject of any outstanding insurance claim?

b.

Are you aware of the existence of asbestos in your property?

No

If you have answered yes, please give details:

10. Services

a.

Please tick which services are connected to your property and give details of the supplier:

Services	Connected	Supplier
Gas/liquid petroleum gas	Yes	Gas
Water mains/private water supply	Yes	Mains
Electricity	Yes	
Mains drainage	Yes	Standard mains
Telephone		
Cable TV/Satellite		
Broadband		

b.

Is there a septic tank system in the property?

No

If you have answered yes, please answer the two questions below:

(i). Do you have appropriate consents for the discharge from your septic tank?

(ii). Do you have maintenance contract for your septic tank?

If you have answered yes, please give details of the company with which you have a maintenance contract:

11. Responsibilities for Shared or Common Areas

a.

Are you aware of any responsibility to contribute to the cost of anything used jointly, such as the repair of a shared drive, private road, boundary, or garden area?

No

If you have answered yes, please give details:

b.

Is there a responsibility to contribute to repair and maintenance of the roof, common stairwell or other common areas?

Yes

If you have answered yes, please give details:

Roof

c.

Has there been any major repair or replacement of any part of the roof during the time you have owned the property?

Yes

d.

Do you have the right to walk over any of your neighbours' property - for example, to put out your rubbish bin or to maintain your boundaries?

No

If you have answered yes, please give details:

e.

As far as you are aware, do any of your neighbours have the right to walk over your property, for example to put out their rubbish bin or to maintain their boundaries?

No

If you have answered yes, please give details:

f.

As far as you are aware, is there a Public Right of Way across any part of your property? (A Public Right of Way is a way over which the public has a right to pass, whether or not the land is privately-owned).

No

If you have answered yes, please give details:

12. Charges associated with your property

a.

Is there a factor or property manager for your property?

No

If you have answered yes, please provide the name and address and give details of any deposit held and approximate charges:

b.

Is there a common buildings insurance policy?

No

If you have answered yes, is the cost of the insurance included in your monthly/annual factor's charges?

c.

Please give details of any other charges you have to pay on a regular basis for the upkeep of common areas or repair works, e.g. to a Resident's Association, or maintenance or stair fund.

13. Specialist Works

a.

As far as you are aware, has treatment of dry rot, wet rot, damp or any other specialist work ever been carried out to your property?

No

If you have answered yes, please say what the repairs were for, whether they carried out the repairs (and when), or if they were done before you bought the property:

b.

As far as you are aware, has any preventative work for dry rot, wet rot, or damp ever been carried out to your property?

No

If you have answered yes, please give details:

c.

If you have answered yes to 13 (a) or (b), do you have any guarantees relating to this work?

If you have answered yes, these guarantees will be needed by the purchaser and should be given to your solicitor as soon as possible for checking. If you do not have them yourself, please write below who has these documents and your solicitor or estate agent will arrange for them to be obtained. You will also need to provide a description of the work carried out. This may be

shown in the original estimate.

Guarantees are held by:

14. Guarantees

a.

Are there any guarantees or warranties for any of the following?

(i). Electrical work

No

(ii). Roofing

No

(iii). Central Heating

No

(iv). NHBC

No

(v). Damp course

No

(vi). Any other work or installations? (For example, cavity wall insulation, underpinning, indemnity policy)

No

b.

If you have answered 'yes' or 'with title deeds', please give details of the work or installations to which the guarantee(s) relate(s):

c.

Are there any outstanding claims under any of the guarantees listed above?

If you have answered yes, please give details

No

15. Boundaries

a.

So far as you are aware, has any boundary of your property been moved in the last 10 years?

No

If you have answered yes, please give details:

16. Notices that affect your property

In the past 3 years, have you ever received a notice;

a.

advising that the owner of a neighbouring property has made a planning application?

No

b.

that affects your property in some other way?

No

c.

that requires you to do any maintenance, repairs or improvements to your property?

No

Notice:

If you have answered yes to any of **a.-c.** above, please give the notices to your solicitor or estate agent, including any notices which arrive at any time before the date of entry of the purchase of your property.

RESIDENTIAL HOME REPORT TERMS AND CONDITIONS OF ENGAGEMENT



HOME REPORT TERMS AND CONDITIONS

PART 1 – GENERAL

1.1 THE SURVEYORS

The seller has engaged J & E Shepherd to provide the Single Survey Report and a generic Mortgage Valuation Report for Lending Purposes. The seller has also engaged J & E Shepherd to provide an Energy Report in the format prescribed by the accredited Energy Company.

J & E Shepherd are authorised to provide a transcript or retype of the generic Mortgage Valuation Report on to Lender specific forms where requested. For this service a fee may be charged to the prospective purchaser. Transcript reports are commonly requested by Brokers and Lenders. The transcript report will be in the format required by the Lender but will contain the same information, inspection date and valuation figure as the generic Mortgage Valuation Report and the Single Survey.

J & E Shepherd will decline any transcript request which requires the provision of information additional to the information in the report and the generic Mortgage Valuation Report until the Seller has conditionally accepted an offer to purchase, made in writing.

Once the Seller has conditionally accepted an offer to purchase, made in writing, the Purchaser's lender or conveyancer may request that J & E Shepherd provide general comment on standard appropriate supplementary documentation. In the event of a significant amount of documentation being provided to J & E Shepherd, an additional fee may be incurred by the Purchaser.

If information is provided to J & E Shepherd during the conveyancing process which materially affects the valuation stated in the Report and generic Mortgage Valuation Report, J & E Shepherd reserves the right to reconsider the valuation. Where J & E Shepherd requires to amend the valuation in consequence of such information, we will issue an amended Report and generic Mortgage Valuation Report to the Seller. It is the responsibility of the Seller to ensure that the amended Report and generic Mortgage Valuation Report are transmitted to every prospective Purchaser.

The individual Surveyor will be a member of the Royal Institution of Chartered Surveyors who is competent to survey, value and report upon Residential Property. The attending Surveyor will be a member of the RICS Valuer's Registration Scheme and will have the required experience and competency including the skills, understanding and market knowledge to undertake this valuation.

A replacement Home Report (RHR) may also be required, (see S1.10 attached), and these Terms and Conditions, when accepted and returned to J & E Shepherd also relate and are applicable to any RHR where instructed.

If the Surveyor has had previous involvement in the subject property or if a potential conflict of interest exists, this will be notified in writing as an Appendix to these Terms & Conditions.

J & E Shepherd have a written Complaints Handling Procedure (CHP). This CHP document is available from the offices of J & E Shepherd.

1.2 THE REPORT

The Report provided will be a Scottish Single Survey which is a prescribed document as provided by legislation passed by the Scottish Government including the Housing (Scotland) Act 2006 (Prescribed Documents) Regulations 2008.

J & E Shepherd will not provide an amended Report on the Property, except to correct factual inaccuracies.

The report will identify the nature and source of information relied upon in its preparation.

J & E Shepherd shall provide a Market Value of the Property, unless the condition of the Property is such that it would be inappropriate to do so. A final decision on whether a loan will be granted rests with the Lender who may impose retentions in line with their lending criteria. The date of condition and value of the property will be the date of inspection.

A Single Survey is instructed by the Seller and made available to all potential Purchasers in the expectation that the successful Purchaser will have relied upon it. The Royal Institution of Chartered Surveyor rules require disclosure of any potential conflict of interest when acting for the Seller and the Purchaser in the same transaction. The Single Survey may give rise to a conflict of interest and if this is of concern to any party they are advised to seek their own independent advice.

The Report and any expressions or assessments in it are not intended as advice to the Seller or Purchaser or any other person in relation to an asking price or any other sales or marketing decisions.

The Report is based solely on the Property and is not to be relied upon in any manner whatsoever when considering the valuation or condition of any other property.

If certain minor matters are mentioned in the Report it should not be assumed that the Property is free of other minor defects.

Neither the whole nor any part of the report may be published in any way, reproduced or distributed by any party other than the seller, prospective purchasers the Purchaser and their respective professional advisers without the prior written consent of J & E Shepherd.

Information relied upon in the research and preparation of our Report, will be obtained from various sources including information from the Seller including but not restricted to that contained in the Property Questionnaire provided by the Seller, secure and publicly available sales registers, online property information and sales websites and our own records.

1.3 LIABILITY

The Report is prepared with the skill and care reasonably to be expected of a competent residential surveyor who is a member of the Royal Institution of Chartered Surveyors.

The Report shall be prepared in accordance with the RICS Valuation Professional Standards (The Red Book) current version, being the latest published version as at the date of Report. It is confirmed that the valuation will be undertaken in accordance with the International Valuation Standards (IVS). The Firms compliance with these standards may be subject to monitoring under the RICS conduct and disciplinary regulations.

The Report is addressed to the Seller and was prepared in the expectation that it (or a complete copy) along with these Terms and Conditions (or a complete copy) would (or, as the case might be, would have been) be disclosed and delivered to

- the Seller;
- any person(s) noting an interest in purchasing the Property from the Seller;
- any person(s) who make(s) (or on whose behalf is made) an offer to purchase the Property, whether or not that offer is accepted by the Seller;
- the Purchaser; and
- the professional advisers of any of these.

J & E Shepherd acknowledge that their duty of skill and care in relation to the Report is owed to the Seller and to the Purchaser. J & E Shepherd accept no responsibility or liability whatsoever in relation to the Report to persons other than the seller and the Purchaser. The Seller and Purchaser should be aware that if a Lender seeks to rely on this Report they do so at their own risk. In particular, J & E Shepherd accept no responsibility or liability whatsoever to any Lender in relation to the Report. Any such Lender relies upon the report entirely at their own risk.

1.4 GENERIC MORTGAGE VALUATION REPORT

J & E Shepherd undertake to the Seller that they will prepare a generic Mortgage Valuation Report, which will be issued along with the Single Survey. It is the responsibility of the Seller to ensure that the generic Mortgage Valuation Report is provided to every potential Purchaser.

The Seller has the option to exclude the generic Mortgage Valuation Report from being produced.

1.5 TRANSCRIPT MORTGAGE VALUATION FOR LENDING PURPOSES

J & E Shepherd undertake that on being asked to do so by a prospective purchaser, and at an optional minimum charge of £50+vat, or his/her professional advisor or Lender, they will prepare a Transcript Mortgage Valuation Report for Lending Purposes on terms and conditions to be agreed between J & E Shepherd and the Lender and solely for the use of the Lender and upon which the Lender may rely. The decision as to whether finance will be provided is entirely a matter for the Lender. The Transcript Mortgage Valuation Report will be prepared from information contained in the Report and the generic Mortgage Valuation Report, which shall be in accordance with the current RICS Valuation Professional Standards (the Red Book) and the RICS International Valuation Standards (IVS).

1.6 INTELLECTUAL PROPERTY

All intellectual property rights whatsoever (including copyright) in and to the Report, excluding the headings and rubrics, are the exclusive property of J & E Shepherd and shall remain their exclusive property unless they assign the same to any other party in writing.

1.7 PAYMENT

J & E Shepherd are entitled to refrain from delivering the Report to anyone until the fee and other charges for it notified to the Seller have been paid. Additional fees will be charged for subsequent inspections and Reports.

1.8 CANCELLATION

The Seller will be entitled to cancel the inspection by notifying the relevant J & E Shepherd office at any time before the day of the inspection.

J & E Shepherd will be entitled not to proceed with the inspection (and will so report promptly to the Seller) if after arriving at the property, the Surveyor concludes that it is of a type of construction of which the surveyor has insufficient specialist knowledge to be able to provide the inspection satisfactorily. J & E Shepherd will also be entitled not to proceed if after arriving at the property, the inspecting surveyor concludes that the property is exempt under Part 3 of The Housing (Scotland) Act 2006 as detailed in the (Prescribed Documents) Regulations 2008. If there is a potential threat to their health or personal safety, the inspection may be postponed or cancelled, at the surveyor's discretion.

In the case of cancellation or the inspection not proceeding, J & E Shepherd will refund any fees paid by the Seller for the inspection and Report, except for expenses reasonably incurred and any fee due in light of the final paragraph of this section.

In the case of cancellation by the Seller, for whatever reason, after the inspection has taken place but before a written report is issued, J & E Shepherd will be entitled to raise an Invoice equivalent to 80% of the agreed fee.

1.9 PRECEDENCE

If there is any incompatibility between these Terms and Conditions and the Report, these Terms and Conditions take precedence.

1.10 DEFINITIONS

- The "Lender" is the party who has provided or intends or proposes to provide financial assistance to the Purchaser towards the purchase of the Property and in whose favour a standard security will be granted over the Property;
- The "Transcript Mortgage Valuation Report for Lending Purposes" means a separate report, prepared by the Surveyor, prepared from information in the Report and the generic Mortgage Valuation Report, but in a style and format required by the Lender. The Transcript Mortgage Valuation Report for Lending Purposes will be prepared with the skill and care reasonably to be expected from a surveyor who is a member of the Royal Institution of Chartered Surveyors and who is competent to survey, value and report on the Property;
- The "Generic Mortgage Valuation Report" means a separate report, prepared by J & E Shepherd from information in the Report but in the Surveyor's own format;
- "Replacement Home Report" (RHR) relates to a reinspection of the property to prepare a new full Single Survey in order to replace the previous out of date Home Report, normally required after the original Home Report dates 91 days or older;
- The "Market Value" is the estimated amount for which an asset or liability should exchange on the valuation date between a willing Buyer and a willing Seller in an arm's length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion;
- The "Property" is the property which forms the subject of the Report;
- The "Purchaser" is the person (or persons) who enters into a contract to buy the Property from the Seller;
- A "prospective Purchaser" is anyone considering buying the property;
- The "Report" is the report, of the kind described in Part 2 of these Terms and Conditions and in the form set out in Part 1 of Schedule 1 of The Housing (Scotland) Act 2006 (Prescribed Documents) Regulations 2008;
- The "Seller" is/are the proprietor(s) of the Property;
- The "Surveyor" is the author of the report on the Property. The inspection and valuation will be carried out by a Surveyor from J & E Shepherd who will also be a member of the RICS and accredited by the Valuer's Registration Scheme (VRS). Any previous involvement by this Surveyor in the property or potential conflicts of interest will be disclosed as per Section 1.1 above;
- The "Surveyors/J & E Shepherd" are the firm or company of whom the Surveyor is an employee, director, member or partner (unless the Surveyor is not an employee, director, member or partner, when the "Surveyors" means the Surveyor) whose details are set out at the head of the report;
- The "Energy Report" is the advice given by the accredited Energy Company, based on information collected by the Surveyor during the Inspection, and also includes an Energy Performance Certificate, in a Government approved format;

PART 2 – DESCRIPTION OF THE REPORT

2.1 THE SERVICE

The Single Survey is a Report by an independent Surveyor, prepared in an objective way regarding the condition and value of the Property on the day of the inspection, and who is a member of the Royal Institution of Chartered Surveyors. It includes an Energy Report as required by Statute and this is in the format of the accredited Energy Company. In addition, J & E Shepherd has agreed to supply a generic Mortgage Valuation Report.

2.2 THE INSPECTION

The Inspection is a general surface examination of those parts of the Property which are accessible: in other words, visible and readily available for examination from ground and floor levels, without risk of causing damage to the Property or injury to the surveyor.

All references to visual inspection refer to an inspection from within the property at floor level and from ground level within the site and adjoining public areas, without the need to move any obstructions. Any references to left or right are taken facing the front of the property.

Sloping roofs are visually inspected with the aid of binoculars where appropriate. Roof spaces are visually inspected and entered where there is safe and reasonable access, normally defined as being from a 3m ladder within the property. If this is not possible, then physical access to the roof space may be taken by other means if the surveyor deems it safe and reasonable to do so.

Surfaces of exposed floors are visually inspected. No carpets or floor coverings are lifted. Sub-floor areas are inspected only to the extent visible from a readily accessible and unfixed hatch by way of an inverted "head and shoulders" inspection at the access point. Physical access to the sub floor area may be taken if the surveyor deems it is safe and reasonable to do so, and subject to a minimum clearance of 1m between the underside of floor joists and the solum as determined from the access hatch.

The Inspection is carried out with the Seller's permission, without causing damage to the building or contents. Furniture, stored items and insulation are not moved.

Unless identified in the report the surveyor will assume that no harmful or hazardous materials have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

The surveyor will not carry out an asbestos inspection and will not be acting as an asbestos inspector in completing a Single Survey of properties that may fall within the Control of Asbestos in the Workplace Regulations.

In the case of flats, it will be assumed that there is a duty holder, as defined in the Regulations and that a Register of Asbestos and effective Management Plan is in place, which does not require any expenditure, or pose a significant risk to health. No enquiry of the duty holder will be made.

It is assumed that the subject property site and neighbouring areas are free from Japanese Knotweed. Japanese knotweed is an invasive plant that can damage footpaths, driveways, patios and in the worst cases, it can get into the home itself. It is very difficult to get rid of this plant, and removal of this plant can take a number of years, be costly and may affect future saleability and mortgagability of an affected home. Japanese Knotweed is a seasonal growth plant and is almost invisible during the winter months and during its non-growth phase.

2.3 THE REPORT

The Report will be prepared by the surveyor who carried out the property inspection and will describe various aspects of the property as defined by the headings of the Single Survey report with the comments being general and unbiased. The report on the location, style and condition of the property, will be concise and will be restricted to matters that could have a material effect upon value and will omit items that, in the surveyor's opinion, are not significant. If certain minor matters are mentioned, it should not be interpreted that the property is free of any other minor defects.

Throughout the report, the following repair categories will be used to give an overall opinion of the state of repair and condition of the property.

2.3.1 Category 3: Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.

2.3.2 Category 2: Repairs or replacement requiring future attention, but estimates are still advised.

2.3.3 Category 1: No immediate action or repair is needed.

WARNING: If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions when the effect can be considerable.

Parts of the property, which cannot be seen or accessed, will not be reported upon and this will be stated. If the surveyor suspects that a defect may exist within an unexposed area and which could have a material effect upon the value, he may recommend further investigation by specialist contractors.

Where defects or repairs have been identified within the report it is essential that, prior to entering into any legally binding sale or purchase contract, further specialists or contractor's advice and estimates should be obtained, to establish the implications, if any, on a potential offer to purchase or the sale price likely to be achieved for the property.

2.4 SERVICES

Our surveyors are not equipped or qualified to test the services and therefore no comment can be interpreted as implying that the design, installation and function of the services are in accordance/compliance with regulations, safety and efficiency expectations. However, comment is made where there is cause to suspect significant defects or shortcomings with the installations. No tests are made of any services or appliances.

2.5 ACCESSIBILITY

A section is included to help identify the basic information interested parties need to know to decide whether to view a property.

2.6 ENERGY REPORT

A section is included that makes provision for an Energy Report, relative to the property. The surveyor will collect physical data from the property and provide such data in a format required by an accredited Energy Company. J & E Shepherd cannot of course accept liability for any advice given by the Energy Company.

2.7 VALUATION AND CONVEYANCER ISSUES

The last section of the Report contains matters considered relevant to the Conveyancer (Solicitor). It also contains J & E Shepherd's opinion both of the market value of the property and of the re-instatement cost, as defined below.

"Market Value" The estimated amount for which an asset or liability should exchange on the valuation date between a willing buyer and a willing seller in an arm's-length transaction, after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion. In arriving at the opinion of the Market Value the Surveyor also makes various standard assumptions covering, for example, vacant possession; tenure and other legal considerations; contamination and hazardous materials; the condition of un-inspected parts; the right to use mains services; and the exclusion of curtains, carpets etc. from the valuation. In the case of flats, the following further assumptions are made that:

- There are rights of access and exit over all communal roadways, corridors, stairways etc. and to use communal grounds, parking areas, and other facilities;
- There are no particularly troublesome or unusual legal restrictions;
- There is no current dispute between the occupiers of the flats or any outstanding claims or losses; and the costs of repairs to the building are shared among the co-proprietors on an equitable basis.

Any additional assumption, or any found not to apply, is reported.

"Re-instatement cost" is an estimate for insurance purposes of the current cost of rebuilding the Property in its present form unless otherwise stated. This includes the cost of rebuilding the garage and permanent outbuildings, site clearance and professional fees but excludes VAT (except on the fees).

Sellers or prospective Purchasers may consider it prudent to instruct a re-inspection and revaluation after a period of 12 weeks (or sooner if appropriate) to reflect changing circumstances in the market and/or in the physical condition of the Property.

Unless stated otherwise within this report and in the absence of any information to the contrary, we have assumed that:

- All buildings have been erected either prior to planning control, or in accordance with planning permissions, and have the benefit of permanent planning consents or existing use rights for their current use;
- The property is not adversely affected by town planning or road proposals;
- All alterations, additions or extensions to the property have received all necessary Town Planning Consents, Building Authority Approvals (Building Warrants) and Completion Certificates;
- The property complies with all relevant statutory and local authority requirements, including but not limited to Fire Regulations, The Equality Act, The Control of Asbestos Act, Health and Safety Regulations, Environmental Health Regulations, Regulations governing Residential Tenancies and similar.

J & E Shepherd Privacy Policy

Protecting your Privacy

J&E Shepherd and Hardies Property & Construction Consultants are committed to protecting the privacy and security of your personal information. This privacy notice aims to give you information on the types of personal data we may collect about you when you interact with us, how we will collect and process your personal data through your use of our website and during and after use of any of the services provided by us. It also explains how we will store and handle and keep that data safe.

This notice applies to anyone who uses our website or services.

It is important that you read this privacy notice together with any other privacy notice or fair processing notice we may provide on specific occasions when we are collecting personal data about you so that you are fully aware of how and why we are using your data. The following sections will answer any questions you have but if not, please do get in touch by contacting us by post, telephone or email. Contact details are shown below.

Controller

J & E Shepherd (Company No.2837574810) Registered Office: 13, Albert Square, Meadowside, DUNDEE, DD1 1XA and Hardies Property & Construction Consultants (Company Number: SO300703) whose Registered Office: Swilken House, 35 Largo Road, ST ANDREWS, Fife, KY16 8NJ (collectively referred to as Firm, we, us, our in this privacy notice) are the controllers and are responsible for your personal data. This means that we are responsible for deciding how we hold and use personal information about you. We are required under data protection legislation to notify you of the information contained in this privacy notice. It is likely that we will need to update this Privacy Notice from time to time. You are welcome to come back and check this at any time or contact us by any of the means shown below. The law on data protection sets out a number of different reasons or conditions for which an organisation may collect and process your personal data, including:

Consent

In specific situations, we can collect and process your data with your consent. This might include when you complete a form online to receive an email about ways you can receive information about us and our services.

When J&E Shepherd and Hardies Property & Construction Consultants collect your personal data, we will always make clear to you why data is necessary and for what purpose.

Contractual obligations

We need your personal data to comply with our contractual obligations when using one of our many services.

Legal compliance

If the law requires us to, we may need to collect and process your data. For example, we can pass on details of people involved in fraud or other criminal activity affecting J&E Shepherd and Hardies Property & Construction Consultants to law enforcement.

Legitimate interest

In specific situations, we require your data to pursue our legitimate interests in a way which might reasonably be expected when we pursue our aims and objectives as an organisation and which does not materially impact your rights, freedom or interests. For example, we will use personal details to send regular information to our clients about our services.

Special category data

"Special categories" of particularly sensitive personal data require higher levels of protection. We take extra care when collecting, storing and using this type of personal data. We aim to collect and process special category data as little as possible. Generally, we will only collect information on your health to ensure we can make any necessary adjustments. This is to uphold our duty of care, our contractual arrangements and to ensure the safeguarding of staff, those using our services and visitors to our various locations. Other special categories of data may be revealed to us by subjects during the course of delivering our services; we do not strictly process this information but acknowledge it may on occasion be recorded. We will document all incidents of this processing of special category data in our Information Asset Register with reasons, having conducted assessment where required.

The Special Categories of personal data consist of data revealing:

- racial or ethnic origin;
- political opinions;
- religious or philosophical beliefs;
- trade union membership.

They also consist of the processing of:

- genetic data;
- biometric data (e.g. fingerprints) for the purpose of uniquely identifying someone;
- data concerning health;
- data concerning someone's sex life or sexual orientation.

We may process special categories of personal data in the following circumstances:

- With your explicit written consent; or
- Where it is necessary in the substantial public interest, and further conditions are met;
- Where the processing is necessary for further safeguards for your fundamental rights and interests specified in law;
- Where there is a legal obligation.

Further legal controls apply to data relating to criminal convictions and allegations of criminal activity. We may process such data on the same grounds as those identified for "special categories" referred to above.

When we collect your data

When you email us we may collect your name, gender, date of birth, postal address, email and telephone number. For your security, we keep all data secure with appropriate organisational and technical safeguards to keep information safe. When we interact with you we may also collect notes from our conversations with you, details of any complaints or comments you make. We might record your age for identity where the law requires this. We may use technology such as cookies to help us deliver relevant and interesting content in our communications in the future.

We will only ask for and use your personal data collected for the purpose stated at the point at which it is collected. If we believe your data is no longer needed for this purpose we will not process your data further. Your image may be recorded on CCTV when you visit our premises for safety and crime prevention and detection.

Telephone call may be recorded for security and staff training purposes. We may collect your social media username, if you interact with us through those channels, to help us respond to your comments, questions and feedback.

The data privacy law allows this as part of our legitimate interest in understanding our clients. If and when you wish to change how we use your data, you will find details in the 'What are my rights?' section below.

An overview of your data protection rights

- Access to the personal information we may hold about you. This is free of charge and will be supplied to you within one month of your request.
- You can withdraw consent, or object to marketing communications we send you if we do not have a legitimate interest to continue, or once the purpose for which we hold the data has ended.
- You can object to our processing of your personal information for direct marketing purposes.
- You have a right to know why we are processing your data and whether we are sharing your information with any third parties.
- You have the right to request a copy of any information about you that we may hold at any time to check whether it is accurate.
- To ask for your information, please contact the Data Protection Officer using the details below.

Whenever you have given us your consent to use your personal data you have the right to change your mind and stop future communications. You may also opt-out, in some cases, of our processing of your data where we have a legitimate interest.

To protect the confidentiality of your information and the interests of the Firm, we will ask you to verify your identity before proceeding with any request for information. If you have authorised a third party to submit a request on your behalf, we will ask them to prove they have your permission to request such information. You are free to opt-out of hearing from us by any channels at any time unless we have a legal obligation to communicate with you.

We may send you relevant and personalised communications by post. We will do this on the basis of our legitimate interest but only after certain risk assessments.

You are free to opt-out of receiving marketing materials from us by post at any time.

Sometimes we are required to inform you about certain changes. For example, updates to this Privacy Notice and where we have a legal obligation. These administrative messages will not include any marketing content and do not require prior consent when sent by email.

If we did not use your personal data for these purposes, we would be unable to comply with our legal obligations.

To display the most interesting content to you on our website, we may use data we hold about your previous visits.

We may use your data to send you a survey and feedback requests to help improve the way we communicate. These messages will not include marketing and do not require prior consent when sent by email. We have a legitimate interest to do so as this helps make our services more relevant to you.

Data Retention

Whenever we collect or process your personal data, we will only keep it for as long as is necessary for the purpose for which it was collected.

At the end of that retention period, your data will either be deleted completely, put beyond use or anonymised.

Sharing your data

Should we need to, we will share your personal data with third parties and suppliers outside the European Economic Area (EEA).

Protecting your data outside the EEA

The EEA includes all EU Member countries as well as Iceland, Liechtenstein and Norway. We may transfer personal data that we collect from you to third-party data processors in countries that are outside the EEA such as the USA. For example, this might be required when we store data in a Cloud. If we do this, we have procedures in place to ensure your data receives the same protection as if it were being processed inside the EEA and we will treat the information under the guiding principles of this Privacy Notice.

Stopping us from using your data in the future

You can stop communications from us by contacting us using the information below.

How to complain about our processing of your data

If you feel that your data has been handled incorrectly, or you are unhappy with the way we have dealt with your query regarding the way we use your personal data, you have the right to complain to the Information Commissioner's Office (ICO) which regulates the use of information in the UK.

You can call them on 0303 123 1113 or go online to www.ico.org.uk/concerns If you are based outside the UK you have the right to complain to the relevant data protection supervisory authority in your country. If you would like to discuss any aspect of this policy or the way we handle or process your information please contact our Data Protection Officer using the details below.

Here's how to get in touch:

By Post – By writing to us at: Data Protection Officer, Swilken House, 35 Largo Road, St Andrews, KY16 8NJ

By e-mail – You can e-mail us at: Dataprotection@hardies.co.uk or Dataprotection@shepherd.co.uk By Telephone – Please call us on 01334 47646

COVID-19 RISK MANAGEMENT CONTROL MEASURES

COVID-19 RISK MANAGEMENT CONTROL MEASURES FOR COMPLETING YOUR PROPERTY SURVEY SAFELY

addendum to our standard
Terms of Engagement

version 1.0.2



Covid-19 Risk Control Measures for Completing your Property Survey (addendum to existing Terms of Engagement)



This document forms an addendum to our standard Terms of Engagement and takes into account the impact of Covid-19 on the interaction of surveyors and customers. This guide relates to a survey/inspection we are intending to undertake on your property for Home Report, Valuation or EPC purposes. As professional Chartered Surveyors we will act in a transparent and professional manner with all parties involved and will be clear with you about our service and any restrictions to the service as a result of COVID-19.



Please refer to Scottish Government Guidance since you are also expected to be familiar with these prior to our inspection of your property.



Please watch our safety video prior to our inspection on YouTube:

<https://youtu.be/jXKWKiyLfbk>



Additionally, we will commit to the following:

Our Surveyors will be wearing all appropriate Personal Protective Equipment (PPE)* whilst conducting the survey.

For example, gloves, shoe protectors and access to masks where required.

General Summary of control measures

- Our surveyor/s will confirm that they have no COVID-19 symptoms
- You are required to confirm whether anyone in the household has had COVID-19 or has had symptoms, are shielding or clinically vulnerable, or have not yet completed the required period of household isolation
- If either party shows any form of Covid-19 symptoms prior to the inspection taking place, then the appointment must be postponed until safety measures can be complied with
- Our surveyors will use gloves when handling ladders, handles, doors etc
- Our surveyor will have minimal contact with all surfaces whilst at the property
- No physical contact is needed nor will be permitted at any time during the survey
- All equipment used by the surveyor will be disinfected before entering the property.

* the use of specified PPE may vary by agreement

What we will need from you:

To enable the surveyor to spend as little time as possible in your home, we request that you strictly follow 2 metre social-distancing. In addition, we request that all occupants vacate the property where possible (e.g. stay in the driveway, sit in the car or stand in the garden). If that is not possible please congregate in a single room within the property (e.g. the kitchen)



We also request the following:

- Pets are removed from the property or shut away
- Wipe down with disinfectant, and sanitise surfaces, such door handles, hand rails etc., especially in the kitchen & bathroom (after our visit wipe down door handles and "touch points" with a disinfectant)
- Please open all internal doors and open some windows for ventilation
- Cupboards containing meters and boilers/hot tanks are left open, please also make sure all curtains and blinds are open.
- Please open loft hatches and setup loft ladders if possible, failing which the Surveyor will use own ladders
- It would also help if you could prepare answers about the following, and advise the surveyor on the day from a safe distance:
 - Where are the electrics located in the property?
 - Where is the gas meter located?
 - Where is the water stopcock located?
 - Where is the water meter located?
 - Where is the central heating boiler located?
 - Are you aware of any issues in or with the property, if so please specify?
 - Do you have any certification relating to gas and electricity safety?
 - Do you have any guarantees or warranties for windows, boilers, historical damp treatment, extensions etc.?
 - If applicable where is the cold-water storage tank located?
 - If applicable where is the hot water cylinder located?
 - Is there underfloor heating? If so, where are the controls?
 - If you have a floor plan of the property can you email this in advance of the inspection- this will help reduce the surveyors time in the property

Your Health & Safety: Are you in at 'at risk' or 'vulnerable' category?

Government is advising those who are at increased risk of severe illness from coronavirus (COVID-19) to be particularly stringent in following social distancing measures. This group includes those who are:



- Aged 70 or older (regardless of medical conditions)
- Under 70 with an underlying health condition listed below (i.e. anyone instructed to get a flu jab as an adult each year on medical grounds):
 - Chronic (long-term) respiratory diseases, such as asthma, chronic obstructive pulmonary disease (COPD), emphysema or bronchitis
 - Chronic heart disease, such as heart failure
 - Chronic kidney disease
 - Chronic liver disease, such as hepatitis
 - Chronic neurological conditions, such as Parkinson's disease, motor neurone disease, multiple sclerosis (MS), a learning disability or cerebral palsy
 - Diabetes
 - Problems with your spleen – for example, sickle cell disease or if you have had your spleen removed
 - A weakened immune system as the result of conditions such as HIV and AIDS, or medicines such as steroid tablets or chemotherapy
 - Being seriously overweight (a body mass index (BMI) of 40 or above)
 - Women who are pregnant
 - Anyone who has received an organ transplant and remain on ongoing immunosuppression medication
 - Anyone with cancer or leukaemia who are undergoing active chemotherapy or radiotherapy
 - Anyone with severe chest conditions such as cystic fibrosis or severe asthma (requiring hospital admissions or courses of steroid tablets
 - Anyone with severe diseases of body systems, such as severe kidney disease (dialysis)
- Note: there are some clinical conditions which put people at even higher risk of severe illness from COVID-19. If you are in this category please refer to [www.NHSinform.Scot/coronavirus](https://www.nhs.uk/inform-scot/coronavirus) in order to keep yourself and others safe.

If you are in an at-risk category, please do let us know in advance and we will postpone the inspection until it is safe to do so. Should you have any questions or concerns, please do not hesitate to contact us directly.

Thank you for your cooperation in advance of our inspection:



Coronavirus

**Wash your hands
with soap and water
more often
for 20 seconds**

Use a tissue to turn off the tap.
Dry hands thoroughly.



In the event that you have
any further queries, please do
not hesitate to contact your
local surveyor.
Details of your local office
can be found via our website:

www.shepherd.co.uk



Home Report
Valuation Report
Executory Valuation
Tax Valuations
Separation Valuation
Private Sale Valuation
New Build & Plot Valuation
Insurance Reinstatement Valuation
Portfolio Valuation
Rental Valuation
Drive By & Desktop Valuation
Energy Performance Certificate (EPC)
Level Two Survey & Valuation Report
Level Two Condition Report
Expert Witness Report



Commercial Valuation
Commercial Agency
Acquisitions Consultancy
Commercial Lease Advisory
Rent Reviews
Asset Management
Development Appraisals & Consultancy
Auctions
Property Management
Professional Services
Licensed Trade & Leisure
Expert Witness Report
Rating
Property Investment
Public Sector



Quantity Surveying
Building Surveying
Project Management
Dispute Resolution Support Services
Principal Designer
Clerk of Works
Commercial EPC
Health & Safety Management
Employer's Agent
Energy Consultancy
Housing Partnerships
Housing Consultancy
Development Monitoring
Mediation Services

Aberdeen

△△△ 01224 202800

Ayr

△△ 01292 267987

Bearsden

△△ 0141 611 1500

Belfast

△ 02890 912975

Birmingham

△ 0121 270 2266

Coatbridge

△△ 01236 436561

Cumbernauld

△△ 01236 780000

Dalkeith

△△ 0131 663 2780

Dumbarton

△△ 01389 731682

Dumfries

△△△ 01387 264333

Dundee

△△ 01382 200454
△ 01382 220699

Dunfermline

△△ 01383 722337
△ 01383 731841

East Kilbride

△△ 01355 248535

Edinburgh

△△ 0131 2251234
△ 0131 557 9300

Elgin

△△ 01343 553939

Falkirk

△△ 01324 635 999

Fraserburgh

△△ 01346 517456

Galashiels

△△ 01896 750150

Glasgow

△△△ 0141 331 2807

Glasgow South

△△ 0141 649 8020

Glasgow West End

△△ 0141 353 2080

Greenock

△△ 01475 730717

Hamilton

△△ 01698 897548

Inverness

△△△ 01463 712239

Kilmarnock

△△ 01563 520318

Kirkcaldy

△△ 01592 205442

Leeds

△ 0113 322 5069

Livingston

△△ 01506 416777

London

△△ 02033 761 236

Montrose

△△ 01674 676768

Motherwell

△△ 01698 252229

Musselburgh

△△ 0131 653 3456

Oban

△△ 01631 707 800

Paisley

△△ 0141 889 8334

Perth

△△ 01738 638188
△ 01738 631631

Peterhead

△△ 01779 470766

St Andrews

△△ 01334 477773
△ 01334 476469

Saltcoats

△△ 01294 464228

Stirling

△△ 01786 450438
△ 01786 474476