

# YOUR ONESURVEY HOME REPORT

---

## ADDRESS

---

Flat 11  
19 Kirkvale Drive  
Newton Mearns, Glasgow  
G77 5HD

## PREPARED FOR

---

K Marshall

## INSPECTION CARRIED OUT BY:



## SELLING AGENT:



## HOME REPORT GENERATED BY:





# Document Index

Document	Status	Prepared By	Prepared On
Single Survey	Final	Glasgow South - Allied Surveyors Scotland Ltd	28/05/2025
Mortgage Certificate	Final	Glasgow South - Allied Surveyors Scotland Ltd	28/05/2025
Property Questionnaire	Final	K Marshall	27/05/2025
EPC	FileUploaded	Glasgow South - Allied Surveyors Scotland Ltd	28/05/2025
Additional Documents	FileUploaded		

## Important Notice:

This report has been prepared for the purposes and use of the person named on the report. In order to ensure that you have sight of a current and up to date copy of the Home Report it is **essential** that you log onto [www.onesurvey.org](http://www.onesurvey.org) (free of charge) to download a copy personalised in your own name. This enables both Onesurvey and the Surveyor to verify that you have indeed had sight of the appropriate copy of the Home Report prior to your purchasing decision. This personalised report can then be presented to your legal and financial advisers to aid in the completion of your transaction. **Failure to obtain a personalised copy may prevent the surveyor having any legal liability to you as they will be unable to determine that you have relied on this report prior to making an offer to purchase.**

Neither the whole, nor any part of this report may be included in any published document, circular or statement, nor published in any way without the consent of Onesurvey Ltd. Only the appointed Chartered Surveyor can utilise the information contained herein for the purposes of providing a transcription report for mortgage/loan purposes.



P A R T 1 .

# SINGLE SURVEY

---

A report on the condition of the property, with categories being rated from 1 to 3.





# Single Survey

Survey report on:

<b>Surveyor Reference</b>	WH/3627
---------------------------	---------

<b>Customer</b>	K Marshall
-----------------	------------

<b>Selling address</b>	Flat 11 19 Kirkvale Drive Newton Mearns, Glasgow G77 5HD
------------------------	---

<b>Date of Inspection</b>	28/05/2025
---------------------------	------------

<b>Prepared by</b>	Gary Firth, MRICS Glasgow South - Allied Surveyors Scotland Ltd
--------------------	--



# **SINGLE SURVEY TERMS AND CONDITIONS (WITH MVR)**

## **PART 1 - GENERAL**

### **1.1 THE SURVEYORS**

The Seller has engaged the Surveyors to provide the Single Survey Report and a generic Mortgage Valuation Report for Lending Purposes. The Seller has also engaged the Surveyors to provide an Energy Report in the format prescribed by the accredited Energy Company.

The Surveyors are authorised to provide a transcript or retype of the generic Mortgage Valuation Report on to Lender specific pro-forma. Transcript reports are commonly requested by Brokers and Lenders. The transcript report will be in the format required by the Lender but will contain the same information, inspection date and valuation figure as the generic Mortgage Valuation Report and the Single Survey. The Surveyors will decline any transcript request which requires the provision of information additional to the information in the Report and the generic Mortgage Valuation Report until the Seller has conditionally accepted an offer to purchase made in writing.

Once the Seller has conditionally accepted an offer to purchase made in writing, the Purchaser's lender or conveyancer may request that the Surveyors provide general comment on standard appropriate supplementary documentation. In the event of a significant amount of documentation being provided to the Surveyors, an additional fee may be incurred by the Purchaser. Any additional fee will be agreed in writing.

If information is provided to the Surveyors during the conveyancing process which materially affects the valuation stated in the Report and generic Mortgage Valuation Report, the Surveyors reserve the right to reconsider the valuation. Where the Surveyors require to amend the valuation in consequence of such information, they will issue an amended Report and generic Mortgage Valuation Report to the Seller. It is the responsibility of the Seller to ensure that the amended Report and generic Mortgage Valuation Report are transmitted to every prospective Purchaser.

The individual Surveyor will be a member of the Royal Institution of Chartered Surveyors who is competent to survey, value and report upon Residential Property.<sup>1</sup>

If the Surveyors have had a previous business relationship within the past two years with the Seller or Sellers Agent or relative to the property, they will be obliged to indicate this by ticking the adjacent box.



The Surveyors have a written complaints handling procedure. This is available from the offices of the Surveyors at the address stated.

### **1.2 THE REPORT**

The Surveyors will not provide an amended Report on the Property, except to correct factual inaccuracies.

---

<sup>1</sup> Which shall be in accordance with the current RICS Valuation Standards (the Red Book) and RICS Codes of Conduct



The Report will identify the nature and source of information relied upon in its preparation.

The Surveyor shall provide a Market Value of the Property, unless the condition of the Property is such that it would be inappropriate to do so. A final decision on whether a loan will be granted rests with the Lender who may impose retentions in line with their lending criteria. The date of condition and value of the property will be the date of inspection.

To date, Purchasers have normally obtained their own report from their chosen Surveyor. By contrast, a Single Survey is instructed by the Seller and made available to all potential Purchasers in expectation that the successful Purchaser will have relied upon it. The Royal Institution of Chartered Surveyors rules require disclosure of any potential conflict of interest when acting for the Seller and the Purchaser in the same transaction. The Single Survey may give rise to a conflict of interest and if this is of concern to any party they are advised to seek their own independent advice.

The Report and any expressions or assessments in it are not intended as advice to the Seller or Purchaser or any other person in relation to an asking price or any other sales or marketing decisions.

The Report is based solely on the Property and is not to be relied upon in any manner whatsoever when considering the valuation or condition of any other property.

If certain minor matters are mentioned in the Report it should not be assumed that the Property is free of other minor defects.

Neither the whole nor any part of the Report may be published in any way, reproduced or distributed by any party other than the Seller, prospective purchasers and the Purchaser and their respective professional advisers without the prior written consent of the Surveyors.

### **1.3 LIABILITY**

The Report is prepared with the skill and care reasonably to be expected of a competent residential surveyor who is a member of the Royal Institution of Chartered Surveyors.

The Report is addressed to the Seller and was prepared in the expectation that it (or a complete copy) along with these Terms and Conditions (or a complete copy) would (or, as the case might be, would have been) be disclosed and delivered to

- the Seller;
- any person(s) noting an interest in purchasing the Property from the Seller;
- any person(s) who make(s) (or on whose behalf is made) an offer to purchase the Property, whether or not that offer is accepted by the Seller;
- the Purchaser; and
- the professional advisers of any of these.



The Surveyors acknowledge that their duty of skill and care in relation to the Report is owed to the Seller and to the Purchaser. The Surveyors accept no responsibility or liability whatsoever in relation to the Report to persons other than the Seller and the Purchaser. The Seller and Purchaser should be aware that if a Lender seeks to rely on this Report they do so at their own risk. In particular, the Surveyors accept no responsibility or liability whatsoever to any Lender in relation to the Report. Any such Lender relies upon the Report entirely at their own risk.

#### **1.4 GENERIC MORTGAGE VALUATION REPORT**

The Surveyors undertake to the Seller that they will prepare a generic Mortgage Valuation Report, which will be issued along with the Single Survey. It is the responsibility of the Seller to ensure that the generic Mortgage Valuation Report is provided to every potential Purchaser.

#### **1.5 TRANSCRIPT MORTGAGE VALUATION FOR LENDING PURPOSES**

The Surveyors undertake that on being asked to do so by a prospective purchaser, or his/her professional advisor or Lender, they will prepare a Transcript Mortgage Valuation Report for Lending Purposes on terms and conditions to be agreed between the Surveyors and Lender and solely for the use of the Lender and upon which the Lender may rely. The decision as to whether finance will be provided is entirely a matter for the Lender. The Transcript Mortgage Valuation Report will be prepared from information contained in the Report and the generic Mortgage Valuation Report. 2

#### **1.6 INTELLECTUAL PROPERTY**

All intellectual property rights whatsoever (including copyright) in and to the Report, excluding the headings and rubrics, are the exclusive property of the Surveyors and shall remain their exclusive property unless they assign the same to any other party in writing.

#### **1.7 PAYMENT**

The Surveyors are entitled to refrain from delivering the Report to anyone until the fee and other charges for it notified to the Seller have been paid. Additional fees will be charged for subsequent inspections and Reports.

#### **1.8 CANCELLATION**

The Seller will be entitled to cancel the inspection by notifying the Surveyor's office at any time before the day of the inspection.

The Surveyor will be entitled not to proceed with the inspection (and will so report promptly to the Seller) if after arriving at the property, the Surveyor concludes that it is of a type of construction of which the surveyor has insufficient specialist knowledge to be able to provide the inspection satisfactorily. The Surveyor will also be entitled not to proceed if after arriving at the property, the surveyor concludes that the property is exempt under Part 3 of The Housing (Scotland) Act 2006 as detailed in the (Prescribed Documents) Regulations 2008. If there is a potential threat to their health or personal safety, the inspection may be postponed or cancelled, at the Surveyor's discretion.

In the case of cancellation or the inspection not proceeding, the Surveyor will refund any fees paid by the Seller for the inspection and Report, except for



expenses reasonably incurred and any fee due in light of the final paragraph of this section.

In the case of cancellation by the Seller, for whatever reason, after the inspection has taken place but before a written report is issued, the Surveyor will be entitled to raise an Invoice equivalent to 80% of the agreed fee.

## **1.9 PRECEDENCE**

If there is any incompatibility between these Terms and Conditions and the Report, these Terms and Conditions take precedence.

## **1.10 DEFINITIONS**

- the "Lender" is the party who has provided or intends or proposes to provide financial assistance to the Purchaser towards the purchase of the Property and in whose favour a standard security will be granted over the Property;
- the "Transcript Mortgage Valuation Report for Lending Purposes" means a separate report, prepared by the Surveyor, prepared from information in the Report and the generic Mortgage Valuation Report, but in a style and format required by the Lender. The Transcript Mortgage Valuation Report for Lending Purposes will be prepared with the skill and care reasonably to be expected from a surveyor who is a member of the Royal Institution of Chartered Surveyors and who is competent to survey, value and report on the Property;
- the "Generic Mortgage Valuation Report" means a separate report, prepared by the Surveyor from information in the Report but in the Surveyor's own format.
- the "Market Value" is *The estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an arm's-length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion*
- the "Property" is the property which forms the subject of the Report;
- the "Purchaser" is the person (or persons) who enters into a contract to buy the Property from the Seller;
- a "prospective Purchaser" is anyone considering buying the Property.
- the "Report" is the report, of the kind described in Part 2 of these Terms and Conditions and in the form set out in part 1 of Schedule 1 of the Housing (Scotland) Act 2006 (Prescribed Documents) Regulations 2008;
- the "Seller" is/are the proprietor(s) of the Property;
- the "Surveyor" is the author of the Report on the Property; and

---

<sup>2</sup> Which shall be in accordance with the current RICS Valuation Standards (the Red Book) and RICS Rules of Conduct.



- the "Surveyors" are the firm or company of which the Surveyor is an employee, director, member or partner (unless the Surveyor is not an employee, director, member or partner, when the "Surveyors" means the Surveyor) whose details are set out at the head of the Report.
- the "Energy Report" is the advice given by the accredited Energy Company, based on information collected by the Surveyor during the Inspection, and also includes an Energy Performance Certificate, in a Government approved format.

## **PART 2 – DESCRIPTION OF THE REPORT**

### **2.1 THE SERVICE**

The Single Survey is a Report by an independent Surveyor, prepared in an objective way regarding the condition and value of the Property on the day of the inspection, and who is a member of the Royal Institution of Chartered Surveyors. It includes an Energy Report as required by Statute and this is in the format of the accredited Energy Company. In addition, the Surveyor has agreed to supply a generic Mortgage Valuation Report.

### **2.2 THE INSPECTION**

The Inspection is a general surface examination of those parts of the Property which are accessible: in other words, *visible and readily available for examination from ground and floor levels, without risk of causing damage to the Property or injury to the Surveyor.*

All references to visual inspection refer to an inspection from within the property at floor level and from ground level within the site and adjoining public areas, without the need to move any obstructions. Any references to left or right are taken facing the front of the property.

The Inspection is carried out with the Seller's permission, without causing damage to the building or contents. Furniture, stored items and insulation are not moved.

Unless identified in the report the Surveyor will assume that no harmful or hazardous materials have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

The Surveyor will not carry out an asbestos inspection, and will not be acting as an asbestos inspector in completing a Single Survey of properties that may fall within the Control of Asbestos in the Workplace Regulations. In the case of flats it will be assumed that there is a duty holder, as defined in the Regulations and that a Register of Asbestos and effective Management Plan is in place, which does not require any expenditure, or pose a significant risk to health. No enquiry of the duty holder will be made.

### **2.3 THE REPORT**

The Report will be prepared by the Surveyor who carried out the property inspection and will describe various aspects of the property as defined by the headings of the Single Survey report with the comments being general and unbiased. The report on the location, style and condition of the property, will be concise and will be restricted to matters that could have a material effect upon value and will omit items that, in the Surveyor's opinion, are not



significant. If certain minor matters are mentioned, it should not be interpreted that the property is free of any other minor defects.

Throughout the report, the following repair categories will be used to give an overall opinion of the state of repair and condition of the property.

2.3.1 Category 3: Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.

2.3.2 Category 2: Repairs or replacement requiring future attention, but estimates are still advised.

2.3.3 Category 1: No immediate action or repair is needed.

**WARNING:** If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions when the effect can be considerable.

Parts of the property, which cannot be seen or accessed, will not be reported upon and this will be stated. If the Surveyor suspects that a defect may exist within an unexposed area and which could have a material effect upon the value, he may recommend further investigation by specialist contractors.

## 2.4 SERVICES

Surveyors are not equipped or qualified to test the services and therefore no comment can be interpreted as implying that the design, installation and function of the services are in accordance/compliance with regulations, safety and efficiency expectations. However, comment is made where there is cause to suspect significant defects or shortcomings with the installations. No tests are made of any services or appliances.

## 2.5 ACCESSIBILITY

A section is included to help identify the basic information interested parties need to know to decide whether to view a property.

## 2.6 ENERGY REPORT

A section is included that makes provision for an Energy Report, relative to the property. The Surveyor will collect physical data from the property and provide such data in a format required by an accredited Energy Company. The Surveyor cannot of course accept liability for any advice given by the Energy Company.

## 2.7 VALUATION AND CONVEYANCER ISSUES

The last section of the Report contains matters considered relevant to the Conveyancer (Solicitor). It also contains the Surveyor's opinion both of the market value of the property and of the re-instatement cost, as defined below.

*"Market Value" The estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an*



*arm's-length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion.* In arriving at the opinion of the Market Value the Surveyor also makes various standard assumptions covering, for example, vacant possession; tenure and other legal considerations; contamination and hazardous materials; the condition of un-inspected parts; the right to use mains services; and the exclusion of curtains, carpets etc. from the valuation. In the case of flats, the following further assumptions are made that:

- \*There are rights of access and exit over all communal roadways, corridors, stairways etc. and to use communal grounds, parking areas, and other facilities;
- \*There are no particularly troublesome or unusual legal restrictions;
- \*There is no current dispute between the occupiers of the flats or any outstanding claims or losses; and the costs of repairs to the building are shared among the co-proprietors on an equitable basis.

Any additional assumption, or any found not to apply, is reported.

*“Re-instatement cost” is an estimate for insurance purposes of the current cost of rebuilding the Property in its present form* unless otherwise stated. This includes the cost of rebuilding the garage and permanent outbuildings, site clearance and professional fees, but excludes VAT (except on the fees).

Sellers or prospective Purchasers may consider it prudent to instruct a reinspection and revaluation after a period of 12 weeks (or sooner if appropriate) to reflect changing circumstances in the market and/or in the physical condition of the Property



## 1. INFORMATION AND SCOPE OF INSPECTION

This section tells you about the type, accommodation, neighbourhood, age and construction of the property. It also tells you about the extent of the inspection and highlights anything that the Surveyor could not inspect.

All references to visual inspection refer to an inspection from within the property without moving any obstructions and externally from ground level within the site and adjoining public areas. Any references to left or right in a description of the exterior of the property refer to the view of someone standing facing that part of the property from the outside.

The inspection is carried out without causing damage to the building or its contents and without endangering the occupiers or the Surveyor. Heavy furniture, stored items and insulation are not moved. Unless identified in the report the Surveyor will assume that no harmful or hazardous materials or techniques have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

Services such as TV/cable connection, internet connection, swimming pools and other leisure facilities will not be inspected or reported on.

Description	Second floor flat in a three storey flatted block containing six flats in total. No lift.
Accommodation	Second floor: entrance hallway, living room, dining room, two bedrooms (one with en-suite bathroom), kitchen with breakfasting area and shower room with WC.
Gross internal floor area (m2)	108m2 or thereby.
Neighbourhood and location	The subject property is located within a popular and sought after residential area. Close by is Kirkhill Primary School. Shopping and transport facilities are available within a half mile radius.
Age	55 years old.
Weather	Dry and sunny following period of sustained heavy rainfall.
Chimney stacks	None.
Roofing including roof space	<p>The roof is flat and clad with felt or similar. No inspected.</p> <p><b><i>Sloping roofs were visually inspected with the aid of binoculars where required.</i></b></p> <p>Flat roofs have a limited life and depending on their age and quality of workmanship can fail at any time.</p> <p><b><i>Roof spaces were visually inspected and were entered where there was safe and reasonable access, normally defined as being from a 3m ladder within the property. If this is not possible, then physical access to the roof space may be taken by other means if the Surveyor deems it safe and reasonable to do so.</i></b></p> <p><b><i>Roofs are prone to water penetration during adverse weather but it is not always possible for surveyors to identify this likelihood in good or dry weather. All roofs should be inspected and repaired by reputable tradesmen on an annual basis and especially after storms.</i></b></p>



Rainwater fittings	<p>These are mainly run internally. PVC remainder.</p> <p><b><i>Visually inspected with the aid of binoculars where required.</i></b></p>
Main walls	<p>Cavity brick construction rendered on face externally having a stone base course and dressings. UPVC weatherboard below windows to front.</p> <p><b><i>Visually inspected with the aid of binoculars where required.</i></b></p> <p><b><i>Foundations and concealed parts were not exposed or inspected.</i></b></p>
Windows, external doors and joinery	<p>Replacement UPVC double glazed units.</p> <p>Timber door from communal entrance close/stairwell to flat under report.</p> <p>UPVC front and back close doors.</p> <p>UPVC soffit and fascia boards.</p> <p><b><i>Internal and external doors were opened and closed where keys were available.</i></b></p> <p><b><i>Random windows were opened and closed where possible.</i></b></p> <p><b><i>Doors and windows were not forced open.</i></b></p>
External decorations	Not applicable.
Conservatories / porches	Not applicable.
Communal areas	<p>Communal entrance vestibule, close and stairwell.</p> <p><b><i>Circulation areas visually inspected.</i></b></p>
Garages and permanent outbuildings	<p>Lock up garage number 5. Brick construction having a felt roof. No access gained.</p> <p><b><i>Visually inspected.</i></b></p>
Outside areas and boundaries	<p>Garden ground to the front, side and rear which is predominantly grass.</p> <p>Mature trees and shrubs.</p> <p><b><i>Visually inspected.</i></b></p>
Ceilings	<p>Plasterboard design.</p> <p><b><i>Visually inspected from floor level.</i></b></p>
Internal walls	<p>Brick construction plastered on the hard both sides and of timber frame finished with plasterboard.</p> <p><b><i>Visually inspected from floor level.</i></b></p> <p><b><i>Using a moisture meter, walls were randomly tested for dampness where considered appropriate.</i></b></p>



Floors including sub floors	<p>Suspended timber.</p> <p><b>Surfaces of exposed floors were visually inspected. No carpets or floor coverings were lifted.</b></p> <p><b>Sub-floor areas were inspected only to the extent visible from a readily accessible and unfixed hatch by way of an inverted "head and shoulders" inspection at the access point.</b></p> <p><b>Physical access to the sub floor area may be taken if the Surveyor deems it is safe and reasonable to do so, and subject to a minimum clearance of 1m between the underside of floor joists and the solum as determined from the access hatch.</b></p>
Internal joinery and kitchen fittings	<p>Internal woodwork is typical of a property of this type and age.</p> <p><b>Built-in cupboards were looked into but no stored items were moved.</b></p> <p><b>Kitchen units were visually inspected excluding appliances.</b></p>
Chimney breasts and fireplaces	None.
Internal decorations	<p>Wallpaper and colourwash emulsion.</p> <p><b>Visually inspected.</b></p>
Cellars	None.
Electricity	<p>Mains.</p> <p><b>Accessible parts of the wiring were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances.</b></p> <p><b>Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the Surveyor will state that in the report and will not turn them on.</b></p>
Gas	<p>Mains.</p> <p><b>Accessible parts of the system were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances.</b></p> <p><b>Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the Surveyor will state that in the report and will not turn them on.</b></p>




<p>Water, plumbing and bathroom fittings</p>	<p>Mains. Modern white sanitary fittings.</p> <p><b><i>Visual inspection of the accessible pipework, water tanks, cylinders and fittings without removing any insulation.</i></b></p> <p><b><i>No tests whatsoever were carried out to the system or appliances.</i></b></p> <p><b><i>Concealed areas around baths and shower trays cannot be inspected however water spillage over a period of time can result in unexpected defects to hidden parts of the building fabric.</i></b></p>
<p>Heating and hot water</p>	<p>Located in the kitchen is a Worcester central heating boiler which we also assume provides domestic hot water.</p> <p><b><i>Accessible parts of the system were visually inspected apart from communal systems, which were not inspected.</i></b></p> <p><b><i>No tests whatsoever were carried out to the system or appliances.</i></b></p>
<p>Drainage</p>	<p>Both foul and storm drainage are assumed to be to the public sewer.</p> <p><b><i>Drainage covers etc were not lifted.</i></b></p> <p><b><i>Neither drains nor drainage systems were tested.</i></b></p>
<p>Fire, smoke and burglar alarms</p>	<p>There are smoke alarms within the flat.</p> <p>There is a fire/heat alarm within the kitchen.</p> <p><b><i>Visually inspected.</i></b></p> <p><b><i>No test whatsoever were carried out to any systems or appliances.</i></b></p> <p><b><i>There is now a requirement in place for compliant interlinked fire, smoke and heat detectors in residential properties. The new fire smoke and alarm standard came into force in Scotland in February 2022, requiring a smoke alarm to be installed in the room most frequently used for living purposes and in every circulation space on each floor. A heat alarm also requires to be installed in each kitchen. The alarms need to be ceiling mounted and interlinked. Where there is a carbon fuelled appliance such as a boiler, open fire or wood burner etc. a carbon monoxide detector is also required.</i></b></p> <p><b><i>The surveyor will only comment on the presence of a smoke detector etc. but will not test them, ascertain if they are in working order, interlinked and / or fully compliant with the fire and smoke alarm standard that was introduced in 2022.</i></b></p> <p><b><i>We have for the purposes of the report, assumed the system is fully compliant, if not then the appropriate compliant system will required to be installed prior to sale. This of course should be confirmed by your legal advisor.</i></b></p>



<p>Any additional limits to inspection</p>	<p><b><i>Only the subject flat and internal communal areas giving access to the flat were inspected.</i></b></p> <p><b><i>If the roof space or under-building / basement is communal, reasonable and safe access is not always possible. If no inspection was possible, this will be stated. If no inspection was possible, the Surveyor will assume that there are no defects that will have a material effect on the valuation.</i></b></p> <p><b><i>The building containing the flat, including any external communal areas, was visually inspected only to the extent that the Surveyor is able to give an opinion on the general condition and standard of maintenance.</i></b></p> <p><b><i>An inspection for Japanese Knotweed was not carried out. This is a plant which is subject to control regulation, is considered to be invasive and one which can render a property unsuitable for some mortgage lenders. It is therefore assumed that there is no Japanese Knotweed within the boundaries of the property or its neighbouring property. Identification of Japanese Knotweed is best undertaken by a specialist contractor. If it exists removal must be undertaken in a controlled manner by specialist contractors. This can prove to be expensive.</i></b></p> <p><b><i>Normal maintenance is not treated as a repair for the purposes of the Single Survey. When a category 1 rating is provided this means the property must continue to be maintained in the normal way.</i></b></p>
--	--



## Sectional Diagram showing elements of a typical house



Reference may be made in this report to some or all of the above component parts of the property. This diagram may assist you in locating and understanding these items.



## 2. CONDITION

This section identifies problems and tells you about the urgency of any repairs by using one of the above 3 categories:

Category 3	Category 2	Category 1
Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.	Repairs or replacement requiring future attention, but estimates are still advised.	No immediate action or repair is needed.

Structural movement	
Repair category:	1
Notes:	No obvious or serious defect noted within the limitations of this inspection.

Dampness, rot and infestation	
Repair category:	1
Notes:	No visible indication of any defects of this nature noted.

Chimney stacks	
Repair category:	
Notes:	Not applicable.

Roofing including roof space	
Repair category:	1
Notes:	We understand from the vendor that the roof was overlaid in 2019 and that a twenty year guarantee exists. This should be sought as a condition of purchase.

Rainwater fittings	
Repair category:	1
Notes:	Appear adequately maintained.



Category 3	Category 2	Category 1
Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.	Repairs or replacement requiring future attention, but estimates are still advised.	No immediate action or repair is needed.

Main walls	
Repair category:	1
Notes:	Walls externally were re-rendered in 2019 and we understand that there is a ten year guarantee. This should be sought as a condition of purchase.

Windows, external doors and joinery	
Repair category:	1
Notes:	Windows are modern. Any guarantees should be sought as a condition of purchase.

External decorations	
Repair category:	
Notes:	Not applicable.

Conservatories / porches	
Repair category:	
Notes:	Not applicable.

Communal areas	
Repair category:	1
Notes:	There is deteriorating plasterwork in the rear close.

Garages and permanent outbuildings	
Repair category:	1
Notes:	From an external inspection no significant visual defects were noted.



Category 3	Category 2	Category 1
Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.	Repairs or replacement requiring future attention, but estimates are still advised.	No immediate action or repair is needed.

Outside areas and boundaries	
Repair category:	1
Notes:	Mature trees and shrubs will require regular maintenance/pruning.

Ceilings	
Repair category:	1
Notes:	Some general surface damage and undulations.

Internal walls	
Repair category:	1
Notes:	Some surface damage and undulations.

Floors including sub-floors	
Repair category:	1
Notes:	No obvious or serious defects noted.

Internal joinery and kitchen fittings	
Repair category:	1
Notes:	Internal woodwork is showing some signs of wear and tear. It cannot be confirmed that glazed internal doors have been fitted with safety glass.

Chimney breasts and fireplaces	
Repair category:	
Notes:	Not applicable.



Category 3	Category 2	Category 1
Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.	Repairs or replacement requiring future attention, but estimates are still advised.	No immediate action or repair is needed.

Internal decorations	
Repair category:	1
Notes:	Satisfactory.

Cellars	
Repair category:	
Notes:	Not applicable.

Electricity	
Repair category:	1
Notes:	<p>We understand from the vendors that the property was completely rewired in August 2023. There is an electrical certificate signed by Bryan Dodds dated 22nd August 2023. A copy of this is attached an additional document to this report.</p> <p>Any potential purchaser will require to satisfy themselves on this point.</p>

Gas	
Repair category:	1
Notes:	All gas appliances should be checked by a Gas Safe registered contractor prior to any further use.

Water, plumbing and bathroom fittings	
Repair category:	1
Notes:	The sanitary fittings are modern and appear of a serviceable type.



Category 3	Category 2	Category 1
Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.	Repairs or replacement requiring future attention, but estimates are still advised.	No immediate action or repair is needed.

Heating and hot water	
Repair category:	1
Notes:	Modern boiler. Any warranties or Gas Safety certificates should be sought as a condition of purchase.

Drainage	
Repair category:	1
Notes:	No evidence of surface problems at present.



Set out below is a summary of the condition of the property which is provided for reference only. You should refer to the comments above for detailed information.

<b>Structural movement</b>	1
<b>Dampness, rot and infestation</b>	1
Chimney stacks	
<b>Roofing including roof space</b>	1
<b>Rainwater fittings</b>	1
<b>Main walls</b>	1
<b>Windows, external doors and joinery</b>	1
External decorations	
Conservatories / porches	
<b>Communal areas</b>	1
<b>Garages and permanent outbuildings</b>	1
<b>Outside areas and boundaries</b>	1
<b>Ceilings</b>	1
<b>Internal walls</b>	1
<b>Floors including sub-floors</b>	1
<b>Internal joinery and kitchen fittings</b>	1
Chimney breasts and fireplaces	
<b>Internal decorations</b>	1
Cellars	
<b>Electricity</b>	1
<b>Gas</b>	1
<b>Water, plumbing and bathroom fittings</b>	1
<b>Heating and hot water</b>	1
<b>Drainage</b>	1

## Remember

The cost of repairs may influence the amount someone is prepared to pay for the property. We recommend that relevant estimates and reports are obtained in your own name.

## Warning

If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions where the effect can be considerable.



### 3. ACCESSIBILITY INFORMATION

#### Guidance Notes on Accessibility Information

**Three steps or fewer to a main entrance door of the property:** In flatted developments the 'main entrance' would be the flat's own entrance door, not the external door to the communal stair. The 'three steps or fewer' are counted from external ground level to the flat's entrance door. Where a lift is present, the count is based on the number of steps climbed when using the lift.

**Unrestricted parking within 25 metres:** For this purpose, 'Unrestricted parking' includes parking available by means of a parking permit. Restricted parking includes parking that is subject to parking restrictions, as indicated by the presence of solid yellow, red or white lines at the edge of the road or by a parking control sign, parking meters or other coinoperated machines.

1. Which floor(s) is the living accommodation on?	Second floor.
2. Are there three steps or fewer to a main entrance door of the property?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
3. Is there a lift to the main entrance door of the property?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
4. Are all door openings greater than 750mm?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
5. Is there a toilet on the same level as the living room and kitchen?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
6. Is there a toilet on the same level as a bedroom?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
7. Are all rooms on the same level with no internal steps or stairs?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
8. Is there unrestricted parking within 25 metres of an entrance door to the building?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO



## 4. VALUATION AND CONVEYANCER ISSUES

This section highlights information that should be checked with a solicitor or licensed conveyancer. It also gives an opinion of market value and an estimated re-instatement cost for insurance purposes.

### Matters for a solicitor or licensed conveyancer

We understand that the building is managed by MacFie and Co. This should be confirmed in writing.

At some time in the past an en-suite bathroom has been created. Our valuation advice assumes that all necessary Local Authority consents have been sought and granted. This position should be clarified prior to purchase.

The existence of these permissions is important to ensure that the subjects were altered and extended in accordance with the consents and regulations granted at that time. In the event that such consents do not exist we would wish to be advised as this fact may influence our opinion of the property, particularly as to its market value and its suitability for purchase.

An external refurbishment programme was undertaken in 2019 where the roof was overlaid and the external walls re-rendered. Any guarantees and documentation should be sought as a condition of purchase.

Where items of maintenance or repair have been identified, the purchaser should satisfy themselves as to the costs and implications of these issues prior to making an offer to purchase.

### Estimated re-instatement cost (£) for insurance purposes

370,000

Three Hundred and Seventy Thousand Pounds.

### Valuation (£) and market comments

240,000

Two Hundred and Forty Thousand Pounds.

<b>Report author:</b>	Gary Firth, MRICS
<b>Company name:</b>	Glasgow South - Allied Surveyors Scotland Ltd
<b>Address:</b>	246 Kilmarnock Road Glasgow G43 1TT
<b>Signed:</b>	Electronically Signed: 288256-208238FE-1919
<b>Date of report:</b>	28/05/2025



P A R T 2 .

# MORTGAGE VALUATION REPORT

---

Includes a market valuation of the property.







### Mortgage Valuation Report

Property:	Flat 11 19 Kirkvale Drive Newton Mearns, Glasgow G77 5HD	Client: K Marshall  Tenure: Ownership.
Date of Inspection:	28/05/2025	Reference: WH/3627/NM

*This report has been prepared as part of the seller's instructions to carry out a Single Survey on the property referred to above. The purpose of this report is to summarise the Single Survey for the purpose of advising a potential lender on the suitability of the property for mortgage purposes. The decision as to whether mortgage finance will be provided is entirely a matter for the lender. You should not rely on this report in making your decision to purchase but consider all the documents provided in the Home Report. Your attention is drawn to the additional comments elsewhere within the report which set out the extent and limitations of the service provided. This report should be read in conjunction with the Single Survey Terms and Conditions (with MVR). In accordance with RICS Valuation – Global Standards 2017 this report is for the use of the party to whom it is addressed or their named client or their nominated lender. No responsibility is accepted to any third party for the whole or any part of the reports contents. Neither the whole or any part of this report may be included in any document, circular or statement without prior approval in writing from the surveyor.*

#### 1.0 LOCATION

The subject property is located within a popular and sought after residential area. Close by is Kirkhill Primary School. Shopping and transport facilities are available within a half mile radius.

#### 2.0 DESCRIPTION 2.1 Age: 55 years old.

Second floor flat in a three storey flatted block containing six flats in total. No lift.

#### 3.0 CONSTRUCTION

External walls are of cavity brick construction rendered. The roof is flat and clad with felt or similar.

#### 4.0 ACCOMMODATION

Second floor: entrance hallway, living room, dining room, two bedrooms (one with en-suite bathroom), kitchen with breakfasting area and shower room with WC.

#### 5.0 SERVICES (No tests have been applied to any of the services)

Water:	Mains.	Electricity:	Mains.	Gas:	Mains.	Drainage:	Mains.
--------	--------	--------------	--------	------	--------	-----------	--------

Central Heating: Gas fired to water filled radiators.

#### 6.0 OUTBUILDINGS

Garage: Lock up garage number 5.

Others: None.

**7.0 GENERAL CONDITION** - A building survey has not been carried out, nor has any inspection been made of any woodwork, services or other parts of the property which were covered, unexposed or inaccessible. The report cannot therefore confirm that such parts of the property are free from defect. Failure to rectify defects, particularly involving water penetration may result in further and more serious defects arising. Where defects exist and where remedial work is necessary, prospective purchasers are advised to seek accurate estimates and costings from appropriate Contractors or Specialists before proceeding with the purchase. Generally we will not test or report on boundary walls, fences, outbuildings, radon gas or site contamination.



A second floor flat which appears to have been well maintained having regard to its age and character. The external fabric of the building was refurbished in 2019 and any guarantees and documentation should be sought as a condition of purchase.					
<b>8.0</b>	<b>ESSENTIAL REPAIR WORK</b> (as a condition of any mortgage or, to preserve the condition of the property)				
None.					
<b>8.1 Retention recommended:</b>			Nil.		
<b>9.0</b>	<b>ROADS &amp; FOOTPATHS</b>				
Made up road.					
<b>10.0</b>	<b>BUILDINGS INSURANCE (£):</b>	370,000	<b>GROSS EXTERNAL FLOOR AREA</b>	126	<b>Square metres</b>
	This figure is an opinion of an appropriate sum for which the property and substantial outbuildings should be insured against total destruction on a re-instatement basis assuming reconstruction of the property in its existing design and materials. Furnishings and fittings have not been included. No allowance has been included for inflation during the insurance period or during re-construction and no allowance has been made for VAT, other than on professional fees. Further discussions with your insurers is advised.				
<b>11.0</b>	<b>GENERAL REMARKS</b>				
At some time in the past an en-suite bathroom has been created. Our valuation advice assumes that all necessary Local Authority consents have been sought and granted. This position should be clarified prior to purchase.					
The subject property will form suitable security for normal lending purposes.					
<b>12.0</b>	<b>VALUATION</b> On the assumption of vacant possession and that the property is unaffected by any adverse planning proposals, onerous burdens, title restrictions or servitude rights. It is assumed that all necessary Local Authority consents, which may have been required, have been sought and obtained. No investigation of any contamination on, under or within the property has been made as we consider such matters to be outwith the scope of this report. All property built prior to the year 2000 may contain asbestos in one or more of its components or fittings. It is impossible to identify without a test. It is beyond the scope of this inspection to test for asbestos and future occupants should be advised that if they have any concerns then they should ask for a specialist to undertake appropriate tests.				
<b>12.1</b>	<b>Market Value in present condition (£):</b>	<b>240,000</b>	Two Hundred and Forty Thousand Pounds.		
<b>12.2</b>	<b>Market Value on completion of essential works (£):</b>				
<b>12.3</b>	<b>Suitable security for normal mortgage purposes?</b>	Yes			
<b>12.4</b>	<b>Date of Valuation:</b>	28/05/2025			
<b>Signature:</b>		Electronically Signed: 288256-208238FE-1919			
<b>Surveyor:</b>	Gary Firth	MRICS	<b>Date:</b>	28/05/2025	
<b>Glasgow South - Allied Surveyors Scotland Ltd</b>					
<b>Office:</b>	246 Kilmarnock Road Glasgow G43 1TT		Tel: 0141 636 5345 Fax: email: <a href="mailto:glasgow.south@alliedsurveyorsscotland.com">glasgow.south@alliedsurveyorsscotland.com</a>		



P A R T 3 .

# ENERGY REPORT

---

A report on the energy efficiency of the property.





# energy report

energy report on:

<b>Property address</b>	Flat 11 19 Kirkvale Drive Newton Mearns, Glasgow G77 5HD
-------------------------	---

<b>Customer</b>	K Marshall
-----------------	------------

<b>Customer address</b>	Flat 11 19 Kirkvale Drive Newton Mearns, Glasgow G77 5HD
-------------------------	---

<b>Prepared by</b>	Gary Firth, MRICS Glasgow South - Allied Surveyors Scotland Ltd
--------------------	--



# Energy Performance Certificate (EPC)

Dwellings

# Scotland

FLAT 11 , 19 KIRKVALE DRIVE, NEWTON MEARN, GLASGOW, G77 5HD

**Dwelling type:** Top-floor flat  
**Date of assessment:** 28 May 2025  
**Date of certificate:** 28 May 2025  
**Total floor area:** 108 m<sup>2</sup>  
**Primary Energy Indicator:** 288 kWh/m<sup>2</sup>/year

**Reference number:** 0150-2518-9150-2425-0405  
**Type of assessment:** RdSAP, existing dwelling  
**Approved Organisation:** Elmhurst  
**Main heating and fuel:** Boiler and radiators, mains gas


## You can use this document to:

- Compare current ratings of properties to see which are more energy efficient and environmentally friendly
- Find out how to save energy and money and also reduce CO<sub>2</sub> emissions by improving your home

Estimated energy costs for your home for 3 years*	£4,902	See your recommendations report for more information
Over 3 years you could save*	£1,950	

\* based upon the cost of energy for heating, hot water, lighting and ventilation, calculated using standard assumptions

Very energy efficient - lower running costs



Not energy efficient - higher running costs

Current	Potential
63	77


## Energy Efficiency Rating

This graph shows the current efficiency of your home, taking into account both energy efficiency and fuel costs. The higher this rating, the lower your fuel bills are likely to be.

Your current rating is **band D (63)**. The average rating for EPCs in Scotland is **band D (61)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Very environmentally friendly - lower CO<sub>2</sub> emissions



Not environmentally friendly - higher CO<sub>2</sub> emissions

Current	Potential
56	75

## Environmental Impact (CO<sub>2</sub>) Rating

This graph shows the effect of your home on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating, the less impact it has on the environment.

Your current rating is **band D (56)**. The average rating for EPCs in Scotland is **band D (59)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

## Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years
1 Flat roof or sloping ceiling insulation	£850 - £1,500	£1275.00
2 Cavity wall insulation	£500 - £1,500	£675.00

A full list of recommended improvement measures for your home, together with more information on potential cost and savings and advice to help you carry out improvements can be found in your recommendations report.

To find out more about the recommended measures and other actions you could take today to stop wasting energy and money, visit [greenerscotland.org](http://greenerscotland.org) or contact Home Energy Scotland on 0808 808 2282.

**THIS PAGE IS THE ENERGY PERFORMANCE CERTIFICATE WHICH MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED CERTIFICATE**



## Summary of the energy performance related features of this home

This table sets out the results of the survey which lists the current energy-related features of this home. Each element is assessed by the national calculation methodology; 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the condition of an element and how well it is working. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology, based on age and type of construction.

Element	Description	Energy Efficiency	Environmental
Walls	Cavity wall, as built, no insulation (assumed)	★★☆☆☆	★★☆☆☆
	Cavity wall, as built, partial insulation (assumed)	★★★☆☆	★★★☆☆
Roof	Flat, limited insulation (assumed)	★☆☆☆☆	★☆☆☆☆
Floor	(another dwelling below)	—	—
Windows	Fully double glazed	★★★★☆	★★★★☆
Main heating	Boiler and radiators, mains gas	★★★★☆	★★★★☆
Main heating controls	Programmer, room thermostat and TRVs	★★★★☆	★★★★☆
Secondary heating	None	—	—
Hot water	From main system	★★★★☆	★★★★☆
Lighting	Low energy lighting in all fixed outlets	★★★★★	★★★★★

## The energy efficiency rating of your home

Your Energy Efficiency Rating is calculated using the standard UK methodology, RdSAP. This calculates energy used for heating, hot water, lighting and ventilation and then applies fuel costs to that energy use to give an overall rating for your home. The rating is given on a scale of 1 to 100. Other than the cost of fuel for electrical appliances and for cooking, a building with a rating of 100 would cost almost nothing to run.

As we all use our homes in different ways, the energy rating is calculated using standard occupancy assumptions which may be different from the way you use it. The rating also uses national weather information to allow comparison between buildings in different parts of Scotland. However, to make information more relevant to your home, local weather data is used to calculate your energy use, CO<sub>2</sub> emissions, running costs and the savings possible from making improvements.

## The impact of your home on the environment


One of the biggest contributors to global warming is carbon dioxide. The energy we use for heating, lighting and power in our homes produces over a quarter of the UK's carbon dioxide emissions. Different fuels produce different amounts of carbon dioxide for every kilowatt hour (kWh) of energy used. The Environmental Impact Rating of your home is calculated by applying these 'carbon factors' for the fuels you use to your overall energy use.

The calculated emissions for your home are 51 kg CO<sub>2</sub>/m<sup>2</sup>/yr.

The average Scottish household produces about 6 tonnes of carbon dioxide every year. Based on this assessment, heating and lighting this home currently produces approximately 5.5 tonnes of carbon dioxide every year. Adopting recommendations in this report can reduce emissions and protect the environment. If you were to install all of these recommendations this could reduce emissions by 2.5 tonnes per year. You could reduce emissions even more by switching to renewable energy sources.







## Estimated energy costs for this home

	Current energy costs	Potential energy costs	Potential future savings
Heating	£4,107 over 3 years	£2,154 over 3 years	
Hot water	£462 over 3 years	£465 over 3 years	
Lighting	£333 over 3 years	£333 over 3 years	
<b>Totals</b>	<b>£4,902</b>	<b>£2,952</b>	

These figures show how much the average household would spend in this property for heating, lighting and hot water. This excludes energy use for running appliances such as TVs, computers and cookers, and the benefits of any electricity generated by this home (for example, from photovoltaic panels). The potential savings in energy costs show the effect of undertaking all of the recommended measures listed below.

## Recommendations for improvement

The measures below will improve the energy and environmental performance of this dwelling. The performance ratings after improvements listed below are cumulative; that is, they assume the improvements have been installed in the order that they appear in the table. Further information about the recommended measures and other simple actions to take today to save money is available from the Home Energy Scotland hotline which can be contacted on 0808 808 2282. Before carrying out work, make sure that the appropriate permissions are obtained, where necessary. This may include permission from a landlord (if you are a tenant) or the need to get a Building Warrant for certain types of work.

Recommended measures	Indicative cost	Typical saving per year	Rating after improvement	
			Energy	Environment
1 Flat roof or sloping ceiling insulation	£850 - £1,500	£425		
2 Cavity wall insulation	£500 - £1,500	£225		

### Alternative measures

There are alternative improvement measures which you could also consider for your home. It would be advisable to seek further advice and illustration of the benefits and costs of such measures.

- External insulation with cavity wall insulation

## Choosing the right improvement package

For free and impartial advice on choosing suitable measures for your property, contact the Home Energy Scotland hotline on 0808 808 2282 or go to [www.greenerscotland.org](http://www.greenerscotland.org).



## About the recommended measures to improve your home's performance rating

This section offers additional information and advice on the recommended improvement measures for your home

### 1 Flat roof or sloping ceiling insulation

Insulating a flat roof or sloping ceiling will significantly reduce heat loss through the roof; this will improve levels of comfort, reduce energy use and lower fuel bills. Insulation can be placed on top of the roof under the waterproof membrane and should particularly be considered when the waterproofing needs to be replaced. Further information about roof insulation and details of local contractors can be obtained from the National Insulation Association ([www.nationalinsulationassociation.org.uk](http://www.nationalinsulationassociation.org.uk)). Building regulations generally apply to this work so it is best to check with your local authority building standards department.

### 2 Cavity wall insulation

Cavity wall insulation, to fill the gap between the inner and outer layers of external walls with an insulating material, reduces heat loss; this will improve levels of comfort, reduce energy use and lower fuel bills. The insulation material is pumped into the gap through small holes that are drilled into the outer walls, and the holes are made good afterwards. As specialist machinery is used to fill the cavity, a professional installation company should carry out this work, and they should carry out a thorough survey before commencing work to ensure that this type of insulation is suitable for this home and its exposure. They should also provide a guarantee for the work and handle any building standards issues. Further information about cavity wall insulation and details of local installers can be obtained from the National Insulation Association ([www.nationalinsulationassociation.org.uk](http://www.nationalinsulationassociation.org.uk)).

## Low and zero carbon energy sources

Low and zero carbon (LZC) energy sources are sources of energy that release either very little or no carbon dioxide into the atmosphere when they are used. Installing these sources may help reduce energy bills as well as cutting carbon.

**LZC energy sources present:** There are none provided for this home

## Your home's heat demand

In this section, you can see how much energy you might need to heat your home and provide hot water. These are estimates showing how an average household uses energy. These estimates may not reflect your actual energy use, which could be higher or lower. You might spend more money on heating and hot water if your house is less energy efficient. The table below shows the potential benefit of having your loft and walls insulated. Visit <https://energysavingtrust.org.uk/energy-at-home> for more information.

Heat demand	Existing dwelling	Impact of loft insulation	Impact of cavity wall insulation	Impact of solid wall insulation
Space heating (kWh per year)	19,087	N/A	(2,992)	N/A
Water heating (kWh per year)	2,392			

## Addendum



## About this document

This Recommendations Report and the accompanying Energy Performance Certificate are valid for a maximum of ten years. These documents cease to be valid where superseded by a more recent assessment of the same building carried out by a member of an Approved Organisation.

The Energy Performance Certificate and this Recommendations Report for this building were produced following an energy assessment undertaken by an assessor accredited by Elmhurst ([www.elmhurstenergy.co.uk](http://www.elmhurstenergy.co.uk)), an Approved Organisation Appointed by Scottish Ministers. The certificate has been produced under the Energy Performance of Buildings (Scotland) Regulations 2008 from data lodged to the Scottish EPC register. You can verify the validity of this document by visiting [www.scottishepcregister.org.uk](http://www.scottishepcregister.org.uk) and entering the report reference number (RRN) printed at the top of this page.

Assessor's name:	Mr. Gary Firth
Assessor membership number:	EES/008223
Company name/trading name:	Allied Surveyors Scotland Ltd
Address:	246 Kilmarnock Road Shawlands Glasgow G43 1TT
Phone number:	0141 636 5345
Email address:	<a href="mailto:glasgow.south@alliedsurveyorsscotland.com">glasgow.south@alliedsurveyorsscotland.com</a>
Related party disclosure:	No related party

If you have any concerns regarding the content of this report or the service provided by your assessor you should in the first instance raise these matters with your assessor and with the Approved Organisation to which they belong. All Approved Organisations are required to publish their complaints and disciplinary procedures and details can be found online at the web address given above.

## Use of this energy performance information

Once lodged by your EPC assessor, this Energy Performance Certificate and Recommendations Report are available to view online at [www.scottishepcregister.org.uk](http://www.scottishepcregister.org.uk), with the facility to search for any single record by entering the property address. This gives everyone access to any current, valid EPC except where a property has a Green Deal Plan, in which case the report reference number (RRN) must first be provided. The energy performance data in these documents, together with other building information gathered during the assessment is held on the Scottish EPC Register and is available to authorised recipients, including organisations delivering energy efficiency and carbon reduction initiatives on behalf of the Scottish and UK governments. A range of data from all assessments undertaken in Scotland is also published periodically by the Scottish Government. Further information on these matters and on Energy Performance Certificates in general, can be found at [www.gov.scot/epc](http://www.gov.scot/epc).



## Advice and support to improve this property

There is support available, which could help you carry out some of the improvements recommended for this property on page 3 and stop wasting energy and money. For more information, visit [greener-scotland.org](https://www.greener-scotland.org) or contact Home Energy Scotland on 0808 808 2282.

Home Energy Scotland's independent and expert advisors can offer free and impartial advice on all aspects of energy efficiency, renewable energy and more.

**HOMEENERGYSCOTLAND.ORG**  
**0808 808 2282**  
FUNDED BY THE SCOTTISH GOVERNMENT





P A R T 4 .

# PROPERTY QUESTIONNAIRE

---

The owner of the property is required to complete this document which asks for information on the property such as 'Which council tax band?' etc.





## Property Questionnaire

Property Address

Flat 11

19 Kirkvale Drive

Newton Mearns, Glasgow

G77 5HD

Seller(s)

R and K Marshall

Completion date of property questionnaire

27/05/2025

Note for sellers

1.	<b>Length of ownership</b>
	<b>How long have you owned the property?</b> 12 years 3 months
2.	<b>Council tax</b>
	<b>Which Council Tax band is your property in? (Please circle)</b> <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H
3.	<b>Parking</b>
	<b>What are the arrangements for parking at your property?</b> <b>(Please tick all that apply)</b>  Garage <input checked="" type="checkbox"/> Allocated parking space <input type="checkbox"/> Driveway <input type="checkbox"/> Shared parking <input type="checkbox"/> On street <input checked="" type="checkbox"/> Resident permit <input type="checkbox"/> Metered parking <input type="checkbox"/> Other (please specify):



<b>4.</b>	<b>Conservation area</b>	
	Is your property in a designated Conservation Area (that is an area of special architectural or historical interest, the character or appearance of which it is desirable to preserve or enhance)?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> Don't know
<b>5.</b>	<b>Listed buildings</b>	
	Is your property a Listed Building, or contained within one (that is a building recognised and approved as being of special architectural or historical interest)?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
<b>6.</b>	<b>Alterations/additions/extensions</b>	
a	(i) During your time in the property, have you carried out any structural alterations, additions or extensions (for example, provision of an extra bath/shower room, toilet, or bedroom)?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
	If you have answered yes, please describe below the changes which you have made:  <i>Created a shower room and separate en-suite bathroom out of the former bathroom. This involved taking a foot or so off of the main bedroom.</i>	
	(ii) Did you obtain planning permission, building warrant, completion certificate and other consents for this work?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
	If you have answered yes, the relevant documents will be needed by the purchaser and you should give them to your solicitor as soon as possible for checking.	
	If you do not have the documents yourself, please note below who has these documents and your solicitor or estate agent will arrange to obtain them:	
b	Have you had replacement windows, doors, patio doors or double glazing installed in your property	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
	If you have answered yes, please answer the three questions below:	
	(i) Were the replacements the same shape and type as the ones you replaced?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
	(ii) Did this work involve any changes to the window or door openings?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
	(iii) Please describe the changes made to the windows doors, or patio doors (with approximate dates when the work was completed):  <i>Small changes to accord with current safety requirements.</i>  Please give any guarantees which you received for this work to your solicitor or estate agent.	
<b>7.</b>	<b>Central heating</b>	



# property questionnaire

a	Is there a central heating system in your property? (Note: a partial central heating system is one which does not heat all the main rooms of the property - the main living room, the bedroom(s), the hall and the bathroom).	[x]YES [ ]NO [ ]Partial
	If you have answered yes or partial - what kind of central heating is there? (Examples: gas-fired, solid fuel, electric storage heating, gas warm air).  <i>Gas fired</i>	
	If you have answered yes, please answer the three questions below:	
	(i) When was your central heating system or partial central heating system installed?  <i>Boiler installed 11 August 2020</i>	
	(ii) Do you have a maintenance contract for the central heating system?	[x]YES [ ]NO
	If you have answered yes, please give details of the company with which you have a maintenance contract  <i>Thomson Heating Group</i>	
	(iii) When was your maintenance agreement last renewed? (Please provide the month and year).  <i>August 2024</i>	
<b>8.</b>	<b>Energy Performance Certificate</b>	
	Does your property have an Energy Performance Certificate which is less than 10 years old?	[x]YES [ ]NO
<b>9.</b>	<b>Issues that may have affected your property</b>	
a	Has there been any storm, flood, fire or other structural damage to your property while you have owned it?	[ ]YES [x]NO
	If you have answered yes, is the damage the subject of any outstanding insurance claim?	[ ]YES [ ]NO
b	Are you aware of the existence of asbestos in your property?	[x]YES [ ]NO [ ]Don't know
	If you have answered yes, please give details:  <i>In roof of the old bin shelter in the garden</i>	
<b>10.</b>	<b>Services</b>	



# property questionnaire

a	Please tick which services are connected to your property and give details of the supplier:		
	Services	Connected	Supplier
	Gas or liquid petroleum gas	Y	edf
	Water mains or private water supply	Y	Scottish Water
	Electricity	Y	edf
	Mains drainage	Y	Scottish Water
	Telephone	Y	VOIP
	Cable TV or satellite	Y	Freesat
	Broadband	Y	Vodafone full fibre
b	Is there a septic tank system at your property?		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
	If you have answered yes, please answer the two questions below:		
	(i) Do you have appropriate consents for the discharge from your septic tank?		<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> Don't know
	(ii) Do you have a maintenance contract for your septic tank?		<input type="checkbox"/> YES <input type="checkbox"/> NO
	If you have answered yes, please give details of the company with which you have a maintenance contract:		
<b>11. Responsibilities for shared or common areas</b>			
a	<p>Are you aware of any responsibility to contribute to the cost of anything used jointly, such as the repair of a shared drive, private road, boundary, or garden area?</p> <p>If you have answered yes, please give details:</p> <p><i>Title deeds regulate responsibility for shared common areas and garden. Shared equally amongst the 6 flats in the building.</i></p>		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> Don't know
b	<p>Is there a responsibility to contribute to repair and maintenance of the roof, common stairwell or other common areas?</p> <p>If you have answered yes, please give details:</p> <p><i>Title deeds regulate responsibility for shared common areas and garden. Shared equally amongst the 6 flats in the building.</i></p>		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
c	Has there been any major repair or replacement of any part of the roof during the time you have owned the property?		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO



# property questionnaire

d	<p>Do you have the right to walk over any of your neighbours' property- for example to put out your rubbish bin or to maintain your boundaries?</p> <p>If you have answered yes, please give details:</p> <p><i>Right to walk across the gardens of the neighbouring block at 17 Kirkvale Drive for pedestrian access to lockup garage.</i></p>	[x]YES [ ]NO
e	<p>As far as you are aware, do any of your neighbours have the right to walk over your property, for example to put out their rubbish bin or to maintain their boundaries?</p> <p>If you have answered yes, please give details:</p>	[ ]YES [x]NO
f	<p>As far as you are aware, is there a public right of way across any part of your property? (public right of way is a way over which the public has a right to pass, whether or not the land is privately owned.)</p> <p>If you have answered yes, please give details:</p>	[ ]YES [x]NO
<b>12. Charges associated with your property</b>		
a	<p>Is there a factor or property manager for your property? If you have answered yes, please provide the name and address, and give details of any deposit held and approximate charges:</p> <p><i>Macfie &amp; Co, Management Services Ltd., 5 Cathkinview Road, Glasgow G42 9EA Management Fee is £41 per quarter.</i></p>	[x]YES [ ]NO
b	Is there a common buildings insurance policy?	[x]YES [ ]NO [ ]Don't know
	If you have answered yes, is the cost of the insurance included in your monthly/annual factors charges?	[x]YES [ ]NO [ ]Don't know
c	<p>Please give details of any other charges you have to pay on a regular basis for the upkeep of common areas or repair works, for example to a residents' association, or maintenance or stair fund.</p> <p><i>Residents Association, comprised of the owners of the flats. We pay £70 per month each into a common fund to cover cleaning of common areas, gardening and some small jobs that we decide to take on ourselves.</i></p>	
<b>13. Specialist works</b>		
a	As far as you are aware, has treatment of dry rot, wet rot, damp or any other specialist work ever been carried out to your property?	[ ]YES [x]NO
	If you have answered yes, please say what the repairs were for, whether you carried out the repairs (and when) or if they were done before you bought the property.	
b	As far as you are aware, has any preventative work for dry rot, wet rot, or damp ever been carried out to your property?	[ ]YES [x]NO
	If you have answered yes, please give details:	



c	If you have answered yes to 13(a) or (b), do you have any guarantees relating to this work?	[ ]YES [ ]NO
	If you have answered yes, these guarantees will be needed by the purchaser and should be given to your solicitor as soon as possible for checking. If you do not have them yourself please write below who has these documents and your solicitor or estate agent will arrange for them to be obtained. You will also need to provide a description of the work carried out. This may be shown in the original estimate. Guarantees are held by:	

<b>14. Guarantees</b>		
a	Are there any guarantees or warranties for any of the following:	
(i)	Electrical work	[ ]NO [ ]YES [x]Don't know [ ]With title deeds [ ]Lost
(ii)	Roofing	[ ]NO [x]YES [ ]Don't know [ ]With title deeds [ ]Lost
(iii)	Central heating	[ ]NO [x]YES [ ]Don't know [ ]With title deeds [ ]Lost
(iv)	National House Building Council(NHBC)	[x]NO [ ]YES [ ]Don't know [ ]With title deeds [ ]Lost
(v)	Damp course	[x]NO [ ]YES [ ]Don't know [ ]With title deeds [ ]Lost
(vi)	Any other work or installations? (for example, cavity wall insulation, underpinning, indemnity policy)	[ ]NO [ ]YES [x]Don't know [ ]With title deeds [ ]Lost
b	If you have answered 'yes' or 'with title deeds', please give details of the work or installations to which the guarantee(s) relate(s):  <i>Flat fully rewired in 2023 Roof overlaid in 2019 Central heating boiler replaced in 2020</i>	
c	Are there any outstanding claims under any of the guarantees listed above?	[ ]YES [x]NO
	If you have answered yes, please give details:	



<b>15.</b>	<b>Boundaries</b>	
	So far as you are aware, has any boundary of your property been moved in the last 10 years?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> Don't know
	If you have answered yes, please give details:	
<b>16.</b>	<b>Notices that affect your property</b>	
In the past three years have you ever received a notice:		
a	advising that the owner of a neighbouring property has made a planning application?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
b	that affects your property in some other way?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
c	that requires you to do any maintenance, repairs or improvements to your property?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
	If you have answered yes to any of a-c above, please give the notices to your solicitor or estate agent, including any notices which arrive at any time before the date of entry of the purchaser of your property.	

<b>Declaration by the seller(s)/or other authorised body or person(s) I/We confirm that the information in this form is true and correct to the best of my/our knowledge and belief.</b>	
Signature(s):	Kathleen Marshall
Capacity:	<input checked="" type="checkbox"/> Owner <input type="checkbox"/> Legally Appointed Agent for Owner
Date:	27/05/2025



19 KIRKVALE . 11 ICM18

## ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

## PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

## DETAILS OF THE CONTRACTOR

Trading Title: **OVERCOR INSTALLATIONS**  
Address: **4 CLEMENT DRIVE**Postcode: **G77 6WH** Tel No: **07796935787**

## DETAILS OF THE CLIENT

Contractor Reference Number (CRN):  
Name: **ROBERT + KATHLEEN MARSHALL**Address: **FLAT 11 19 KIRKVALE**  
**KIRKVALE DR**Postcode: **G77 5HD** Tel No:

## DETAILS OF THE INSTALLATION

Occupier:  
Address:

Postcode: Tel No:

## PART 2 : DETAILS OF THE ELECTRICAL WORK COVERED BY THIS INSTALLATION CERTIFICATE

Date works completed: **22/08/2023**

Description and extent of the installation covered by this certificate:

The installation is –

New: ( ☒ )An addition: ( ☐ )An alteration: ( ☐ )Replacement of a distribution board: ( ☐ )**FULL REWIRE OF PROPERTY.**

Where necessary, continue on a separate numbered page: Page No(s) ( )

## PART 3 : NEXT INSPECTION OF THE ELECTRICAL INSTALLATION

I/We, being the designer(s) of the electrical installation as documented in PART 4, RECOMMEND that this installation is further inspected and tested after an interval of not more than: **10** years/months\* (delete as appropriate)

## PART 4 : DECLARATION FOR THE ELECTRICAL INSTALLATION WORK (this option may be used where the design, construction, inspection &amp; testing have been the responsibility of one person)

## DESIGN, CONSTRUCTION, INSPECTION &amp; TESTING (The extent of liability of the signatories is limited to the work detailed in PART 2)

I, being the person responsible for the design, construction, inspection and testing of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the design and additionally where this certificate applies to an addition or alteration, having confirmed that the safety of the existing installation is not impaired, hereby CERTIFY that the design, construction, inspection and testing for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671: 2018, amended to **2021** (date) except for the departures, if any, detailed on attached page(s) ( **NA** ) (Regulations 120.3, 133.1.3 and 133.5).• Permitted exception applied (411.3.3): Yes/NA Risk assessment attached: ( **NA** ) Page No(s) ( **NA** )

• Where selectivity is required, details of the verification appended (536.4): ( ) Page No(s) ( )

Name (capitals): **BRYAN DODDS**Signature: **B. Dodds**Date: **22/08/2023**

## REVIEWED BY

Name (capitals):

Signature:

Date:

\* The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.



19 KIRKVALE

ICM18

## ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

## PART 4 : DECLARATION FOR THE ELECTRICAL INSTALLATION WORK (to be completed where different parties are responsible for the design, construction, inspection &amp; testing)

## DESIGN (The extent of liability of the signatories is limited to the work detailed in PART 2)

I/We being the person(s) responsible for the design of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the design and additionally where this certificate applies to an addition or alteration, having confirmed that the safety of the existing installation is not impaired, hereby CERTIFY that the design work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671: 2018, amended to 2021 (date) except for the departures, if any, detailed on attached page(s) (NA) (Regulations 120.3, 133.1.3 and 133.5).

• Permitted exception applied (411.3.3): Yes/NA Risk assessment attached: (NA) Page No(s) (NA) • Where selectivity is required, details of the verification appended (536.4): (.....) Page No(s) (.....)

## DESIGNER 1

Name (capitals): BRYAN DODDS

Signature: B. Dodds

Date: 22/08/2023

## DESIGNER 2 (where there is divided responsibility for design)

Name (capitals):

Signature:

Date:

## CONSTRUCTION (The extent of liability of the signatory is limited to the work detailed in PART 2)

I, being the person responsible for the construction of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the construction, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671: 2018, amended to 2021 (date) except for the departures, if any, detailed on attached page(s) (.....) (Regulations 120.3 and 133.5).

Name (capitals): BRYAN DODDS

Signature: B. Dodds

Date: 22/08/2023

## INSPECTION &amp; TESTING (The extent of liability of the signatories is limited to the work detailed in PART 2)

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671: 2018, amended to 2021 (date) except for the departures, if any, detailed on attached page(s) (.....) (Regulations 120.3 and 133.5).

Name (capitals): BRYAN DODDS

Signature: B. Dodds

Date: 22/08/2023

## REVIEWED BY

Name (capitals):

Signature:

Date:

## PART 5 : COMMENTS ON THE EXISTING INSTALLATION (in the case of an addition or alteration see Regulation 644.1.2)

FULL REVIEW

Where necessary, continue on a separate numbered page: Page No(s) (.....)

Where the electrical work to which this certificate relates includes the installation of a fire alarm system and/or an emergency lighting system (or a part of such systems), this electrical safety certificate should be accompanied by the particular certificate(s) for the system(s).



## ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

## PART 6 : DETAILS OF THE ORGANISATION(S) RESPONSIBLE FOR THE ELECTRICAL INSTALLATION (signatures of which are in PART 4)

DESIGN, CONSTRUCTION,  
INSPECTION & TESTINGOrganisation: POWERCORE  
Address: INSTALLATIONS  
4 CLEMENT DRIVE

Postcode: G77 6WH

Tel No:

## DESIGN

## DESIGNER 1

Organisation: POWERCORE  
Address: INSTALLATIONS  
4 CLEMENT DRIVE

Postcode: G77 6WH

Tel No:

## DESIGNER 2

Organisation:  
Address:

Postcode:

Tel No:

## CONSTRUCTION

Organisation: POWERCORE  
Address: INSTALLATIONS  
4 CLEMENT DRIVE

Postcode: G77 6WH

Tel No:

## INSPECTION &amp; TESTING

Organisation: POWERCORE  
Address: INSTALLATIONS  
4 CLEMENT DRIVE

Postcode: G77 6WH

Tel No:

Original (to the person ordering the work)

## PART 7 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

## System type and earthing arrangements

TN-C-S: (.....) TN-S: (.....) TT: (.....)

Other (state): .....

## Supply protective device

(BS (EN) BS 88 .....

Type: (MK II .....

Rated current: (63) A

## Number and type of live conductors

AC 1-phase, 2-wire: (.....) 2-phase, 3-wire: (.....)

3-phase, 3-wire: (.....) 3-phase, 4-wire: (.....)

DC 2-wire: (.....) 3-wire: (.....) Other: (.....)

Confirmation of supply polarity: (.....)

Other sources of supply (as detailed on attached schedule) Page No: (.....)

## Nature of supply parameters

Nominal line voltage,  $U^{(1)}$ : (230) VNominal line voltage to Earth,  $U_0^{(1)}$ : (230) VNominal frequency,  $f^{(1)}$ : (50) HzProspective fault current,  $I_{pf}^{(1)*}$ : (843) AExternal loop impedance,  $Z_e^{(1)*}$ : (0.27)  $\Omega$ <sup>(1)</sup> By enquiry,  
measurement, or  
by calculation

## PART 8 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS CERTIFICATE

Maximum demand (load): (56) kVA / A  
(delete as appropriate)

## Means of Earthing

Distributor's facility: (.....)

Installation earth electrode: (NA) .....

## Where an earth electrode is used insert

Type – rod(s), tape, etc: (NA) .....

Location: (NA) .....

Electrode resistance to Earth: (NA)  $\Omega$ 

## Main protective conductors

Earthing conductor:  
(material COPPER .....

Connection / continuity verified: (.....)

Main protective bonding conductors:  
(material COPPER .....

Connection / continuity verified: (.....)

## Main protective bonding connections

Water installation pipes: (.....)

Gas installation pipes: (.....)

Structural steel: (.....)

Oil installation pipes: (.....)

Lightning protection: (.....)

Other (state): .....

## Main switch / Switch-fuse / Circuit-breaker / RCD

Type: (BS (EN) 60947 .....

Location: (D.B. ....)

No. of poles: (2) .....

Current rating: (100) A .....

## Where an RCD is used as the main switch

RCD rated residual operating current,  $I_{\Delta n}$ : (NA) mA

Measured operating time: (NA) ms

Rating / setting of device: (100) A

Voltage rating: (240) V

Rated time delay: (NA) ms

\*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current,  $I_{pf}$ , and external earth fault loop impedance,  $Z_e$ , must be recorded.



## ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

## PART 9 : SCHEDULE OF ITEMS INSPECTED – continues on next page

<b>1. External condition of electrical intake equipment (visual inspection only)</b>		3.3 FELV – requirements satisfied: (.....✓)	7.15 Indication of SPD(s) continued functionality confirmed: (.....✓)
1.1 Service cable: (.....✓)	1.2 Service head: (.....✓)	3.4 Reduced low voltage – requirements satisfied: (.....✓)	7.16 Selection of protective devices(s) and base(s); correct type and rating: (.....✓)
1.3 Earthing arrangement: (.....✓)	1.4 Meter tails: (.....✓)	<b>4. Additional protection</b>	7.17 Single-pole protective devices in line conductors only: (.....✓)
1.5 Metering equipment: (.....✓)	1.6 Isolator (where present): (NA)	4.1 The presence and effectiveness of additional protection methods used, as follows:	7.18 Protection against mechanical damage where cables enter equipment: (.....✓)
<b>2. Parallel or switched alternative sources of supply</b>		a) RCDs not exceeding 30 mA operating current, as specified (.....✓)	7.19 Protection against electromagnetic effects where cables enter ferromagnetic enclosures: (.....✓)
2.1 Presence of adequate arrangements where generator to operate as a switched alternative:		b) Supplementary bonding (.....✓)	7.20 Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure: (.....✓)
a) Dedicated earthing arrangement independent of that of the public supply (NA)		<b>5. Basic protection</b> (≠ For use in controlled / supervised conditions only)	7.21 Presence of RCD six-monthly test notice, where required: (.....✓)
2.2 Presence of adequate arrangements where generator to operate in parallel with public supply: (NA)		5.1 Presence and adequacy of protective measures to provide basic protection:	7.22 Presence of diagrams, charts or schedules at or near each distribution board, where required: (.....✓)
a) Correct connection of generator in parallel (NA)		a) Insulation of live parts (.....✓)	7.23 Presence of next inspection recommendation label: (.....✓)
b) Compatibility of characteristics of means of generation (NA)		b) Barriers or enclosures (.....✓)	7.24 Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required: (NA)
c) Means to provide automatic disconnection of generator in the event of loss of public supply or voltage or frequency deviation beyond declared values (NA)		c) Obstacles ‡ (.....✓)	7.25 Presence of other required labelling: (.....✓)
d) Means to prevent connection of generator in the event of loss of public supply or voltage or frequency deviation beyond declared values (NA)		d) Placing out of reach ‡ (.....✓)	<b>8. Circuits</b>
e) Means to isolate generator from public supply (NA)		<b>6. Basic and fault protection</b>	8.1 Identification of conductors: (.....✓)
2.3 Presence of alternative / additional supply warning notices at or near:		a) SELV (.....✓)	8.2 Cables correctly supported throughout, with protection against abrasion: (.....✓)
a) The origin (NA)		b) PELV (.....✓)	8.3 Examination of cables for signs of mechanical damage during installation: (.....✓)
b) The meter position, if remote from origin (NA)		c) Double or reinforced insulation (.....✓)	8.4 Examination of installation of live parts, not damaged during erection: (.....✓)
c) The consumer unit / distribution board to which the alternative / additional sources are connected (NA)		When used, provide details on a separate numbered page: Page No (.....)	8.5 Non-sheathed cables protected by enclosure in conduit, ducting or trunking: (.....✓)
d) All points of isolation of ALL sources of supply (NA)		<b>7. Distribution equipment</b>	8.6 Suitability of containment systems (including flexible conduit): (.....✓)
<b>3. Automatic disconnection of supply</b>		7.1 Adequacy of working space / accessibility: (.....✓)	8.7 Correct temperature rating of cable insulation: (.....✓)
3.1 Presence and adequacy of protective earthing / bonding arrangements as follows:		7.2 Security of fixing: (.....✓)	8.8 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation: (.....✓)
a) Distributor's earthing arrangement or installation earth electrode arrangement (✓)		7.3 Insulation of live parts not damaged during erection: (.....✓)	8.9 Adequacy of protective devices: type and fault current rating for fault protection: (.....✓)
b) Earthing conductor and connections (.....✓)		7.4 Adequacy / security of barriers: (.....✓)	8.10 Adequacy of AFDD(s), where specified: (NA)
c) Main protective bonding conductors and connections (.....✓)		7.5 Suitability of enclosures for IP and fire ratings: (.....✓)	8.11 Presence and adequacy of circuit protective conductors: (.....✓)
d) Earthing / bonding labels at all appropriate locations (.....✓)		7.6 Enclosures not damaged during installation: (.....✓)	8.12 Coordination between conductors and overload protective devices: (.....✓)
3.2 Accessibility of:		7.7 Presence and effectiveness of obstacles: (.....✓)	
a) Earthing conductor connections (.....✓)		7.8 Presence and operation (functional) check of main switch(es): (.....✓)	
b) All protective bonding connections (.....✓)		7.9 Components are suitable according to assembly manufacturer's instructions or literature: (.....✓)	
		7.10 Operation of circuit-breakers and RCDs to prove functionality: (.....✓)	
		7.11 RCD(s) provided for fault protection, where specified: (.....✓)	
		7.12 RCD(s) provided for protection against fire, where specified: (.....✓)	
		7.13 RCD(s) provided for additional protection, where specified: (.....✓)	
		7.14 Confirmation overvoltage protection (SPDs) provided, where specified: (.....✓)	

Original (to the person ordering the work)

ICM18/4



ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

Original (to the person ordering the work)

PART 9 : SCHEDULE OF ITEMS INSPECTED

8.13 Wiring systems and cable installation methods / practices appropriate to the type and nature of installation and external influences: (.....) ✓

8.14 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage: (.....) ✓

8.15 Cables installed in walls / partitions, installed in prescribed zones: (.....) ✓

8.16 Provision of additional protection by RCDs having rated residual operating current ( $I_{\Delta n}$ ) not exceeding 30 mA:  
a) For all socket-outlets with a rated current not exceeding 32 A or less, unless exempt (.....) ✓  
b) For supplies to mobile equipment with a current rating not exceeding 32 A for use outdoors (.....) ✓  
c) For cables concealed in walls / partitions at a depth of less than 50 mm (.....) ✓  
d) For cables concealed in walls / partitions containing metal parts regardless of depth (.....) ✓  
e) For circuits supplying luminaires within domestic (household) premises only (.....) ✓

8.17 Provision of fire barriers, sealing arrangements so as to minimise the spread of fire: (.....) ✓

8.18 Band II cables segregated / separated from Band I cables: (.....) ✓

8.19 Cables segregated / separated from non-electrical services: (.....) ✓

8.20 Termination of cables at enclosures:  
a) Connections under no undue strain (.....) ✓  
b) No basic insulation of a conductor visible outside enclosure (.....) ✓  
c) Connections of live conductors adequately enclosed (.....) ✓  
d) Adequately connected at point of entry to enclosure (.....) ✓

8.21 Suitability of circuit accessories for external influences: (.....) ✓

8.22 Circuit accessories not damaged during erection: (.....) ✓

8.23 Single-pole devices for switching or protection in line conductors only: (.....) ✓

8.24 Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment: (.....) ✓

9. Isolation and switching  
9.1 Isolators:  
a) Presence and location of appropriate devices (.....) ✓  
b) Capable of being secured in the OFF position (.....) ✓  
c) Correct operation verified (functional check) (.....) ✓  
d) The installation, circuit or part thereof that will be isolated is clearly identified by location and / or durable marking (.....) ✓  
e) Warning notice posted in situations where live parts cannot be isolated by the operation of a single device (.....) ✓  
9.2 Switching off for mechanical maintenance:  
a) Presence of appropriate devices (.....) ✓  
b) Acceptable location (local or remote) (.....) ✓  
c) Capable of being secured in the OFF position (.....) ✓  
d) Correct operation verified (functional check) (.....) ✓  
e) The installation, circuit or part thereof to be disconnected clearly identified by location and / or durable marking (.....) ✓  
9.3 Emergency switching / stopping:  
a) Presence of appropriate devices (.....) ✓  
b) Readily accessible for operation where danger might occur (.....) ✓  
c) Correct operation verified (functional check) (.....) ✓  
d) The installation, circuit or part thereof to be disconnected clearly identified by location and / or durable marking (.....) ✓  
e) Firefighter's switches present, where required (.....) NA  
9.4 Functional switching:  
a) Presence of appropriate devices (.....) ✓  
b) Correct operation verified (functional check) (.....) ✓

10. Current-using equipment (permanently connected)  
10.1 Suitability of equipment in terms of IP and fire ratings: (.....) ✓  
10.2 Enclosure not damaged / deteriorated during installation so as to impair safety: (.....) ✓  
10.3 Suitability for the environment and external influences: (.....) ✓  
10.4 Security of fixing: (.....) ✓  
10.5 Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire: (.....) ✓  
10.6 Recessed luminaires (downlighters):  
a) Correct type of lamps fitted (.....) ✓  
b) Installed to minimise build-up of heat (.....) ✓  
10.7 Provision of undervoltage protection, where specified: (.....) ✓  
10.8 Provision of overload protection, where specified: (.....) ✓  
10.9 Adequacy of working space / accessibility to equipment: (.....) ✓

11. Special installations or locations  
List below any special installations or locations which are part of the installation to be verified, and confirm that the additional requirements given in the respective section of Part 7 are fulfilled:  
(.....) (.....)  
(.....) (.....)  
(.....) (.....)  
(.....) (.....)  
(.....) (.....)  
Details must be appended on a separate numbered page (see PART 10 below)

SCHEDULE OF ITEMS INSPECTED BY  
Name (capital): BRYAN DODDS  
Signature: B. Dodds Date: 22/08/23

PART 10 : SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 11 above)	Continuation sheets
Page No(s): (..... 4 & 6 .....) )	Page No(s): (..... 6 .....) )	Page No(s): (.....) )	Page No(s): (.....) )	Page No(s): (.....) )

The pages identified are an essential part of this certificate.



## ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

## PART 11 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing ..... NONE

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables		(B) Thermoplastic cables in metallic conduit		(C) Thermoplastic cables in non-metallic conduit		(D) Thermoplastic cables in metallic trunking		(E) Thermoplastic cables in non-metallic trunking		(F) Thermoplastic / SWA cables		(G) Thermosetting / SWA cables		(H) Mineral-insulated cables		(I) other - state:								
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max. disconnection time (BS 7671) (s)	Protective device				RCD Operating current, $I_{\Delta n}$ (mA)	Maximum permitted $Z_s$ for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, $Z_s$ (Ω)	RCD operating time (ms)	Test buttons	
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)
														(Line) $r_1$	(Neutral) $r_n$	(cpc) $r_2$	( $R_1 + R_2$ )	$R_2$								
	SHOWER	A	C	1	10	4	.4	61009	B	40	6	30	1.09	✓	✓	✓	.18	✓	✓	7200	500	✓	.45	23.0	✓	NA
	HOUSE SOCKETS	A	C	14	2.5	1.5	.4	61009	B	32	6	30	1.37	.39	.39	.84	.31	✓	✓	7200	500	✓	.58	28.4	✓	NA
	COOKER	A	C	2	6	2.5	.4	61009	B	32	6	30	1.37	✓	✓	✓	.12	✓	✓	7200	500	✓	.39	25.6	✓	NA
	KIT SOCKETS	A	C	6	2.5	1.5	.4	61009	B	32	6	30	1.37	.19	.19	.62	.17	✓	✓	7200	500	✓	.44	25.8	✓	NA
	STUDIO SOCKETS	A	C	8	4	1.5	.4	61009	B	20	6	30	2.19	✓	✓	✓	.34	✓	✓	7200	500	✓	.61	27.2	✓	NA
	TWEL RAIL	A	C	1	2.5	1.5	.4	61009	B	16	6	30	2.73	✓	✓	✓	.26	✓	✓	7200	500	✓	.53	26.4	✓	NA
	DB CUP SOCKETS	A	C	3	2.5	1.5	.4	61009	B	16	6	30	2.73	✓	✓	✓	.14	✓	✓	7200	500	✓	.41	27.6	✓	NA
	BOILER	A	C	1	1.5	1	.4	61009	B	6	6	30	7.28	✓	✓	✓	.09	✓	✓	7200	500	✓	.36	24.2	✓	NA
	LTS	A	C	5	1.5	1	.4	61009	B	6	6	30	7.28	✓	✓	✓	1.14	✓	✓	7200	500	✓	1.41	28.4	✓	NA
	LTS	A	C	3	1.5	1	.4	61009	B	6	6	30	7.28	✓	✓	✓	1.21	✓	✓	7200	500	✓	1.48	24.8	✓	NA

## DISTRIBUTION BOARD (DB) DETAILS

DB designation: HOUSELocation of DB: HALL CUPBOARD

## TESTED BY

Name (capital): BRYAN DODDSignature: B. DoddPosition: 22/08/2023Date: 22/08/2023

## TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (.....) Nominal voltage: (.....) V No. of phases: (.....)

Overcurrent protection device for the distribution circuit Type: (BS EN ..... ) Rating: (.....) A

Associated RCD (if any) Type: (BS EN ..... ) No. of poles: (.....)  $I_{\Delta n}$  (.....) mA Operating time (.....) ms

Characteristics at this DB Confirmation of supply polarity: (.....) Phase sequence confirmed (where appropriate): (.....)  $Z_s$  (.....)  $\Omega$   $I_{pf}$  (.....) kA

## TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: 10125423 Continuity: (.....)

Insulation resistance: (.....) Earth fault loop impedance: (.....)

Earth electrode resistance: (.....) RCD: (.....)