# **Energy performance certificate (EPC)**

Unit 1 Masonry Trading Estate 135a Bloxwich Road WALSALL WS2 8BS Energy rating

Valid until: 18 November 2035

Certificate number: 0046-4043-1172-1131-5717

Property type Storage or Distribution


Total floor area 1,202 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

repende eminer to ane one could have raunge.

If typical of the existing stock

If newly built

12 A

47 B

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	7.07
Primary energy use (kWh/m2 per year)	75

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the  $\frac{\text{recommendation report}}{(\text{/energy-certificate/0904-4478-4232-6834-4049})}$ .

### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Focus Green
Telephone	03303203494
Email	james@focusgreen.co.uk

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Sterling Accreditation Ltd
Assessor's ID	STER500240
Telephone	0161 727 4303
Email	info@sterlingaccreditation.com

#### About this assessment

Focus Green
35 Oakhall Drive, Dorridge, West Midlands, B93 8UA
The assessor is not related to the owner of the property.
12 November 2025
19 November 2025