Energy performance certificate (EPC) recommendation report

114 Bentley Road Bentley DONCASTER DN5 9QW Report number 1786-6810-5366-7649-9266

Valid until

17 August 2032

Energy rating and EPC

This property's current energy rating is C.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Make these changes to improve the property's energy efficiency.

Recommended improvements are grouped by the estimated time it would take for the change to pay for itself. The assessor may also make additional recommendations.

Each recommendation is marked as low, medium or high. This shows the potential impact of the change on reducing the property's carbon emissions.

Changes that pay for themselves within 3 years

Recommendation	Potential impact
Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	High
Changes that pay for themselves in more than 7 years	

Recommendation	Potential impact
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	Medium
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium
Consider installing an air source heat pump.	High
Some floors are poorly insulated - introduce and/or improve insulation. Add insulation to the exposed surfaces of floors adjacent to underground, unheated spaces or exterior.	Medium

Property and report details

Report issued on	18 August 2022
Total useful floor area	77 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	CLG, iSBEM, v6.1.b, SBEM, v6.1.b.0

Assessor's details

Assessor's name	John Mann
Telephone	07789740450
Email	homeinspector01@yahoo.co.uk
Employer's name	<insert employer="" name="" trading=""></insert>
Employer's address	<insert address="" employer="" trading=""></insert>
Assessor ID	STRO002093
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Stroma Certification Ltd