

Energy performance certificate (EPC)

UNIT 21 Unit 21-24 Jubilee Industrial Estate ASHINGTON NE63 8UB	Energy rating D	Valid until: 6 May 2030
		Certificate number: 0050-1258-0390-5441-4050

Property type	B2 to B7 General Industrial and Special Industrial Groups
Total floor area	233 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built	26 B
If typical of the existing stock	77 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	96.75
Primary energy use (kWh/m ² per year)	559

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/2155-4045-0509-0401-4801\)](/energy-certificate/2155-4045-0509-0401-4801).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Lloyd Holmes
Telephone	0191 2849999
Email	alan@ahbss.org.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019076
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Lloyd Holmes
Employer address	C/O , 43 Lovaine Avenue Whitley Bay Tyne and Wear North Tyneside NE25 8RW
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	4 May 2020
Date of certificate	7 May 2020