

Energy performance certificate (EPC)

20 Field Lane
KESSINGLAND
NR33 7QB

Energy rating

E

Valid until:

17 August 2035

Certificate number:

7724-2907-1444-8759-4815

Property type

Offices and Workshop Businesses

Total floor area


498 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

20 A

If typical of the existing stock

79 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	36.97
Primary energy use (kWh/m ² per year)	223

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/7372-9931-2132-4802-4884\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	John Denby
Telephone	07434 283713
Email	john.denby@ecea.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/028113
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	East Coast Energy Assessors
Employer address	31 Manor Park Road, Lowestoft, NR32 5HL
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	13 August 2025
Date of certificate	18 August 2025