# **Energy performance certificate (EPC)**

GRANGERS YARD LAND & BUILDINGS LYING TO THE WEST OF BURY ROAD SHILLINGTON HITCHIN SG5 3NY

Energy rating

Valid until: 5 September 2031

Certificate number:

4931-1658-7995-3469-0770

Property type

B1 Offices and Workshop businesses

Total floor area


147 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built	30 B
If typical of the existing stock	88 D

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	42.38
Primary energy use (kWh/m2 per year)	292

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/3179-0821-0327-8626-6451).

### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Joe Panther
Telephone	0800 170 1201
Email	admin@easyepc.org

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Elmhurst Energy Systems Ltd
EES/024201
01455 883 250
enquiries@elmhurstenergy.co.uk
EASY EPC
12 Albion Street Brighton BN2 9NE
The assessor is not related to the owner of the property.
31 August 2021
6 September 2021