Energy performance certificate (EPC)					
FLAT 4 9-11 Endless Street SALISBURY SP1 1DL	Energy rating	Valid until: 11 November 2031 Certificate number: 6609-2337-8570-1448-1206			
Property type	Top-floor flat				
Total floor area		72 square metres			

Rules on letting this property


Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

<u>See how to improve this property's energy</u> performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	re Description	
Walls	Average thermal transmittance 0.17 W/m²K	Very good
Roof	Average thermal transmittance 0.1 W/m ² K	Very good
Windows	Full secondary glazing	Good
Main heating	Room heaters, electric	Average
Main heating control	Programmer and appliance thermostats	Good
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	(other premises below)	N/A
Secondary heating	None	N/A
Air tightness	(not tested)	N/A

Primary energy use

The primary energy use for this property per year is 215 kilowatt hours per square metre (kWh/m2).

Environmental impact of this property		This property's potential production	2.6 tonnes of CO2
One of the biggest contributors to climate change is carbon dioxide (CO2). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO2 emissions.		By making the <u>recommended changes</u> , you could reduce this property's CO2 emissions by 0.0 tonnes per year. This will help to protect the environment.	
An average household produces	6 tonnes of CO2	Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.	
This property produces	2.6 tonnes of CO2		

How to improve this property's energy performance

The assessor did not make any recommendations for this property.

<u>Simple Energy Advice has guidance on improving a property's energy use.</u> (<u>https://www.simpleenergyadvice.org.uk/</u>)

Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings Estimated energy used to heat this property Space heating 2890 kWh per year Estimated yearly energy cost for this property £651 Potential saving £0 Potential energy savings by installing insulation

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in <u>how to improve this</u> <u>property's energy performance</u>.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u> (<u>https://www.simpleenergyadvice.org.uk/</u>).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

insulation The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive <u>Renewable Heat</u> <u>Incentive payments (https://www.gov.uk/domestic-</u> <u>renewable-heat-incentive</u>). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name Telephone Email Andrew Ling 01264781894 andrewjling@hotmail.com

Accreditation scheme contact details

Accreditation scheme Assessor ID Telephone Email

Assessment details

Assessor's declaration Date of assessment Date of certificate

Type of assessment

Stroma Certification Ltd STRO000469 0330 124 9660 certification@stroma.com

No related party 8 March 2021 12 November 2021 <u>SAP</u>