Energy performance certificate (EPC)

65 Kirkby Road Hemsworth PONTEFRACT WF9 4AS Energy rating

Valid until: 21 July 2033

Certificate number:

8190-7891-1317-0000-2726

Property type

Retail/Financial and Professional Services

Total floor area


46 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	6 A
If typical of the existing stock	25 A

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	30.95
Primary energy use (kWh/m2 per year)	326

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation}}{\text{report (/energy-certificate/7060-2592-5283-1445-9253)}}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Michael Townsend
Telephone	01904 799941
Email	mtownsend1972@outlook.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Elmhurst Energy Systems Ltd
EES/008160
01455 883 250
enquiries@elmhurstenergy.co.uk
_

The assessor is not related to the owner of the property.
21 July 2023
22 July 2023