

Energy performance certificate (EPC)

Unit 9d
Clay Flatts Industrial Estate
Buddle Road
Workington
CA14 3YD

Energy rating

C

Valid until:

7 April 2034

Certificate
number:

0083-8370-1912-4887-
5610

Property type

Offices and Workshop Businesses

Total floor area

47 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built



If typical of the existing stock



Breakdown of this property's energy performance

| | |
|--|---------------------------------|
| Main heating fuel | Grid Supplied Electricity |
| Building environment | Heating and Natural Ventilation |
| Assessment level | 3 |
| Building emission rate (kgCO2/m2 per year) | 5.77 |
| Primary energy use (kWh/m2 per year) | 62 |

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/6836-9412-3720-5597-1309\)](/energy-certificate/6836-9412-3720-5597-1309).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

| | |
|-----------------|--|
| Assessor's name | James McSorley |
| Telephone | 07812 345 153 |
| Email | jms@energy-rating.org |

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

| | |
|----------------------|--|
| Accreditation scheme | Elmhurst Energy Systems Ltd |
| Assessor's ID | EES/016017 |
| Telephone | 01455 883 250 |
| Email | enquiries@elmhurstenergy.co.uk |

About this assessment

| | |
|------------------------|---|
| Employer | Energy Rating Services Ltd |
| Employer address | |
| Assessor's declaration | The assessor is not related to the owner of the property. |
| Date of assessment | 5 April 2024 |
| Date of certificate | 8 April 2024 |
