Energy performance certificate (EPC)

Unit 21H Solway Trading Estate MARYPORT CA15 8NF Energy rating

Valid until: 11 December 2032

Certificate number: 0068-0732-4464-9986-3305

Property type

Storage or Distribution

Total floor area

41 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is C.

Under 0 A+

Net zero CO2

0-25 A

26-50 B

51-75 C 72 | C

76-100 D

101-125 E

126-150 F

Over 150 G

Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

21 | A

If typical of the existing stock

82 | D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	7.22
Primary energy use (kWh/m2 per year)	77

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\underline{\text{recommendation}}$ $\underline{\text{report (/energy-certificate/5711-2957-4011-0567-8356)}}$.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name James McSorley Telephone 07812345153

Email jms@energy-rating.org

Accreditation scheme contact details

Accreditation scheme Stroma Certification Ltd

Assessor ID STRO000011 Telephone 0330 124 9660

Email <u>certification@stroma.com</u>

Assessment details

Employer EnergyRating Services Ltd

Employer address

Assessor's declaration The assessor is not related to the owner of the

property.

Date of assessment 7 December 2022

Date of certificate 12 December 2022