Energy performance certificate (EPC)

Unit 4 Keys Business Village Keys Park Road CANNOCK WS12 2HA Energy rating

Valid until: 11 October 2027

Certificate number:

9964-3010-0136-0290-2495

Property type

B1 Offices and Workshop businesses

Total floor area


228 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

27 B

If typical of the existing stock

80 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	42.23
Primary energy use (kWh/m2 per year)	245

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/0290-0243-6169-4190-4096).

Who to contact about this certificate

Contacting the assessor

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Scott Lamont
Telephone	01244 681221
Email	scott@brymauestates.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008295
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment	
Employer	C6 Ltd
Employer address	Red Hil House, Hope Street, Saltney, Chester, CH4 8BU
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	12 October 2017

12 October 2017