

# Energy performance certificate (EPC)

Salvation Army Walker Road Cardiff CF24 2EG	Energy rating	Valid until: <b>26 June 2034</b>
	<b>F</b>	Certificate number: <b>7618-7371-4777-7069-0814</b>

Property type	Non-residential Institutions: Community/Day Centre
Total floor area	632 square metres

## Rules on letting this property

**!** You may not be able to let this property.

This property has an energy rating of F. The landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.


Properties can be let if they have an energy rating from A+ to E. The [recommendation report](#) sets out changes you can make to improve the property's rating.

## Energy rating and score

Properties get a rating from A+ (best) to G (worst) and a score.

This property's energy rating is F.

The better the rating and score, the lower your property's carbon emissions are likely to be.



## How this property compares to others

Properties similar to this one could have ratings:

If newly built

42 B

If typical of the existing stock

196 G

## Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	67.67
Primary energy use (kWh/m <sup>2</sup> per year)	423

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/8054-4831-4443-3585-6466\)](#).

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Joel Davies
Telephone	07503 545 959
Email	<a href="mailto:info@energy-consult.co.uk">info@energy-consult.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019606
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### About this assessment

Employer	Green Energy Consult Limited
Employer address	Douglas House Caerphilly CF83 1HU
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	19 June 2024
Date of certificate	27 June 2024