

Serial No.

7008215

LANDLORD/HOME OWNER GAS SAFETY RECORD



This form allows the recording of the results of the required checks as defined by the Gas Safety (Installation and Use) Regulations. Chimney systems were inspected visually and checked for satisfactory evacuation of products of combustion, a detailed internal inspection of the chimney system has not been carried out. The information recorded on this form does not confirm that the installation was installed by a person licensed by Gas Safe Register nor that the installation complies with any relevant Building Regulations.

Registered Business Details

Reg No: 533271
 Company: CONRAD ROAD HEATING LTD
 Address: 29 BARNOR RD - SOLENT
W. FINEER
 Postcode: PO10 9W
 Tel No: 01203 602015

Job Address

Name: _____
 Address: 6 AMENIA COURT
SHILOH RD. E. WIMBORNE
W. FINEER
 Postcode: _____
 Tel No: _____

Landlord Details (or where appropriate their agent)

Name: _____
 Address: APRONS OF FIRE
1 NEW AVENUE E. WIMBORNE
W. FINEER
 Postcode: PO10 9W Tel No: 01203 671941
 No. of appliances checked TWO

APPLIANCE DETAILS

	Location	Appliance Type	Make	Model	Chimney/Flue Type (OF/RS/FL)	Landlord's Appliance (Yes/No/NA)	Appliance Checked (Yes/No)
1	KITCHEN	BOILER	WIMBORNE	GREENSTAR 24i Junior	RS	KS	KS
2	KITCHEN	HUB	COX		FL	KS	KS
3							
4							

INSPECTION / SAFETY CHECKS

Ventilation Satisfactory (Yes/No)	Operating Pressure or Heat Input (mbar/kW)	Safety Device(s) Correct Operation (Yes/No/NA)	Visual Condition Satisfactory (Yes/No/NA)	Chimney/Flue Performance (Pass/Fail/NA)	Final (if Applicable)	Appliance Serviced (Yes/No)	Appliance Safe (Yes/No)
KS	22kwh	KS	KS	NA	0.0006	KS	KS
KS	/	KS	NA	NA	/	NO	KS

SUMMARY

Correctly Installed (Yes/No/NA)	In Date (Yes/No/NA)	Test Satisfactory (Yes/No/NA)
/	/	/
/	/	/

AUDIBLE CO DETECTOR

Emergency Control Valve Satisfactory	Main Protective Bonding Satisfactory (Visual)	Gas Installation Pipework Satisfactory (Visual)	Gas Tightness Test Satisfactory
KS	KS	KS	KS
NO	NO	NO	NO

DEFECT(S) IDENTIFIED

Warning Notice Serial No. (3)*
NO VISIBLE EX BONDING ON GAS SUPPLY PIPING

REMEDIAL ACTION TAKEN

None

OTHER OBSERVATIONS / COMMENTS

Issued by:

Print Name: CONRAD ROAD Signed: _____
 Licence No: 4385446 Issue Date: 29th JAN 2019
 Received by: _____ No one present at the time of visit
 Signed: _____ Print Name: _____

NEXT SAFETY CHECK DUE BEFORE

29/01/20