

ELECTRICAL INSTALLATION CONDITION REPORT

(Requirements for Electrical Installations – BS 7671
IEE Wiring Regulations)

DETAILS OF THE CLIENT

Name: Campus Cribs

Address:

PURPOSE FOR WHICH THIS REPORT IS REQUIRED

This report must be used only for reporting on the condition of an existing installation.

Electrical Condition Report

Date(s): 23/09/20

DETAILS OF THE INSTALLATION

Occupier:

Address: 206 St Georges Road, Bolton

Description of Premises:

Domestic Commercial Industrial Other

Estimated age of the Electrical Installation:

5

Years

Evidence of Alterations or Additions:

No

If "yes" estimated age:

Years

Date of previous Inspection:

Unknown

Electrical Installation Certificate No: or previous
Periodic Inspection report No:

Unknown

Records of installation available.

Records held by:

EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING

Extent of the Electrical installation covered by this report:

All electrical accessories and control equipment

Agreed Limitations (including the reasons), if any, on the inspection and testing

Operational limitations including the reasons (see page No.)

This inspection has been carried out in accordance with BS 7671:2008, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in roof spaces and generally within the fabric of the building or under ground have not been inspected.

SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

All accessories and control equipment in good condition and good working order.

If necessary, continue on additional page(s)? No Yes Specify page Overall assessment of the
installation:

SATISFACTORY

(Delete as appropriate)

An "Unsatisfactory" assessment indicates that dangerous and/or potentially dangerous conditions have been identified.

SCHEDULES AND ADDITIONAL PAGES

Schedule of items inspected Page No. 4,5,6,7

Additional pages, including additional source(s) data sheets: Page No(s):

Schedule of Circuit Details for the installation: Page No(s): 8

Schedule of Test Results for the installation: Page No(s):

The pages identified here form an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

NEXT INSPECTION

We recommend that this installation is further inspected and tested after an interval of not more than 5 Years

Provided that any items which have been attributed a Recommendation Code C1 and C2 (require urgent attention) are remedied without delay and as soon as possible respectively. Items which have been attributed a Recommendation Code C3 should be actioned as soon as practicable (see F).

DETAILS OF ELECTRICAL CONTRACTOR

Trading Title: K.M ELECTRICAL SERVICES

Telephone number: 7850221036

Address: BOLTON

Fax number:

Postcode: BL4 0DT

Registration number

Branch number:

(if applicable)

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Tick boxes and enter details, as appropriate

System Type(s)	Number and Type of Live Conductors			Nature of Supply Parameters			Characteristics of Primary supply Overcurrent Protective Device(s)		
	AC	DC		Nominal Voltage U (1)			BS(EN)		
TN-S <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			230		V	1361		
TN-C-S	1-phase (2 wire) <input checked="" type="checkbox"/>	1-phase (3 wire)		Nominal frequency f (1)	50	Hz	Type	BS3161 Fuse HBC - Type 2	
TN-C	2-phase (3 wire)	3-phase (3 wire)		Prospective fault current (2/3)	0.36	kA	Rated current	100	A
TT	3-phase (4 wire)	2 pole		External earth fault loop impedance Ze (3/4)	0.64	Ω	Short-circuit capacity		kA
IT	3 pole	other		Number of supplies		1) by enquiry	(3) where more than one supply, the higher or highest values		
	Other (Please state)			NOTES:		2) by enquiry or by measurement	4) by measurement		

PARTICULARS OF INSTALLATION AT THE ORIGIN

Tick boxes and enter details, as appropriate

Means of earthing		Details Installation Earth Electrode (where applicable)			
Distributor's facility <input checked="" type="checkbox"/>		Type: (eg rod(s), tape etc)		Location:	Maximum Demand: kVA/Amps
Installation earth electrode		Electrode resistance, RA: Ω		Method of measurement:	Protective measures against electric Shock:
# Main Switch or Circuit Breaker	Earthing and Protective Bonding Conductors				
Type (BS(EN))	60947-3 Isolator	Voltage Rating	230	V	Earthing conductor
No of Poles	2	Rated current I _n	100	A	Conductor material
Supply conductors: material	Copper	RCD operating current I Δ n		mA	Conductor csa
Supply conductors: csa	25 mm ²	RCD operating time (at I Δ n)		ms	Continuity check
					Bonding of extraneous-conductive-parts (✓)
					Gas service
					Lighting
					Water service
					Structural steel
					Oil service
					Other service(s)

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
1.0 Condition/adequacy of distributor's supply intake equipment			
1.1	Service cable	ACCEPTABLE	
1.2	Service cut-out/fuse(s)	ACCEPTABLE	
1.3	Meter tails - distributor	ACCEPTABLE	
1.4	Meter tails - consume	ACCEPTABLE	
1.5	Metering equipment	ACCEPTABLE	
1.6	Means of main isolation (where present)	ACCEPTABLE	
2.0 Presence of adequate arrangements for parallel or switched alternative sources			
		N/A	
3.0 Automatic disconnection of supply			
3.1 Main earthing and bonding arrangements			
	* Presence and condition of distributor's earthing arrangement	ACCEPTABLE	
	* Presence and condition of earth electrode arrangement	N/A	
	* Adequacy of earthing conductor size	ACCEPTABLE	
	* Adequacy of earthing conductor connections	ACCEPTABLE	
	* Accessibility of earthing conductor connections	LIMITED	
	* Adequacy of main protective bonding conductor size(s)	ACCEPTABLE	
	* Adequacy of main protective bonding conductor connections	ACCEPTABLE	
	* Accessibility of main protective bonding connections	LIMITED	
	* Provision of earthing/bonding labels at all appropriate locations	LIMITED	
3.2 FELV			
	* Source providing at least simple separation	N/A	
	* Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	N/A	
3.3 Reduced low voltage			
	* Adequacy of source	N/A	
	* Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	N/A	
4.0 Other methods of protection (where the methods of protection listed below are employed, details should be provided on separate sheets)			
4.1	Double insulation	N/A	
4.2	Reinforced insulation	N/A	
4.3	Use of obstacles	N/A	
4.4	Placing out of reach	N/A	
4.5	Non-conducting location	N/A	
4.6	Earth-free local equipotential bonding	N/A	
4.7	Electrical separation for more than one item of equipment	N/A	
5.0 Distribution equipment			
5.1	Adequacy of working space/accessibility of equipment	ACCEPTABLE	
5.2	Security of fixing	ACCEPTABLE	
5.3	Condition of insulation of live parts	ACCEPTABLE	
5.4	Adequacy/security of barriers	ACCEPTABLE	
5.5	Condition of enclosure(s) in terms of IP rating	LIMITED	
5.6	Condition of enclosure(s) in terms of fire rating	LIMITED	
5.7	Enclosure not damaged/deteriorated so as to impair safety	ACCEPTABLE	
5.8	Presence of main switch(es), linked where required	ACCEPTABLE	

5.9	Operation of main switch(es) (functional check)	ACCEPTABLE	
5.10	Correct identification of circuit protective devices	ACCEPTABLE	
5.11	Adequacy of protective devices for prospective fault current	ACCEPTABLE	
5.12	RCD(s) provided for fault protection – includes RCBOs	ACCEPTABLE	
5.13	RCD(s) provided for additional protection – includes RCBOs	ACCEPTABLE	
5.14	RCD(s) provided for protection against fire – includes RCBOs	ACCEPTABLE	
5.15	Manual operation of circuit-breakers and RCDs to prove disconnection	ACCEPTABLE	
5.16	Presence of RCD retest notice at or near equipment where required	ACCEPTABLE	
5.17	Presence of diagrams, charts or schedules at or near equipment where required	LIMITED	
5.18	Presence of non-standard (mixed) cable colour warning notice at or near equipment where required	N/A	
5.19	Presence of alternative supply arrangement warning notice(s) at or near equipment where required	N/A	
5.20	Presence of replacement next inspection recommendation label	LIMITED	
5.21	Presence of other required labelling (specify)	ACCEPTABLE	
5.22	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	ACCEPTABLE	
5.23	Protection against mechanical damage where cables enter equipment	ACCEPTABLE	
5.24	Protection against electromagnetic effects where cables enter metallic enclosures	ACCEPTABLE	
6.0 Distribution/final circuits			
6.1	Identification of conductors	ACCEPTABLE	
6.2	Cables correctly supported throughout their length	LIMITED	
6.3	Condition of insulation of live parts	ACCEPTABLE	
6.4	Non-sheathed cables protected by enclosure in conduit, duct or trunking	LIMITED	
6.5	Suitability of containment systems for continued use (including flexible conduit)	ACCEPTABLE	
6.6	Cables correctly terminated in enclosures (indicate extent of sampling in Section D of report)	LIMITED	
6.7	Examination of cables for signs of unacceptable thermal and mechanical damage/deterioration	ACCEPTABLE	
6.8	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	ACCEPTABLE	
6.9	Adequacy of protective devices; type and rated current for fault protection	ACCEPTABLE	
6.10	Presence and adequacy of circuit protective conductors	ACCEPTABLE	
6.11	Co-ordination between conductors and overload protective devices	ACCEPTABLE	
6.12	Cable installation methods/practices appropriate to the type and nature of installation and external influences	ACCEPTABLE	
6.13	Cables where exposed to direct sunlight, of a suitable type	N/A	
6.14	Concealed cables installed in prescribed zones (see extent and limitations)	LIMITED	
6.15	Concealed cables incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage caused by nails, screws and the like where not in prescribed zones or not protected by 30 mA RCD (see extent and limitations)	LIMITED	
6.16	Provision of additional protection by 30 mA RCD for cables concealed in walls or partitions	ACCEPTABLE	
6.17	Provision of additional protection by 30 mA RCD	ACCEPTABLE	
	* Where reasonably likely to be used to supply mobile equipment for use outdoors	ACCEPTABLE	
	* For all socket-outlets of rating 20 A or less provided for use by ordinary persons	ACCEPTABLE	
6.18	Provision of fire barriers, sealing arrangements and protection against thermal effects	ACCEPTABLE	
6.19	Band II cables segregated/separated from Band I cables	N/A	
6.20	Cables segregated/separated from non-electrical services	ACCEPTABLE	
6.21	Termination of cables at enclosures (identify numbers and locations of items inspected in Section D)	ACCEPTABLE	
	* Connections under no undue strain	ACCEPTABLE	
	No basic insulation of a conductor visible outside an enclosure	ACCEPTABLE	
	Connections of live conductors adequately enclosed	ACCEPTABLE	
	Adequacy of connection at point of entry to enclosure (gland, bush or similar)	ACCEPTABLE	
6.22	General condition of wiring systems	ACCEPTABLE	
6.23	Temperature rating of cable insulation	ACCEPTABLE	
6.24	Condition of accessories including socket-outlets, switches and joint boxes	ACCEPTABLE	
6.25	Suitability of accessories for external influences	ACCEPTABLE	
7.0 Isolation and switching			

7.1 Isolations		
* presence and condition of appropriate devices	ACCEPTABLE	
* acceptable location	ACCEPTABLE	
* capable of being secured in the OFF position	ACCEPTABLE	
* correct operation verified	ACCEPTABLE	
* clearly identified by position and/or durable marking(s)	ACCEPTABLE	
* Warning label posted in situations where live parts cannot be isolated by the operation of a single device	LIMITED	
7.2 Switching off for mechanical maintenance		
* presence and condition of appropriate devices	ACCEPTABLE	
* acceptable location	ACCEPTABLE	
* capable of being secured in the OFF position	ACCEPTABLE	
* correct operation verified	ACCEPTABLE	
* clearly identified by position and/or durable marking(s)	ACCEPTABLE	
7.3 Emergency switching/stopping		
* presence and condition of appropriate devices	N/A	
* readily accessible for operation where danger might occur	N/A	
* correct operation verified	N/A	
* clearly identified by position and/or durable marking(s)	N/A	
7.4 Functional switching		
* presence and condition of appropriate devices		
* correct operation verified		
8.0 Current-using equipment (permanently connected)		
8.1 Condition of equipment in terms of IP rating	ACCEPTABLE	
8.2 Equipment does not constitute a fire hazard	ACCEPTABLE	
8.3 Enclosure not damaged/deteriorated so as to impair safety	ACCEPTABLE	
8.4 Suitability for the environment and external influences	ACCEPTABLE	
8.5 Security of fixing	ACCEPTABLE	
8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (indicate extent of sampling in Section D of report)	ACCEPTABLE	
8.7 Recessed luminaires (e.g. downlighters)		
* correct type of lamps fitted	ACCEPTABLE	
* installed to minimise build-up of heat by use of "fire rated" fittings,insulation displacement box or similar	ACCEPTABLE	
* no signs of overheating to surrounding building fabric	ACCEPTABLE	
* no signs of overheating to conductors/terminations	ACCEPTABLE	
9.0 Location(s) containing a bath or shower		
9.1 Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA	ACCEPTABLE	
9.2 Where used as a protective measure, requirements for SELV or PELV are met	N/A	
9.3 Shaver sockets comply with BS EN 61558-2-5 or BS 3535	ACCEPTABLE	
9.4 Presence of supplementary bonding conductors unless not required by BS 7671: 2018	N/A	
9.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
9.6 Suitability of equipment for external influences for installed location in terms of IP rating	ACCEPTABLE	
9.7 Suitability of equipment for installation in a particular zone	ACCEPTABLE	
9.8 Suitability of current-using equipment for a particular position within the location	ACCEPTABLE	
10.0 Other Special installations or locations		
List special locations present, if any. List the results of particular inspections applied.– a separate page is required for each location	N/A	

* **All Boxes must be completed**

Unacceptable condition state **C1** or **C2**

Outcome

✓ Indicates **Acceptable condition**

Improvement recommended state **C3**

Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.

LIM indicates a **limitation**

Further investigation required state **F/I**
(to determine whether danger or potential danger exists)

N/A indicates **Not applicable**

SCHEDULE OF ITEMS TESTED

✓	External earth loop impedance, Ze	✓	Basic protection against direct contact by barrier or enclosure provided during erection
N/A	Installation earth electrode resistance, Ra	✓	Insulation of non-conducting floors or walls
✓	Continuity of protective conductors	✓	Polarity
✓	Continuity of ring circuit conductors	✓	Earth fault loop impedance Zs
✓	Insulation resistance between live conductors	N/A	Verification of phase sequence
✓	Insulation resistance between live conductors and earth	✓	Operation of residual current devices
✓	Protection by separation of circuits	✓	Functional testing of assemblies
		N/A	Verification of voltage drop

TEST INSTRUMENTS USED

Earth fault loop impedance	TELSAR 0100 MULTIMETER
Insulation resistance	TELSAR 0100 MULTIMETER
Continuity	TELSAR 0100 MULTIMETER
RCD	TELSAR 0100 MULTIMETER
Other	N/A
Other	N/A

NOTES FOR RECIPIENT

THIS CERTIFICATE IS A VALUABLE DOCUMENT AND SHOULD BE RETAINED FOR FUTURE REFERENCE

This Electrical Installation Condition Report form is intended for the reporting on the condition of an existing electrical installation.

You should have received an original Certificate and the contractor should have retained a duplicate. If you were the person ordering this report, but not the owner of the installation, you should pass this Report, or a full copy of it, immediately to the user.

The original Report is to be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Report will provide the new owner with the details of the condition of the electrical installation at the time the Report was issued.

The 'Extent and Limitations' box should fully identify the extent of the installation covered by this Report and any limitations on the inspection and tests. The contractor should have agreed these aspects with you and any interested parties (Licensing Authority, Insurance Company, Building Society etc) before the inspection was carried out.

The Report will usually contain a list of recommended actions necessary to bring the installation up to the current standard. **For items classified as 'requires urgent attention', the safety of those using the installation may be at risk**, and it is recommended that a competent person undertake the necessary remedial work without delay.

For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a competent person. The maximum time interval recommended before the next inspection is stated in the Report under "Next Inspection."

DISTRIBUTION BOARD DETAILS

DB ref:	DB2 Apartments	Z _s at this board (Ω):	0.79	I _{pf} at this board (KA):	0.29	Main switch type BSEN reference:	60947-3 Isolator	Rating:	100 Amps	Supply conductors:	25 mm ²	Earth:	16 mm ²
---------	----------------	-----------------------------------	------	-------------------------------------	------	-------------------------------------	---------------------	---------	----------	--------------------	--------------------	--------	--------------------

Distribution board location:	Cellar	Supplied from:	Mains	No. Of phases:	Single	Supply protective device type: BSEN reference:	BS3161 Fuse HBC - Type 2	Rating:	100 Amps
------------------------------	--------	----------------	-------	----------------	--------	---	-----------------------------	---------	----------

CIRCUIT DETAILS TEST RESULTS

Circuit Reference	Circuit designation	Type of wiring	Reference method	Number of points served	Circuit conductors		Max. Disconnection time permitted (s)	Overcurrent devices			RCD		Circuit impedances Ω					Insulation resistance				RCD			
					Live (mm ²)	cpc (mm ²)		Type BS EN	Rating (A)	Short circuit capacity (KA)	IΔn mA	Maximum permitted Zs Ω	Ring final circuits only (Measured end to end)			All circuits (At least one column to be completed)		Phase /Phase M Ω	Phase /Neutral M Ω	Phase /Earth M Ω	Neutral /Earth M Ω	Polarity	Maximum Measured Zs Ω	At IΔn ms	At 5 x IΔn ms
													r ₁	r _n	r ₂	R ₁ + R ₂	R ₂								

1	Apt 1	A	B	1	16	6	0.4	60898 Type B	63	6	30	1.44	N/A	N/A	N/A	1.15	N/A	N/A	>199	>199	>199	√				
2	Apt 5	A	B	1	16	6	0.4	60898 Type B	63	6	30	1.44	N/A	N/A	N/A	1.15	N/A	N/A	>199	>199	>199	√				
3	Apt 6	A	B	1	16	6	0.4	60898 Type B	63	6	30	1.44	N/A	N/A	N/A	1.17	N/A	N/A	>199	>199	>199	√				
4	Apt 4	A	B	1	16	6	0.4	60898 Type B	63	6	30	1.44	N/A	N/A	N/A	1.21	N/A	N/A	>199	>199	>199	√				
5	Apt 2	A	B	1	16	6	0.4	60898 Type B	63	6	30	1.44	N/A	N/A	N/A	1.14	N/A	N/A	>199	>199	>199	√				
6	Apt 3	A	B	1	16	6	0.4	60898 Type B	63	6	30	1.44	N/A	N/A	N/A	1.18	N/A	N/A	>199	>199	>199	√				

CODES FOR TYPES OF WIRING								
A	B	C	D	E	F	G	H	O (other please state)
PVC/PVC CABLES	PVC CABLES IN METALLIC CONDUIT	PVC CABLES IN NON-METALIC CONDUIT	PVC CABLES IN METALIC TRUNKING	PVC CABLES IN NON-METALIC TRUNKING	PVC/SWA CABLES	XLPE/SWA CABLES	MINERAL-INSULATED CABLES	