



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. No detailed internal inspection of flues (Integrity, Constructions and Lining) has been carried out.

Certificate Reference

8 Turnberry Court 18

Certificate No: Certificate -10568

Engineers Details

Trading Title Eastwood Heating And Gas

Address 17 Eastwood Gardens
Kenton
Newcastle upon Tyne

Post Code: NE3 3DP

Gas Safe No: 222266

Telephone No: 07904329008

Installation Details

Installation Address 8 Turnberry Court
Gateshead
Tyne And Wear

Post Code: NE10 8DF

Client Details

Client Address Daniel Craig Residential
307 Chilling ham Road
Heaton
Newcastle upon Tyne

Post Code: NE6 5SB

Telephone No:

Telephone No: 01912656555

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading	CO Reading	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
	Garage	Combi boiler	Ideal	LOGIC COMBI 30	8.3	43	Room	YES	0.0005	YES	30 kw	YES	YES	YES	PASS	NO	YES

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number Of Appliances Tested:

1

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sat-10-08-2019

Installation Pass:

YES

CO Alarm fitted and working?

NO

Smoke alarm fitted and working?

YES

This Gas Safety Report was created by Gas Checker Software 2016 all rights reserved www.gaschecker.co.uk

Signatures

Report Issued By:

Name: Colin Crozier

Signed:

Date:

Mon-13-08-2018

Report Received By:

Name:

Signed:

Date:

Mon-13-08-2018

Gas ID Number:

4334501