



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

843 Chorley Old Road,25

Certificate No: A1845

Engineers Details

Trading Title: Safe Direct Gas Limited

Address: 10 Gilnow Road, Bolton
Post Code: BL1 4LJ

Gas Safe No: 301096 Telephone No: 07787733717

Installation Details

Installation Address: Sheraz Rasul, 843 Chorley Old Road, Bolton
Post Code: BL1 5SL

Telephone No: 07869127513

Client Details

Client Address: Sheraz Rasul, 843 Chorley Old Road, Bolton
Post Code: BL1 5SL

Telephone No: 07869127513

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input (KW) or Operating Pressure (Mbar)	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/IO) (IO - Visual Inspection Only)	FlueType (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Combi boiler	Worcester Bosch	Green Star 25i	0.0003	0.0006	19 mb	69	YES	RS	YES	YES	YES	YES	NA	NO	YES
2	Kitchen	Cooker	LOGIK	LFSTG50W	0	0.017	19 mb	0	YES	OF	YES	YES	YES	YES	NA	NO	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: YES NO

Gas Tightness Satisfactory: YES NO

Gas Installation Pipework Visual Inspection Satisfactory: YES NO

Number of Appliances Tested: Equipotential Bonding: YES NO

NEXT INSPECTION DUE ON OR BEFORE: Installation Pass: YES NO

CO Alarm fitted & working? YES NO Smoke alarm fitted & working? YES NO

Signatures

Report Issued By:

Name: Muhammad Asjad

Signed:

Date: Tue-15-04-2025

Report Received By:

Name: Sheraz Rasul

Signed:

Date: Tue-15-04-2025

Gas ID Number: