

Energy performance certificate (EPC)

Manor Farm Barn High Street Offord D'Arcy PE19 5RF	Energy rating A	Valid until: 8 September 2032 Certificate number: 6795-3601-2891-0568-7650
---	-------------------------------	---

Property type

B1 Offices and Workshop businesses

Total floor area


160 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is A.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

23 | A

If typical of the existing stock

66 | C

Breakdown of this property’s energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Mixed-mode with Natural Ventilation
Assessment level	4
Building emission rate (kgCO2/m2 per year)	29.93
Primary energy use (kWh/m2 per year)	177

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0097-0102-1342-6031-6340\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Robin Thom
Telephone	07908 718784
Email	robin@sapratings.com

Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/003606
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

Assessment details

Employer	Green Heat Ltd
Employer address	190 Whitehouse Common Road, Sutton Coldfield, Birmingham, B75 6DN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	9 September 2022
Date of certificate	9 September 2022
