



Grenville Court, Britwell Road, Burnham, Slough SL1 8DF

T 0345 111 7700 **W** vitaldirect.co.uk


ENERGY PERFORMANCE CERTIFICATE

**37 West Street
Marlow
SL7 2LS**

17th June 2026

UK-wide services

- Energy Performance Certificates
- EPC Plus Upgrade reports
- Display Energy Certificates
- Asbestos Surveys
- Decarbonisation reports
- Heat Network regulations & ESOS
- FRA & GRA Assessments
- Air-conditioning Inspections



Energy performance certificate (EPC)			
37 West Street MARLOW SL7 2LS	Energy rating D	Valid until:	16 June 2036
		Certificate number:	6668-5616-4329-2172-1996

Property type	Retail/Financial and Professional Services
Total floor area	228 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built	27 B
If typical of the existing stock	107 E

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	31.79
Primary energy use (kWh/m ² per year)	201

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/8576-3814-1371-8394-0364\)](/energy-certificate/8576-3814-1371-8394-0364).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Rohiya Tazmeen
Telephone	02087440544
Email	info@seaconsulting.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/028737
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	SEAConsulting.co.uk
Employer address	Unit 11 Teddington Business Park Station Road Teddington TW11 9BQ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 June 2026
Date of certificate	17 June 2026

Energy performance certificate (EPC) recommendation report

37 West Street
MARLOW
SL7 2LS

Report number
8576-3814-1371-8394-0364

Valid until
16 June 2036

Energy rating and EPC

This property's energy rating is D.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Replace 38mm diameter (T12) fluorescent tubes on failure with 26mm (T8) tubes.	Medium
Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	Low
In some spaces, the solar gain limit defined in the NCM is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	Medium

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Add optimum start/stop to the heating system.	Medium
Some walls have uninsulated cavities - introduce cavity wall insulation.	Medium
Some windows have high U-values - consider installing secondary glazing.	Medium
Add weather compensation controls to heating system.	Medium
Some loft spaces are poorly insulated - install/improve insulation.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Add local time control to heating system.	Medium
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	Medium
Consider replacing heating boiler plant with a condensing type.	High
Consider switching from gas to biomass.	High
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium

Property and report details

Report issued on	17 June 2026
Total useful floor area	228 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	DesignBuilder Software Ltd, DesignBuilder SBEM, v7.3.1, SBEM, v6.1.e.2

Assessor's details

Assessor's name	Rohiya Tazmeen
Telephone	02087440544
Email	info@seaconsulting.co.uk
Employer's name	SEAConsulting.co.uk
Employer's address	Unit 11 Teddington Business Park Station Road Teddington TW11 9BQ
Assessor ID	EES/028737
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Elmhurst Energy Systems Ltd